

Boiler 1 Daily Emissions Report

1/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	24.91	0.018	4.97	0.014
1	0.096	28.46	0.028	8.38	0.013
2	0.084	24.75	0.032	9.5	0.013
3	0.09	26.08	0.044	12.74	0.016
4	0.093	26.52	0.036	10.25	0.014
5	0.09	26.62	0.028	8.28	0.013
6	0.088	25.7	0.028	8.06	0.013
7	0.091	26.47	0.027	7.81	0.014
8	0.099	30.56	0.031	9.47	0.014
9	0.088	25.46	0.026	7.49	0.014
10	0.084	24.91	0.028	8.18	0.013
11	0.089	26.51	0.031	9.19	0.013
12	0.09	26.57	0.031	9.02	0.013
13	0.091	26.08	0.034	9.6	0.014
14	0.09	26.39	0.024	6.95	0.013
15	0.091	26.92	0.022	6.66	0.013
16	0.094	28.53	0.032	9.86	0.013
17	0.059	17.65	0.03	9.03	0.013
18	0.062	18.56	0.022	6.5	0.013
19	0.087	26.17	0.025	7.48	0.013
20	0.089	27.16	0.026	7.78	0.013
21	0.091	26.21	0.027	7.73	0.013
22	0.09	26.83	0.03	8.98	0.013
23	0.088	25.85	0.023	6.85	0.013
Average	0.088		0.028		0.013
Total		619.87		200.76	
30-Day Rlng	0.092		0.027		
365-Day Rlng				61540	

1/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.92	0.035	10.47	0.013
1	0.088	26.01	0.027	7.95	0.013
2	0.087	26.04	0.023	6.72	0.013
3	0.084	25.06	0.031	9.21	0.013
4	0.093	28.01	0.027	8.14	0.013
5	0.086	25.45	0.027	7.94	0.013
6	0.091	26.05	0.025	7.32	0.014
7	0.093	28.33	0.031	9.62	0.013
8	0.079	24.9	0.024	7.42	0.013
9	0.087	25.45	0.028	8.22	0.013
10	0.084	24.68	0.031	9.02	0.013
11	0.082	23.85	0.028	8.14	0.013
12	0.086	25.54	0.026	7.71	0.013
13	0.088	26.1	0.028	8.33	0.013

14	0.092	26.55	0.027	7.91	0.013
15	0.087	24.71	0.022	6.36	0.013
16	0.092	26.88	0.034	10.09	0.014
17	0.09	25.59	0.034	9.8	0.014
18	0.092	26.17	0.023	6.49	0.014
19	0.091	26.6	0.031	9.14	0.014
20	0.09	26.15	0.034	10.01	0.015
21	0.09	26.14	0.027	7.66	0.014
22	0.094	27.71	0.022	6.43	0.014
23	0.089	25.85	0.018	5.36	0.014
Average	0.089		0.028		0.013
Total		624.74		195.46	
30-Day Rlng	0.092		0.027		
365-Day Rlng				61554	

1/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.41	0.027	8.05	0.014
1	0.089	25.96	0.017	4.97	0.014
2	0.091	27.17	0.022	6.44	0.014
3	0.092	26.84	0.028	8.22	0.014
4	0.089	26.29	0.032	9.59	0.014
5	0.09	26.34	0.024	6.96	0.013
6	0.093	26.55	0.026	7.37	0.013
7	0.088	26.27	0.031	9.33	0.013
8	0.069	20.63	0.025	7.47	0.015
9	0.092	26.22	0.031	8.84	0.013
10	0.092	25.9	0.023	6.42	0.013
11	0.087	25.18	0.034	9.91	0.013
12	0.091	26.61	0.036	10.47	0.013
13	0.084	24.32	0.027	7.81	0.013
14	0.095	27.03	0.033	9.36	0.013
15	0.092	26.28	0.03	8.4	0.013
16	0.089	25.68	0.029	8.23	0.013
17	0.085	25.07	0.032	9.48	0.013
18	0.092	26.06	0.023	6.42	0.013
19	0.091	26.08	0.044	12.54	0.014
20	0.093	27.14	0.028	8.23	0.013
21	0.089	25.83	0.035	10.09	0.013
22	0.094	26.81	0.023	6.56	0.014
23	0.086	24.95	0.024	6.92	0.014
Average	0.089		0.029		0.013
Total		621.62		198.08	
30-Day Rlng	0.093		0.027		
365-Day Rlng				61565	

1/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	26.88	0.03	8.59	0.014

1	0.091	26.4	0.034	9.77	0.014
2	0.092	26.4	0.017	4.86	0.014
3	0.095	26.93	0.022	6.43	0.014
4	0.092	26.15	0.033	9.28	0.014
5	0.092	26.47	0.024	6.73	0.014
6	0.092	26.38	0.026	7.57	0.014
7	0.082	24.24	0.039	11.53	0.014
8	0.078	22.51	0.025	7.21	0.014
9	0.094	25.86	0.035	9.65	0.014
10	0.092	26.41	0.03	8.66	0.014
11	0.093	26.58	0.027	7.78	0.014
12	0.093	26.11	0.028	8.01	0.014
13	0.089	26.26	0.032	9.48	0.013
14	0.089	25.84	0.028	8.19	0.013
15	0.087	25.31	0.031	8.99	0.013
16	0.091	26.43	0.026	7.53	0.013
17	0.087	25.06	0.025	7.37	0.014
18	0.089	25.36	0.028	8.06	0.014
19	0.095	27.83	0.03	8.78	0.013
20	0.083	23.99	0.036	10.55	0.015
21	0.093	27.21	0.026	7.67	0.013
22	0.09	25.88	0.023	6.66	0.014
23	0.091	26.35	0.018	5.32	0.014
Average	0.09		0.028		0.014
Total		622.84		194.67	
30-Day Rlng	0.093		0.027		
365-Day Rlng				61626	

1/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	27.31	0.02	5.69	0.014
1	0.092	26.45	0.038	10.98	0.014
2	0.09	26.8	0.022	6.41	0.013
3	0.092	26.71	0.023	6.57	0.014
4	0.09	26.24	0.027	7.92	0.014
5	0.091	26.61	0.025	7.28	0.014
6	0.091	26.54	0.029	8.62	0.014
7	0.084	24.21	0.025	7.05	0.014
8	0.072	21.47	0.025	7.7	0.014
9	0.089	25.75	0.028	8	0.013
10	0.095	27.52	0.031	8.95	0.013
11	0.086	24.76	0.028	7.98	0.013
12	0.092	26.22	0.026	7.37	0.013
13	0.089	26.61	0.03	8.84	0.013
14	0.089	26.42	0.027	7.94	0.013
15	0.087	25.47	0.029	8.63	0.013
16	0.083	24.35	0.029	8.43	0.013
17	0.09	26.42	0.027	8.03	0.013

18	0.092	25.77	0.03	8.52	0.014
19	0.094	27.26	0.029	8.27	0.013
20	0.093	26.54	0.026	7.35	0.014
21	0.091	26.19	0.025	7.12	0.014
22	0.09	26.09	0.021	6.19	0.013
23	0.091	26.95	0.019	5.5	0.013
Average	0.09		0.027		0.013
Total		624.66		185.34	
30-Day Rlng	0.093		0.028		
365-Day Rlng				61678	

1/6/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	26.07	0.026	7.34	0.014
1	0.089	26	0.019	5.56	0.013
2	0.09	26.3	0.015	4.54	0.013
3	0.09	25.96	0.022	6.43	0.013
4	0.094	27.43	0.032	9.27	0.013
5	0.093	26.77	0.027	7.95	0.013
6	0.093	26.62	0.024	6.79	0.013
7	0.082	24.99	0.028	8.33	0.013
8	0.075	19.31	0.018	4.95	0.013
9	0.09	23.48	0.028	7.26	0.013
10	0.08	20.25	0.022	5.54	0.013
11	0.064	15.94	0.037	9.22	0.015
12	0.085	22.1	0.026	6.89	0.013
13	0.095	26.6	0.029	7.93	0.013
14	0.095	27.29	0.035	10.03	0.013
15	0.084	23.41	0.036	9.98	0.013
16	0.091	25.64	0.028	7.84	0.013
17	0.088	25.15	0.022	6.33	0.013
18	0.092	26.31	0.029	8.17	0.013
19	0.097	28.23	0.032	9.42	0.013
20	0.089	25.37	0.025	7.17	0.013
21	0.092	26.31	0.03	8.64	0.013
22	0.095	26.77	0.031	8.85	0.013
23	0.091	26.35	0.031	9.07	0.013
Average	0.089		0.027		0.013
Total		598.65		183.5	
30-Day Rlng	0.093		0.028		
365-Day Rlng				61720	

1/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	25.74	0.027	7.65	0.013
1	0.095	27.51	0.037	10.71	0.013
2	0.09	25.65	0.029	8.13	0.013
3	0.093	26.59	0.022	6.23	0.013
4	0.092	26.78	0.031	9.12	0.013

5	0.091	26.41	0.031	8.95	0.013
6	0.087	24.89	0.026	7.53	0.013
7	0.081	24.44	0.032	9.54	0.013
8	0.07	22.85	0.037	12.28	0.014
9	0.084	24.72	0.022	6.59	0.013
10	0.088	26.15	0.034	10.23	0.013
11	0.083	24.22	0.038	11.13	0.013
12	0.087	23.85	0.032	8.83	0.013
13	0.042	11.99	0.033	9.33	0.013
14	0.066	18.7	0.039	11.03	0.013
15	0.095	25.68	0.029	7.83	0.013
16	0.092	26.44	0.033	9.46	0.013
17	0.095	27.05	0.03	8.68	0.013
18	0.091	25.12	0.04	10.97	0.014
19	0.096	26.88	0.04	11.14	0.014
20	0.096	26.28	0.031	8.43	0.014
21	0.096	26.08	0.045	12.21	0.014
22	0.101	27.12	0.026	6.84	0.015
23	0.084	20.22	0.018	4.36	0.016
Average	0.087		0.032		0.013
Total		591.36		217.2	
30-Day Rlng	0.093		0.028		
365-Day Rlng				61782	

1/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.06	14.57	0.017	4.01	0.014
1	0.082	23.26	0.035	9.95	0.014
2	0.093	26.88	0.027	7.91	0.013
3	0.09	26.12	0.03	8.66	0.013
4	0.089	26.21	0.034	10.15	0.013
5	0.086	21.04	0.017	4.1	0.014
6	0.093	26.73	0.032	9.07	0.013
7	0.088	25.9	0.035	10.34	0.013
8	0.084	26.13	0.027	8.53	0.013
9	0.086	24.75	0.023	6.75	0.013
10	0.087	25.66	0.034	10.06	0.013
11	0.091	26.65	0.043	12.65	0.013
12	0.092	25.92	0.03	8.55	0.013
13	0.096	27.55	0.023	6.68	0.013
14	0.089	26.25	0.033	9.6	0.013
15	0.092	27.32	0.028	8.33	0.013
16	0.089	26.66	0.033	9.84	0.013
17	0.088	25.66	0.041	11.79	0.013
18	0.092	26.31	0.03	8.68	0.013
19	0.091	26.58	0.026	7.67	0.013
20	0.089	26.06	0.032	9.28	0.013
21	0.09	26.03	0.036	10.3	0.013

	22	0.092	26.8	0.033	9.46	0.013
	23	0.092	26.87	0.032	9.34	0.013
Average		0.088		0.03		0.013
Total			611.91		211.7	
30-Day Rlng		0.091		0.027		
365-Day Rlng					61891	

1/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.77	0.031	8.84	0.013
1	0.093	26.5	0.04	11.3	0.013
2	0.097	27.31	0.033	9.19	0.014
3	0.093	26.11	0.038	10.8	0.013
4	0.095	26.65	0.031	8.56	0.014
5	0.092	26.69	0.034	9.84	0.013
6	0.085	24.96	0.039	11.45	0.013
7	0.091	27.36	0.036	10.86	0.013
8	0.064	19.91	0.027	8.41	0.014
9	0.09	26.3	0.029	8.59	0.013
10	0.086	25.6	0.032	9.38	0.014
11	0.088	25.72	0.04	11.57	0.013
12	0.093	26.6	0.032	9.11	0.013
13	0.087	26.32	0.026	7.77	0.013
14	0.081	22.98	0.023	6.51	0.015
15	0.077	18.68	0.015	3.69	0.013
16	0.093	23.29	0.024	6.02	0.013
17	0.105	27.73	0.029	7.89	0.015
18	0.087	25.25	0.028	8.25	0.013
19	0.091	27.1	0.036	10.52	0.013
20	0.088	26.56	0.028	8.41	0.013
21	0.088	26.13	0.024	7.12	0.013
22	0.09	27.24	0.032	9.79	0.013
23	0.089	26.16	0.037	10.82	0.013
Average	0.089		0.031		0.013
Total		612.92		214.69	
30-Day Rlng	0.09		0.027		
365-Day Rlng				61964	

1/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.098	23.36	0.016	3.88	0.014
1	0.098	23.98	0.016	3.79	0.014
2	0.09	22.86	0.018	4.48	0.013
3	0.092	22.94	0.018	4.37	0.013
4	0.09	24	0.025	6.86	0.013
5	0.09	26.76	0.035	10.39	0.013
6	0.089	25.3	0.032	9.19	0.013
7	0.083	25.03	0.02	6.12	0.013
8	0.092	28.49	0.022	6.9	0.013

9	0.09	25.38	0.024	6.72	0.013
10	0.091	26.11	0.02	5.76	0.013
11	0.091	26.47	0.022	6.25	0.013
12	0.09	25.38	0.032	8.93	0.013
13	0.089	25.25	0.025	7.16	0.013
14	0.097	27.19	0.035	9.83	0.013
15	0.091	25.46	0.027	7.46	0.013
16	0.094	26.91	0.022	6.16	0.013
17	0.087	25.06	0.022	6.36	0.013
18	0.095	26.7	0.023	6.37	0.013
19	0.093	27.5	0.028	8.27	0.013
20	0.087	25.02	0.029	8.23	0.013
21	0.089	25.58	0.028	8.02	0.013
22	0.093	26.46	0.029	8.25	0.013
23	0.092	26.17	0.017	4.71	0.013
Average	0.091		0.024		0.013
Total		613.36		164.46	
30-Day Rlng	0.09		0.027		
365-Day Rlng				61942	

1/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.6	0.028	7.78	0.013
1	0.094	26.99	0.034	9.94	0.013
2	0.093	26.65	0.03	8.64	0.014
3	0.092	25.77	0.038	10.69	0.014
4	0.093	26.91	0.024	7.05	0.013
5	0.091	26.58	0.029	8.36	0.013
6	0.088	25.16	0.024	6.9	0.013
7	0.092	27.53	0.035	10.63	0.013
8 Cal	Cal	Cal	Cal	Cal	
9	0.094	26.42	0.025	6.99	0.013
10	0.093	26.44	0.031	9.03	0.013
11	0.092	27.39	0.029	8.48	0.013
12	0.092	26.7	0.025	7.19	0.014
13	0.088	26.61	0.036	10.71	0.013
14	0.086	25.68	0.025	7.37	0.013
15	0.089	26.29	0.029	8.58	0.013
16	0.089	26.85	0.03	9.04	0.013
17	0.087	26.13	0.021	6.4	0.013
18	0.09	25.98	0.026	7.59	0.013
19	0.092	27.53	0.026	7.83	0.013
20	0.081	24.01	0.019	5.56	0.013
21	0.082	24.21	0.023	6.81	0.013
22	0.08	23.79	0.025	7.37	0.013
23	0.079	23.4	0.028	8.26	0.013
Average	0.089		0.028		0.013
Total		598.62		187.2	

30-Day Rlng	0.09	0.027	
365-Day Rlng			61952
1/12/2020			
Hour			
	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu
0	0.085	24.79	0.028
1	0.087	26.24	0.023
2	0.088	25.58	0.038
3	0.088	25.29	0.027
4	0.085	25.22	0.029
5	0.086	25.15	0.026
6	0.088	25.69	0.024
7	0.091	26.72	0.023
8	0.089	25.79	0.023
9	0.091	26.17	0.017
10	0.088	25.52	0.026
11	0.09	26.85	0.023
12	0.09	26.2	0.018
13	0.089	26.61	0.022
14	0.085	25.34	0.024
15	0.088	26.54	0.02
16	0.086	26.17	0.022
17	0.083	25.33	0.025
18	0.086	26.07	0.024
19	0.086	25.59	0.023
20	0.082	24.6	0.033
21	0.088	26.14	0.023
22	0.09	25.6	0.032
23	0.089	26.09	0.018
Average	0.087		0.025
Total		619.29	173.74
30-Day Rlng	0.09	0.027	
365-Day Rlng			61952
1/13/2020			
Hour			
	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu
0	0.084	24.78	0.024
1	0.091	27.14	0.021
2	0.087	26.21	0.029
3	0.089	26.08	0.023
4	0.083	25.06	0.027
5	0.09	27.13	0.022
6	0.091	26.33	0.028
7	0.091	26.53	0.019
8	0.092	26.9	0.027
9	0.092	26.8	0.034
10	0.09	26.27	0.017
11	0.091	26.28	0.023
12	0.092	26.2	0.026

13	0.087	25.02	0.031	8.96	0.013
14	0.087	26.51	0.019	5.75	0.012
15	0.086	25.45	0.025	7.43	0.013
16	0.088	26.54	0.022	6.5	0.013
17	0.088	26.65	0.018	5.31	0.013
18	0.088	26.17	0.016	4.9	0.013
19	0.086	25.94	0.02	6.15	0.013
20	0.083	24.25	0.023	6.77	0.013
21	0.086	24.36	0.021	5.94	0.014
22	0.087	25.96	0.025	7.51	0.013
23	0.086	25.76	0.028	8.22	0.013
Average	0.088		0.024		0.013
Total		624.32		167.55	
30-Day Rlng	0.09		0.027		
365-Day Rlng				61938	

1/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	26.71	0.026	7.74	0.013
1	0.085	25.68	0.026	7.94	0.013
2	0.082	24.57	0.03	9.05	0.013
3	0.085	25.03	0.025	7.2	0.013
4	0.09	26.9	0.024	7.01	0.013
5	0.084	25.4	0.027	8.2	0.013
6	0.089	26.11	0.027	7.85	0.013
7	0.09	26.66	0.019	5.53	0.013
8	0.09	26.75	0.023	6.91	0.013
9	0.089	26.01	0.022	6.43	0.013
10	0.091	26.71	0.022	6.45	0.013
11	0.088	25.97	0.023	6.83	0.013
12	0.093	27.22	0.029	8.6	0.013
13	0.087	25.84	0.023	6.78	0.013
14	0.088	26.9	0.021	6.28	0.013
15	0.092	27.53	0.027	8	0.013
16	0.088	26.55	0.026	7.89	0.013
17	0.084	25.59	0.028	8.51	0.013
18	0.089	26.22	0.024	7.11	0.013
19	0.087	26.16	0.026	7.71	0.013
20	0.085	25.74	0.027	8.29	0.013
21	0.085	25.29	0.022	6.72	0.013
22	0.087	25.42	0.028	8.09	0.013
23	0.083	24.65	0.025	7.25	0.013
Average	0.088		0.025		0.013
Total		625.61		178.37	
30-Day Rlng	0.09		0.027		
365-Day Rlng				61936	

1/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
------	--------------	---------	--------------	---------	-------------

0	0.085	25.47	0.03	8.89	0.013
1	0.085	25.87	0.032	9.79	0.013
2	0.087	26.07	0.026	7.64	0.013
3	0.087	26.3	0.021	6.42	0.013
4	0.086	25.99	0.033	9.88	0.013
5	0.072	21.73	0.023	7.02	0.013
6	0.086	25.57	0.028	8.3	0.013
7	0.09	27.1	0.029	8.85	0.013
8	0.089	26.21	0.022	6.58	0.013
9	0.084	24.28	0.02	5.83	0.013
10	0.091	26.18	0.023	6.68	0.013
11	0.088	25.26	0.021	6	0.013
12	0.093	26.2	0.025	6.94	0.013
13	0.095	27.45	0.027	7.75	0.013
14	0.091	26.19	0.025	7.36	0.013
15	0.085	24.53	0.016	4.59	0.013
16	0.09	26.09	0.025	7.22	0.013
17	0.093	26.92	0.025	7.29	0.013
18	0.09	25.69	0.021	5.96	0.013
19	0.085	25.83	0.037	11.33	0.013
20	0.086	25.48	0.03	8.97	0.013
21	0.088	26.02	0.039	11.49	0.013
22	0.087	25.4	0.03	8.77	0.013
23	0.085	25.02	0.015	4.4	0.013
Average	0.087		0.026		0.013
Total		616.85		183.95	
30-Day Rlng	0.09		0.027		
365-Day Rlng				61930	

1/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.078	22.69	0.025	7.05	0.013
1	0.086	25.54	0.032	9.64	0.013
2	0.082	24.73	0.021	6.31	0.013
3	0.086	25.6	0.027	8.08	0.013
4	0.088	26.28	0.029	8.52	0.013
5	0.088	26.74	0.028	8.51	0.013
6	0.089	26.4	0.033	9.87	0.013
7	0.088	27.48	0.046	14.3	0.013
8	0.077	23.95	0.032	10.13	0.013
9	0.088	26.02	0.026	7.69	0.013
10	0.093	27.05	0.035	10.18	0.013
11	0.089	26.67	0.034	10.33	0.013
12	0.09	25.93	0.034	9.58	0.013
13	0.092	26.45	0.027	7.79	0.013
14	0.092	26.89	0.018	5.35	0.013
15	0.091	27.08	0.039	11.57	0.013
16	0.09	26.41	0.039	11.37	0.013

17	0.092	26.08	0.031	8.77	0.013
18	0.089	25.28	0.016	4.46	0.013
19	0.084	25.62	0.029	8.84	0.013
20	0.082	24.04	0.047	13.55	0.013
21	0.092	26.51	0.048	13.69	0.013
22	0.043	11.46	0.027	7.32	0.014
23	0.024	6.94	0.023	6.46	0.014
Average	0.083		0.031		0.013
Total		587.84		219.36	
30-Day Rlng	0.089		0.027		
365-Day Rlng				61968	

1/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.057	15.65	0.032	8.85	0.014
1	0.097	27.11	0.041	11.4	0.014
2	0.095	26.6	0.034	9.56	0.014
3	0.096	26.44	0.04	10.98	0.014
4	0.063	17.35	0.027	7.45	0.014
5	0.098	27.25	0.024	6.59	0.014
6	0.092	26.14	0.027	7.57	0.014
7	0.092	27.28	0.029	8.56	0.014
8	0.08	23.97	0.016	4.96	0.014
9	0.09	27.04	0.027	8.21	0.013
10	0.089	26.46	0.029	8.75	0.013
11	0.09	26.83	0.029	8.68	0.013
12	0.089	26.28	0.023	6.84	0.013
13	0.088	26.66	0.019	5.86	0.013
14	0.089	26.51	0.022	6.75	0.013
15	0.089	25.84	0.023	6.75	0.013
16	0.092	27.31	0.026	7.68	0.013
17	0.089	26.16	0.03	8.78	0.013
18	0.087	26.37	0.027	8.14	0.013
19	0.092	25.99	0.036	10.19	0.013
20	0.094	26.75	0.03	8.4	0.013
21	0.095	26.22	0.026	7.29	0.014
22	0.094	26.4	0.029	8.3	0.014
23	0.096	26.85	0.025	7.09	0.014
Average	0.089		0.028		0.014
Total		615.46		193.63	
30-Day Rlng	0.089		0.027		
365-Day Rlng				61987	

1/18/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.097	26.43	0.019	5.21	0.014
1	0.094	26.43	0.036	10.23	0.014
2	0.096	26.83	0.027	7.61	0.014
3	0.095	26.4	0.055	15.26	0.014

4	0.097	26.71	0.018	4.83	0.014
5	0.094	26.79	0.02	5.71	0.014
6	0.093	26.72	0.026	7.47	0.013
7	0.093	27.8	0.028	8.42	0.013
8	0.087	25.72	0.032	9.48	0.014
9	0.092	26.06	0.022	6.14	0.014
10	0.095	27.1	0.033	9.51	0.013
11	0.095	26.35	0.029	7.96	0.014
12	0.099	26.37	0.031	8.28	0.014
13	0.1	26.87	0.031	8.4	0.014
14	0.098	26.21	0.041	11.05	0.014
15	0.096	26.21	0.027	7.41	0.014
16	0.096	26.42	0.033	9.23	0.014
17	0.09	25.28	0.024	6.67	0.013
18	0.092	27.18	0.021	6.26	0.013
19	0.09	26.79	0.024	7.25	0.013
20	0.088	26.29	0.037	10.91	0.013
21	0.092	26.78	0.034	9.95	0.013
22	0.091	26.25	0.026	7.43	0.013
23	0.084	25.2	0.021	6.2	0.013
Average	0.094		0.029		0.014
Total		635.19		196.87	
30-Day Rlng	0.089		0.027		
365-Day Rlng				62018	

1/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	25.9	0.027	7.43	0.013
1	0.093	26.65	0.033	9.42	0.013
2	0.092	26.45	0.024	6.89	0.013
3	0.083	24.58	0.046	13.58	0.014
4	0.09	26.36	0.025	7.35	0.013
5	0.092	26.53	0.033	9.61	0.013
6	0.093	26.81	0.024	6.95	0.013
7	0.093	27.63	0.036	10.69	0.013
8	0.085	25.92	0.022	6.64	0.013
9	0.092	26.54	0.034	9.78	0.013
10	0.093	26.94	0.028	8.12	0.013
11	0.093	26.44	0.022	6.24	0.013
12	0.096	26.68	0.026	7.13	0.013
13	0.092	26.48	0.028	7.93	0.013
14	0.093	26.81	0.033	9.57	0.013
15	0.093	26.21	0.03	8.34	0.013
16	0.093	26.96	0.03	8.83	0.013
17	0.092	26.31	0.034	9.6	0.013
18	0.085	24.1	0.023	6.63	0.015
19	0.094	27.08	0.021	6.09	0.013
20	0.093	26.34	0.019	5.34	0.013

21	0.093	26.85	0.032	9.11	0.013
22	0.086	24.85	0.026	7.65	0.013
23	0.093	26.99	0.027	7.81	0.013
Average	0.091		0.028		0.013

Total 632.41 196.73
 30-Day Rlng 0.089 0.027
 365-Day Rlng 62020

1/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	26.41	0.026	7.45	0.013
1	0.092	27.16	0.029	8.48	0.013
2	0.091	26.79	0.025	7.48	0.013
3	0.09	26.37	0.023	6.73	0.013
4	0.09	26.91	0.021	6.37	0.013
5	0.091	26.84	0.017	5.09	0.013
6	0.083	23.9	0.028	7.88	0.015
7	0.087	26.01	0.026	7.75	0.013
8	0.079	24.51	0.029	8.94	0.013
9	0.087	25.72	0.026	7.64	0.013
10	0.09	26.39	0.027	7.91	0.013
11	0.09	26.66	0.029	8.7	0.013
12	0.093	26.68	0.026	7.65	0.013
13	0.09	25.76	0.023	6.68	0.013
14	0.089	26.24	0.022	6.53	0.013
15	0.078	23.09	0.024	7.16	0.013
16	0.088	26.21	0.035	10.43	0.013
17	0.088	26.43	0.023	6.95	0.013
18	0.086	25.85	0.023	7.11	0.013
19	0.088	26.4	0.015	4.39	0.013
20	0.088	26.56	0.017	5.13	0.013
21	0.089	26.68	0.021	6.27	0.013
22	0.087	26.58	0.022	6.62	0.013
23	0.086	26.34	0.023	6.94	0.013
Average	0.088		0.024		0.013
Total		626.49		172.28	
30-Day Rlng	0.089		0.027		
365-Day Rlng				62006	

1/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	26.05	0.025	7.63	0.013
1	0.089	26.39	0.018	5.37	0.013
2	0.089	26.47	0.032	9.59	0.013
3	0.088	26.45	0.02	6.1	0.013
4	0.089	26.61	0.026	7.88	0.013
5	0.09	26.58	0.021	6.19	0.013
6	0.091	27	0.03	8.86	0.013
7	0.091	27.05	0.027	8.13	0.013

8	0.077	24.25	0.016	4.93	0.013
9	0.085	25.13	0.029	8.65	0.013
10	0.089	26.5	0.029	8.42	0.013
11	0.09	26.7	0.034	10.15	0.013
12	0.089	25.51	0.037	10.65	0.013
13	0.089	25.45	0.03	8.5	0.013
14	0.094	27	0.026	7.43	0.013
15	0.091	26.34	0.035	10.09	0.013
16	0.092	27.12	0.021	6.21	0.013
17	0.087	25.37	0.023	6.57	0.013
18	0.089	26.21	0.021	6.36	0.013
19	0.089	25.9	0.026	7.67	0.013
20	0.091	26.72	0.024	6.97	0.013
21	0.092	26.72	0.018	5.03	0.013
22	0.086	25.37	0.026	7.56	0.013
23	0.091	26.54	0.026	7.54	0.013
Average	0.089		0.026		0.013
Total		629.43		182.48	
30-Day Rlng	0.089		0.027		
365-Day Rlng				61993	

1/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.69	0.029	8.56	0.013
1	0.091	26.31	0.022	6.36	0.013
2	0.091	26.74	0.028	8.06	0.013
3	0.091	26.61	0.028	8.13	0.013
4	0.09	26.44	0.031	9.3	0.013
5	0.091	26.44	0.022	6.36	0.013
6	0.08	23.6	0.022	6.55	0.013
7	0.068	20.58	0.022	6.56	0.013
8	0.071	22.04	0.018	5.65	0.013
9	0.083	25.1	0.025	7.66	0.013
10	0.087	26.14	0.022	6.7	0.013
11	0.086	25.84	0.027	7.92	0.013
12	0.086	25.7	0.036	10.85	0.013
13	0.086	25.89	0.017	5.23	0.012
14	0.088	26	0.024	7.11	0.013
15	0.089	26.41	0.018	5.42	0.012
16	0.089	26.57	0.023	6.74	0.012
17	0.087	25.55	0.018	5.18	0.013
18	0.091	26.81	0.021	6.25	0.013
19	0.089	26.07	0.021	6.27	0.013
20	0.089	25.88	0.026	7.54	0.013
21	0.094	27.13	0.025	7.17	0.013
22	0.091	26.99	0.021	6.13	0.013
23	0.089	26	0.027	7.93	0.013
Average	0.087		0.024		0.013

Total		616.53		169.63	
30-Day Rlng	0.089		0.027		
365-Day Rlng				61980	
1/23/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.1	0.029	8.55	0.013
1	0.093	27.28	0.03	8.61	0.013
2	0.092	26.7	0.02	5.8	0.013
3	0.094	27.17	0.03	8.82	0.013
4	0.091	26.6	0.018	5.19	0.013
5	0.09	26.55	0.018	5.39	0.013
6	0.089	25.79	0.024	6.83	0.013
7	0.09	26.59	0.03	8.66	0.013
8	0.089	27	0.034	10.56	0.013
9	0.079	22.3	0.038	10.77	0.013
10	0.088	25.49	0.037	10.61	0.013
11	0.092	26.77	0.022	6.29	0.013
12	0.086	24.75	0.039	11.04	0.013
13	0.087	26.51	0.034	10.39	0.013
14	0.088	26.67	0.036	10.9	0.013
15	0.086	25.83	0.023	6.75	0.013
16	0.088	26.92	0.03	9.23	0.013
17	0.088	26.82	0.033	10.04	0.013
18	0.087	25.97	0.018	5.55	0.013
19	0.086	26.43	0.025	7.5	0.013
20	0.087	26.71	0.016	5.03	0.013
21	0.088	25.96	0.017	5.03	0.013
22	0.088	26.83	0.023	7.14	0.013
23	0.088	26.44	0.02	6	0.013
Average	0.089		0.027		0.013
Total		630.18		190.68	
30-Day Rlng	0.089		0.027		
365-Day Rlng				61997	
1/24/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	25.66	0.032	9.76	0.013
1	0.084	25.34	0.018	5.49	0.013
2	0.091	27.38	0.018	5.4	0.013
3	0.087	26.17	0.019	5.53	0.013
4	0.087	26.49	0.032	9.71	0.013
5	0.087	26.52	0.019	5.86	0.013
6	0.088	26.79	0.027	8.35	0.013
7	0.082	25.98	0.026	8.2	0.012
8	0.074	23.62	0.027	8.81	0.013
9	0.085	26.68	0.03	9.24	0.012
10	0.081	25.17	0.028	8.82	0.012
11	0.081	25.06	0.027	8.27	0.012

12	0.087	26.75	0.031	9.39	0.012
13	0.075	22.79	0.034	10.47	0.012
14	0.089	27.05	0.029	8.71	0.012
15	0.088	26.26	0.028	8.56	0.012
16	0.085	25.32	0.019	5.65	0.013
17	0.091	27.16	0.025	7.58	0.013
18	0.088	26.43	0.026	7.78	0.012
19	0.087	26.64	0.032	9.65	0.012
20	0.088	26.66	0.026	7.8	0.013
21	0.088	26.55	0.031	9.3	0.012
22	0.086	26.17	0.029	8.66	0.013
23	0.089	27.14	0.028	8.42	0.013
Average	0.086		0.027		0.013
Total		625.78		195.41	
30-Day Rlng	0.089		0.027		
365-Day Rlng				62009	

1/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	26.55	0.018	5.55	0.013
1	0.088	26.52	0.028	8.36	0.013
2	0.088	26.51	0.03	9.13	0.013
3	0.089	26.96	0.028	8.4	0.012
4	0.086	26.05	0.03	9.2	0.012
5	0.087	26.76	0.027	8.27	0.012
6	0.086	25.94	0.027	8.13	0.012
7	0.083	25.71	0.037	11.35	0.012
8	0.078	25.34	0.025	8.1	0.012
9	0.079	24.34	0.021	6.43	0.013
10	0.084	25.73	0.022	6.66	0.012
11	0.083	25.5	0.015	4.75	0.012
12	0.081	23.79	0.023	6.74	0.012
13	0.093	28.25	0.031	9.33	0.012
14	0.085	25.83	0.024	7.15	0.012
15	0.087	25.84	0.025	7.33	0.012
16	0.088	26.69	0.035	10.56	0.012
17	0.09	26.74	0.027	8.1	0.012
18	0.085	25.25	0.027	7.89	0.012
19	0.089	26.81	0.03	9.08	0.012
20	0.088	26.5	0.023	6.93	0.012
21	0.091	26.74	0.035	10.09	0.013
22	0.087	26.12	0.03	9.15	0.012
23	0.091	27.03	0.021	6.29	0.013
Average	0.086		0.027		0.012
Total		627.5		192.97	
30-Day Rlng	0.089		0.027		
365-Day Rlng				62016	

1/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	25.45	0.029	8.68	0.012
1	0.089	26.71	0.025	7.56	0.013
2	0.092	26.81	0.04	11.67	0.013
3	0.089	26.08	0.035	10.35	0.013
4	0.091	26.65	0.027	8.01	0.013
5	0.09	26.93	0.022	6.76	0.013
6	0.091	26.69	0.023	6.94	0.013
7	0.086	26.92	0.031	9.65	0.012
8	0.073	23.35	0.035	11.47	0.013
9	0.088	26.41	0.031	9.2	0.014
10	0.086	25.65	0.033	9.84	0.013
11	0.09	26.43	0.03	8.75	0.013
12	0.089	26.26	0.023	6.74	0.013
13	0.088	26.53	0.026	7.91	0.014
14	0.089	27.22	0.026	7.86	0.012
15	0.083	23.96	0.039	11.33	0.013
16	0.09	26.59	0.023	6.74	0.013
17	0.089	26.66	0.027	8.21	0.013
18	0.089	25.98	0.022	6.43	0.013
19	0.09	27.3	0.032	9.72	0.012
20	0.088	26.33	0.039	11.63	0.013
21	0.092	25.97	0.029	8.05	0.013
22	0.092	27.31	0.022	6.53	0.013
23	0.086	26.37	0.027	8.25	0.012
Average	0.088		0.029		0.013
Total		630.56		208.28	
30-Day Rng	0.089		0.027		
365-Day Rng				62043	

1/27/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	25.84	0.038	11.41	0.013
1	0.091	26.31	0.034	9.97	0.013
2	0.092	26.7	0.036	10.29	0.013
3	0.091	26.44	0.027	7.68	0.013
4	0.091	26.83	0.034	10.01	0.013
5	0.09	26.38	0.027	7.89	0.013
6	0.089	26.64	0.033	9.81	0.013
7	0.088	26.73	0.027	8.03	0.013
8	0.082	25.99	0.026	8.23	0.013
9	0.09	25.8	0.034	9.57	0.013
10	0.092	26.73	0.038	11.01	0.013
11	0.093	26.81	0.033	9.52	0.013
12	0.097	26.25	0.038	10.2	0.014
13	0.096	26.59	0.039	10.95	0.013
14	0.1	26.95	0.027	7.43	0.014
15	0.097	26.46	0.026	7.08	0.014

16	0.082	23.61	0.03	8.6	0.013
17	0.093	26.93	0.025	7.13	0.013
18	0.092	26.52	0.02	5.84	0.013
19	0.091	26.52	0.029	8.5	0.013
20	0.091	26.37	0.031	8.99	0.013
21	0.092	26.14	0.022	6.31	0.013
22	0.09	26.53	0.025	7.43	0.013
23	0.092	26.95	0.034	9.95	0.013
Average	0.091		0.031		0.013
Total		633.02		211.83	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62074	

1/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.52	0.027	7.6	0.013
1	0.094	26.99	0.031	8.89	0.013
2	0.092	26.93	0.029	8.56	0.013
3	0.091	26.49	0.025	7.31	0.013
4	0.09	26.9	0.031	9.09	0.013
5	0.09	26.73	0.033	9.83	0.013
6	0.092	26.36	0.023	6.5	0.013
7	0.091	27.62	0.026	7.96	0.013
8	0.072	21.82	0.03	9.23	0.013
9	0.09	26.55	0.027	7.99	0.013
10	0.089	26.64	0.035	10.39	0.013
11	0.088	26.02	0.032	9.46	0.013
12	0.092	27.3	0.038	11.2	0.013
13	0.085	25.55	0.025	7.61	0.013
14	0.088	26.18	0.044	13.05	0.013
15	0.092	25.81	0.031	8.75	0.013
16	0.091	26.79	0.03	8.72	0.013
17	0.091	26.95	0.021	6.15	0.013
18	0.093	23.3	0.019	4.74	0.013
19	0.1	27.09	0.028	7.56	0.013
20	0.09	26.09	0.032	9.22	0.013
21	0.092	26.71	0.036	10.45	0.013
22	0.089	26.38	0.027	8.02	0.013
23	0.092	27.5	0.026	7.91	0.013
Average	0.09		0.029		0.013
Total		630.22		206.19	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62104	

1/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	25.32	0.034	10	0.013
1	0.091	26.63	0.027	8.02	0.013
2	0.09	26.47	0.025	7.38	0.013

3	0.089	26.7	0.031	9.15	0.013
4	0.088	27.25	0.019	6.08	0.012
5	0.086	25.81	0.026	7.78	0.013
6	0.09	26.62	0.024	7.26	0.013
7	0.093	28.29	0.032	10.07	0.013
8	0.073	22.64	0.034	11.02	0.013
9	0.088	25.49	0.036	10.3	0.013
10	0.095	26.99	0.024	6.95	0.013
11	0.091	25.68	0.015	4.32	0.013
12	0.084	24.69	0.025	7.36	0.013
13	0.09	26.76	0.032	9.67	0.013
14	0.089	26.95	0.023	6.84	0.013
15	0.088	25.59	0.035	10.2	0.013
16	0.088	26.47	0.023	6.85	0.013
17	0.089	27.23	0.017	5.08	0.013
18	0.082	24.26	0.018	5.29	0.013
19	0.089	26.86	0.028	8.54	0.013
20	0.088	26.47	0.024	7.26	0.013
21	0.09	26.71	0.03	9.04	0.012
22	0.088	26	0.022	6.55	0.013
23	0.09	26.61	0.03	8.75	0.013
Average		0.088	0.026		0.013
Total		628.49		189.76	
30-Day Rlng	0.089		0.027		
365-Day Rlng				62103	

1/30/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.26	0.018	5.19	0.013
1	0.093	27.05	0.035	10.1	0.013
2	0.089	26.4	0.03	8.94	0.013
3	0.089	26.58	0.029	8.6	0.013
4	0.089	26.59	0.026	7.74	0.013
5	0.09	27.33	0.028	8.38	0.012
6	0.087	26.22	0.029	8.82	0.012
7	0.088	25.72	0.048	14.03	0.013
8	0.091	27.91	0.024	7.44	0.013
9	0.081	23.17	0.029	8.19	0.013
10	0.093	27.02	0.034	9.91	0.013
11	0.09	26.04	0.044	12.68	0.013
12	0.088	25.81	0.033	9.56	0.013
13	0.091	26.4	0.045	13	0.013
14	0.09	25.99	0.033	9.6	0.013
15	0.095	26.81	0.037	10.36	0.013
16	0.091	26.66	0.019	5.7	0.013
17	0.091	26.78	0.017	4.93	0.013
18	0.091	26.89	0.031	9.19	0.013
19	0.086	25.46	0.026	7.79	0.013

20	0.088	25.72	0.028	8.21	0.013
21	0.088	25.69	0.029	8.41	0.013
22	0.088	25.97	0.027	7.95	0.013
23	0.091	27.31	0.025	7.63	0.013

Average 0.09 0.03 0.013

Total 631.78 212.35

30-Day Rlng 0.089 0.028

365-Day Rlng 62133

1/31/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.082	24.12	0.026	7.47	0.013
1	0.09	26.47	0.027	7.89	0.013
2	0.09	26.32	0.03	8.78	0.013
3	0.09	26.17	0.037	10.83	0.013
4	0.089	25.75	0.028	7.96	0.013
5	0.093	27.19	0.02	6.04	0.013
6	0.089	25.88	0.034	9.79	0.013
7	0.093	27.91	0.026	7.73	0.013
8	0.086	24.86	0.024	6.81	0.013
9	0.092	26.33	0.026	7.38	0.013
10	0.095	26.25	0.023	6.39	0.013
11	0.093	26.47	0.03	8.44	0.013
12	0.092	26.05	0.027	7.72	0.013
13	0.089	26.16	0.029	8.53	0.013
14	0.093	26.66	0.019	5.36	0.013
15	0.092	26.28	0.028	8.02	0.013
16	0.096	26.75	0.024	6.66	0.013
17	0.091	26.55	0.032	9.51	0.012
18	0.092	26.84	0.022	6.43	0.012
19	0.089	26.52	0.026	7.92	0.013
20	0.088	26.14	0.028	8.31	0.013
21	0.089	26.24	0.025	7.37	0.013
22	0.089	26.46	0.032	9.32	0.013
23	0.085	25.25	0.028	8.28	0.013
Average	0.09		0.027		0.013
Total		629.62		188.94	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62142	

2/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.84	0.034	9.86	0.013
1	0.09	26.51	0.028	8.18	0.013
2	0.092	27.14	0.029	8.6	0.013
3	0.09	26.5	0.027	7.9	0.013
4	0.086	25.41	0.03	8.77	0.013
5	0.085	25.26	0.03	8.81	0.013
6	0.091	26.26	0.028	8.09	0.013

7	0.092	26.62	0.028	8	0.013
8	0.095	29.16	0.033	10.05	0.013
9	0.092	27.62	0.03	9.2	0.013
10	0.087	25.69	0.028	8.25	0.013
11	0.091	26.23	0.025	7.33	0.013
12	0.095	27.78	0.03	8.83	0.012
13	0.09	25.98	0.023	6.78	0.012
14	0.091	26.51	0.023	6.63	0.012
15	0.089	26.09	0.023	6.8	0.012
16	0.09	26.51	0.027	7.88	0.012
17	0.093	27.16	0.024	6.94	0.013
18	0.091	26.35	0.029	8.51	0.012
19	0.09	26.91	0.028	8.26	0.012
20	0.089	26.6	0.028	8.26	0.012
21	0.084	24.64	0.029	8.64	0.013
22	0.085	25.38	0.026	7.65	0.013
23	0.085	25.4	0.026	7.87	0.013
Average	0.09		0.028		0.013
Total		633.55		196.09	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62163	

2/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.53	0.032	9.54	0.013
1	0.085	25.66	0.026	7.81	0.013
2	0.088	26.26	0.032	9.41	0.013
3	0.087	25.56	0.026	7.76	0.013
4	0.089	26.77	0.028	8.6	0.013
5	0.09	27	0.031	9.26	0.013
6	0.091	26.24	0.027	7.85	0.013
7	0.089	26.45	0.02	5.9	0.013
8	0.092	28.85	0.033	10.21	0.013
9	0.085	25.13	0.03	8.97	0.013
10	0.09	27.33	0.022	6.68	0.012
11	0.089	26.84	0.03	9.17	0.012
12	0.085	25.43	0.029	8.77	0.012
13	0.087	26.07	0.029	8.83	0.012
14	0.089	26.63	0.029	8.71	0.012
15	0.091	27.02	0.028	8.21	0.012
16	0.087	25.98	0.029	8.62	0.012
17	0.089	27.15	0.026	7.74	0.012
18	0.084	24.96	0.024	7.25	0.013
19	0.089	27.16	0.038	11.75	0.013
20	0.083	24.71	0.035	10.46	0.013
21	0.088	26.63	0.035	10.6	0.013
22	0.087	26.69	0.027	8.38	0.013
23	0.086	26.66	0.028	8.51	0.012

Average	0.088	0.029	0.013
Total	633.71	208.99	
30-Day Rlng	0.089	0.028	
365-Day Rlng		62196	

2/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.32	0.032	9.25	0.013
1	0.088	26.76	0.031	9.55	0.012
2	0.087	26.29	0.022	6.71	0.013
3	0.088	27.38	0.034	10.66	0.012
4	0.085	25.81	0.029	8.68	0.012
5	0.085	25.63	0.029	8.67	0.013
6	0.086	25.55	0.034	10.19	0.013
7	0.091	26.93	0.024	7.1	0.013
8	0.09	29.62	0.036	11.68	0.012
9	0.087	26.07	0.026	7.75	0.013
10	0.09	27.28	0.025	7.58	0.013
11	0.088	26.35	0.027	8.2	0.013
12	0.089	26.23	0.036	10.59	0.013
13	0.09	26.85	0.031	9.17	0.013
14	0.089	26.15	0.026	7.59	0.013
15	0.092	26.78	0.028	8.21	0.013
16	0.088	26.12	0.026	7.75	0.013
17	0.091	27.29	0.035	10.49	0.013
18	0.091	26.6	0.037	10.96	0.013
19	0.091	26.95	0.023	6.86	0.013
20	0.084	24.65	0.031	9.01	0.013
21	0.094	27.62	0.02	6.06	0.013
22	0.09	26.25	0.037	10.71	0.013
23	0.091	26.44	0.031	9.09	0.013
Average	0.089	0.03		0.013	
Total	637.92	212.51			
30-Day Rlng	0.089	0.028			
365-Day Rlng		62218			

2/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.084	24.32	0.017	4.84	0.013
1	0.09	26.53	0.031	9.04	0.013
2	0.092	26.78	0.025	7.42	0.013
3	0.091	26.43	0.031	8.94	0.013
4	0.089	26.39	0.023	6.96	0.013
5	0.091	27.37	0.03	9.06	0.013
6	0.089	26.13	0.022	6.51	0.013
7	0.093	26.53	0.026	7.61	0.013
8	0.083	25.76	0.018	5.51	0.013
9	0.092	27.33	0.03	8.84	0.013
10	0.091	26.69	0.026	7.73	0.013

11	0.09	26.61	0.032	9.32	0.013
12	0.09	26.67	0.028	8.27	0.013
13	0.09	26.7	0.035	10.4	0.013
14	0.09	26.08	0.021	6.08	0.013
15	0.093	27.42	0.026	7.62	0.013
16	0.089	26.55	0.027	7.97	0.013
17	0.089	26.37	0.035	10.35	0.013
18	0.091	26.31	0.032	9.23	0.013
19	0.083	24.33	0.028	8.14	0.013
20	0.084	24.97	0.023	6.8	0.013
21	0.09	26.25	0.038	11.17	0.013
22	0.09	26.41	0.041	12.04	0.013
23	0.089	26.53	0.026	7.81	0.013
Average		0.089	0.028		0.013
Total		631.46		197.66	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62223	
2/5/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	27.3	0.031	9.3	0.013
1	0.088	26.21	0.027	8.08	0.013
2	0.09	26.36	0.035	10.31	0.013
3	0.09	26.55	0.023	6.73	0.013
4	0.088	26.15	0.044	13.13	0.013
5	0.089	26.03	0.02	6.02	0.013
6	0.09	25.73	0.022	6.44	0.013
7	0.092	27.5	0.037	11.19	0.013
8	0.087	27.65	0.019	6.15	0.013
9	0.087	25.98	0.034	10.06	0.013
10	0.091	27.02	0.024	7.13	0.013
11	0.089	26.16	0.022	6.42	0.013
12	0.091	26.5	0.033	9.62	0.013
13	0.088	25.58	0.024	7	0.013
14	0.095	27.86	0.032	9.46	0.013
15	0.091	26.88	0.03	8.85	0.013
16	0.087	25.88	0.034	10.2	0.013
17	0.088	26.14	0.034	10.06	0.013
18	0.092	26.49	0.03	8.59	0.013
19	0.089	26.37	0.032	9.57	0.013
20	0.09	26.81	0.026	7.76	0.013
21	0.091	27.19	0.021	6.37	0.013
22	0.089	26.65	0.034	10.15	0.013
23	0.091	26.74	0.031	9.17	0.013
Average	0.09		0.029		0.013
Total		637.73		207.76	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62249	

2/6/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.15	0.031	9.18	0.013
1	0.092	27.06	0.033	9.68	0.013
2	0.09	26.37	0.051	14.87	0.013
3	0.091	26.15	0.024	6.82	0.013
4	0.091	26.17	0.027	7.8	0.013
5	0.094	26.97	0.034	9.8	0.013
6	0.093	26.24	0.024	6.82	0.013
7	0.095	27.84	0.037	10.94	0.013
8	0.096	29.54	0.055	17.6	0.013
9	0.094	25.89	0.021	5.62	0.014
10	0.094	26.51	0.023	6.55	0.014
11	0.095	26.55	0.034	9.64	0.014
12	0.096	26.6	0.032	8.79	0.014
13	0.097	26.86	0.036	9.97	0.014
14	0.098	26.77	0.027	7.53	0.014
15	0.094	26.37	0.034	9.52	0.013
16	0.092	27.24	0.028	8.22	0.013
17	0.089	26.3	0.031	9.12	0.015
18	0.091	26.89	0.024	7.14	0.013
19	0.089	26.72	0.039	11.54	0.013
20	0.089	25.86	0.036	10.4	0.013
21	0.094	26.86	0.033	9.45	0.013
22	0.093	26.75	0.051	14.57	0.013
23	0.092	27.01	0.018	5.34	0.013
Average	0.093		0.033		0.013
Total		641.67		226.91	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62292	

2/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.61	0.045	13.29	0.013
1	0.093	26.1	0.041	11.44	0.014
2	0.097	26.7	0.032	8.9	0.014
3	0.092	26.47	0.031	8.73	0.013
4	0.093	27.08	0.048	13.85	0.013
5	0.091	26.62	0.04	11.69	0.013
6	0.091	25.57	0.022	6.17	0.014
7	0.092	26.52	0.034	9.64	0.013
8	0.076	22.83	0.047	14.73	0.014
9	0.09	25.61	0.029	8.26	0.014
10	0.093	26.81	0.02	5.84	0.013
11	0.093	27.06	0.032	9.28	0.013
12	0.089	25.21	0.029	8.1	0.013
13	0.09	26.42	0.035	10.3	0.013
14	0.083	24.19	0.032	9.28	0.013

15	0.083	24.45	0.027	7.85	0.013
16	0.085	24.94	0.037	10.71	0.013
17	0.09	26.32	0.03	8.81	0.013
18	0.088	25.68	0.026	7.47	0.013
19	0.09	26.65	0.03	8.76	0.013
20	0.092	26.68	0.022	6.41	0.013
21	0.09	26.84	0.024	7.07	0.013
22	0.09	26.45	0.016	4.74	0.013
23	0.089	26.27	0.015	4.49	0.013
Average	0.09		0.031		0.013
Total		624.08		215.81	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62316	

2/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	26.68	0.016	4.53	0.013
1	0.092	26.93	0.028	8.26	0.013
2	0.091	26.65	0.023	6.62	0.013
3	0.09	26.22	0.018	5.16	0.013
4	0.09	26.8	0.022	6.67	0.013
5	0.09	26.76	0.016	4.85	0.013
6	0.088	26.01	0.017	5.07	0.013
7	0.084	24.49	0.02	5.92	0.013
8	0.067	20.61	0.018	5.75	0.013
9	0.085	25	0.032	9.55	0.013
10	0.092	27.08	0.029	8.68	0.013
11	0.088	26.14	0.023	6.81	0.013
12	0.089	25.39	0.025	7.18	0.013
13	0.086	25.68	0.032	9.57	0.013
14	0.09	26.67	0.034	10.17	0.013
15	0.082	24.01	0.034	9.96	0.013
16	0.089	26.58	0.027	7.96	0.013
17	0.085	25.2	0.034	10.16	0.013
18	0.089	25.79	0.022	6.4	0.013
19	0.09	26.28	0.021	6.26	0.013
20	0.091	26.63	0.028	8.22	0.013
21	0.095	26.94	0.03	8.37	0.013
22	0.092	26.48	0.019	5.48	0.013
23	0.092	26.7	0.018	5.18	0.013
Average	0.088		0.024		0.013
Total		621.72		172.78	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62284	

2/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	25.71	0.017	4.63	0.013
1	0.094	27.43	0.029	8.55	0.013

2	0.092	26.62	0.016	4.76	0.013
3	0.088	25.76	0.016	4.77	0.013
4	0.092	26.66	0.03	8.7	0.013
5	0.092	26.61	0.034	9.75	0.013
6	0.093	26.64	0.03	8.59	0.013
7	0.087	25.39	0.016	4.68	0.013
8	0.078	24.16	0.021	6.46	0.013
9	0.091	26.27	0.021	5.99	0.013
10	0.087	25.47	0.026	7.64	0.013
11	0.094	26.27	0.016	4.53	0.013
12	0.093	26.23	0.026	7.43	0.013
13	0.091	26.01	0.029	8.26	0.013
14	0.091	26.48	0.035	10.15	0.013
15	0.092	26.86	0.026	7.53	0.013
16	0.09	26.46	0.03	8.87	0.013
17	0.086	24.73	0.03	8.67	0.013
18	0.094	26.99	0.029	8.25	0.013
19	0.09	25.91	0.022	6.37	0.013
20	0.093	26.63	0.027	7.68	0.013
21	0.093	26.42	0.02	5.76	0.013
22	0.092	26.36	0.029	8.33	0.013
23	0.093	26.47	0.022	6.41	0.013
Average	0.091		0.025		0.013
Total		628.54		172.76	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62291	

2/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	25.79	0.025	7.02	0.013
1	0.095	26.89	0.027	7.76	0.013
2	0.094	26.81	0.029	8.2	0.013
3	0.095	27.15	0.035	9.97	0.013
4	0.092	26.68	0.021	5.97	0.013
5	0.093	27.29	0.021	6.22	0.013
6	0.09	25.65	0.022	6.17	0.013
7	0.081	22.7	0.021	5.78	0.014
8	0.082	25.05	0.02	5.98	0.013
9	0.091	26.46	0.025	7.38	0.013
10	0.09	26.24	0.035	10.11	0.013
11	0.089	25.05	0.02	5.76	0.013
12	0.093	26.66	0.031	8.82	0.013
13	0.083	23.45	0.021	5.93	0.014
14	0.092	26.9	0.031	9.19	0.013
15	0.089	25.71	0.034	9.98	0.013
16	0.088	25.8	0.025	7.38	0.013
17	0.086	25.17	0.024	7.02	0.013
18	0.092	26.16	0.029	8.17	0.013

19	0.094	26.66	0.025	7.08	0.013
20	0.091	26.07	0.025	7.21	0.013
21	0.094	26.73	0.023	6.43	0.013
22	0.094	27	0.032	9.24	0.013
23	0.094	27.43	0.021	6.01	0.013
Average	0.091		0.026		0.013
Total		625.5		178.78	
30-Day Rlng	0.089		0.027		
365-Day Rlng				62294	

2/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	25.29	0.018	4.97	0.013
1	0.095	27.41	0.028	8.07	0.013
2	0.09	25.86	0.032	9.29	0.013
3	0.096	27.08	0.017	4.88	0.013
4	0.09	25.78	0.031	8.82	0.013
5	0.094	26.8	0.017	4.81	0.013
6	0.089	25.16	0.023	6.43	0.013
7	0.085	24.46	0.03	8.63	0.013
8	0.084	25.66	0.022	6.76	0.013
9	0.088	24.89	0.024	6.79	0.013
10	0.091	26.09	0.029	8.41	0.013
11	0.091	26.05	0.034	9.68	0.014
12	0.088	24.44	0.024	6.77	0.013
13	0.091	26.4	0.031	8.97	0.013
14	0.091	26.38	0.026	7.6	0.013
15	0.089	25.16	0.029	8.13	0.013
16	0.093	26.37	0.03	8.41	0.013
17	0.09	25.76	0.026	7.57	0.013
18	0.093	25.63	0.026	7.18	0.013
19	0.094	26.28	0.028	7.98	0.013
20	0.095	26.43	0.015	4.25	0.013
21	0.093	25.49	0.016	4.48	0.013
22	0.096	27.08	0.02	5.78	0.013
23	0.096	27.42	0.026	7.37	0.013
Average	0.091		0.025		0.013
Total		623.37		172.03	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62298	

2/12/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	25.36	0.018	4.94	0.014
1	0.097	27.28	0.024	6.8	0.013
2	0.093	26.58	0.036	10.39	0.013
3	0.095	26.29	0.034	9.34	0.013
4 Inval	Inval	Inval	Inval	Inval	Inval
5 Inval	Inval	Inval	Inval	Inval	Inval

	6 Inval	Inval	Inval	Inval	Inval
7	0.092	26.05	0.031	8.65	0.014
8	0.071	20.34	0.036	10.47	0.014
9	0.094	26.23	0.033	9.23	0.013
10	0.093	25.87	0.024	6.6	0.013
11	0.09	25.77	0.025	7.23	0.013
12	0.094	26	0.03	8.25	0.013
13	0.091	26.07	0.027	7.73	0.013
14	0.09	26.13	0.032	9.37	0.013
15	0.088	24.83	0.02	5.71	0.013
16	0.093	26.25	0.031	8.69	0.013
17	0.091	25.41	0.021	5.89	0.013
18	0.092	25.98	0.029	8.24	0.013
19	0.084	24.19	0.034	9.8	0.013
20	0.091	25.74	0.015	4.4	0.013
21	0.096	27.02	0.018	4.96	0.013
22	0.097	26.98	0.024	6.76	0.013
23	0.093	26.78	0.019	5.45	0.013
Average	0.091		0.027		0.013
Total		541.15		158.9	
30-Day Rlng	0.089		0.028		
365-Day Rlng				62301	

2/13/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	18.52	0.02	4.15	0.021
1	0.206	14.55	0.038	2.61	0.141
2	0.099	15.12	0.024	3.63	0.023
3	0.088	13.6	0.023	3.47	0.02
4	0.104	27.88	0.023	6.42	0.014
5	0.082	24.6	0.022	6.6	0.013
6	0.099	26.14	0.016	4.29	0.014
7	0.088	25.38	0.032	9.21	0.014
8	0.091	27.31	0.018	5.28	0.013
9	0.093	26.42	0.027	7.79	0.013
10	0.091	26.91	0.024	6.98	0.013
11	0.091	26.57	0.029	8.57	0.013
12	0.09	24.79	0.023	6.28	0.013
13	0.097	26.84	0.026	7.06	0.013
14	0.094	26.96	0.029	8.43	0.013
15	0.095	26.16	0.031	8.42	0.016
16	0.091	25.62	0.023	6.55	0.013
17	0.093	26.42	0.026	7.22	0.013
18	0.088	24.89	0.026	7.38	0.013
19	0.094	26.73	0.028	7.93	0.013
20	0.094	27.12	0.032	9.23	0.013
21	0.094	26.51	0.029	8.19	0.013
22	0.094	27.14	0.027	7.67	0.013

	23	0.092	26.34	0.032	9.21	0.013
Average		0.097		0.026		0.02
Total			588.52		162.57	
30-Day Rlng		0.089		0.028		
365-Day Rlng					62283	

2/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.096	26.92	0.027	7.58	0.013
1	0.092	25.54	0.03	8.34	0.013
2	0.096	27.41	0.033	9.4	0.013
3	0.093	26.19	0.024	6.72	0.013
4	0.094	26.89	0.031	9.05	0.013
5	0.093	26.26	0.022	6.08	0.013
6	0.096	26.93	0.026	7.24	0.013
7	0.092	27.11	0.027	7.95	0.013
8	0.08	24.49	0.022	6.73	0.013
9	0.092	26.65	0.021	6.08	0.013
10	0.085	24.82	0.021	6.17	0.013
11	0.093	26.72	0.024	6.8	0.013
12	0.09	24.73	0.024	6.67	0.013
13	0.1	29.09	0.026	7.54	0.013
14	0.083	24.28	0.026	7.52	0.013
15	0.09	26.23	0.023	6.63	0.013
16	0.09	26.05	0.03	8.76	0.013
17	0.093	27.21	0.028	8.26	0.013
18	0.092	26.51	0.032	9.13	0.013
19	0.089	26	0.02	5.89	0.013
20	0.09	25.95	0.021	6.18	0.013
21	0.088	25.6	0.027	7.78	0.013
22	0.091	26.05	0.037	10.73	0.013
23	0.092	26.43	0.023	6.53	0.013
Average	0.091		0.026		0.013
Total		630.06		179.76	
30-Day Rlng		0.09	0.028		
365-Day Rlng				62302	

2/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.77	0.027	7.49	0.013
1	0.095	27.39	0.037	10.59	0.013
2	0.088	25.58	0.035	10.19	0.014
3	0.093	26.73	0.024	7.05	0.013
4	0.09	26.06	0.029	8.39	0.013
5	0.095	28.07	0.029	8.48	0.014
6	0.087	25.01	0.029	8.28	0.013
7	0.091	27.39	0.039	11.74	0.013
8	0.077	22.99	0.036	10.58	0.013
9	0.086	24.54	0.029	8.25	0.013

10	0.094	27.55	0.029	8.42	0.013
11	0.09	25.85	0.015	4.37	0.013
12	0.09	25.55	0.025	7.21	0.013
13	0.091	25.92	0.03	8.58	0.013
14	0.096	27.89	0.034	9.79	0.014
15	0.084	24.24	0.033	9.52	0.013
16	0.083	24.42	0.024	6.98	0.013
17	0.093	27.84	0.03	8.86	0.013
18	0.091	25.48	0.024	6.65	0.013
19	0.089	25.75	0.03	8.82	0.013
20	0.093	27.11	0.037	10.61	0.013
21	0.091	25.7	0.04	11.35	0.013
22	0.094	26.21	0.029	8.08	0.013
23	0.095	26.84	0.019	5.37	0.013
Average	0.09		0.03		0.013
Total		625.88		205.65	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62400	

2/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	26.33	0.019	5.29	0.013
1	0.094	26.42	0.022	6.13	0.013
2	0.094	26.21	0.025	6.86	0.013
3	0.093	26.68	0.023	6.62	0.014
4	0.094	27.25	0.029	8.5	0.013
5	0.091	26.34	0.032	9.15	0.013
6	0.091	26.52	0.032	9.25	0.013
7	0.088	25.38	0.028	7.93	0.013
8	0.08	23.86	0.016	4.69	0.013
9	0.09	25.48	0.024	6.75	0.013
10	0.089	25.63	0.029	8.18	0.013
11	0.088	25.29	0.026	7.45	0.013
12	0.083	23.29	0.02	5.59	0.013
13	0.094	27.47	0.029	8.5	0.013
14	0.089	26.39	0.027	7.88	0.013
15	0.086	24.63	0.023	6.67	0.015
16	0.09	25.84	0.027	7.67	0.013
17	0.086	25.11	0.025	7.42	0.013
18	0.093	26.5	0.029	8.39	0.013
19	0.091	26.25	0.026	7.36	0.013
20	0.094	27.37	0.032	9.24	0.013
21	0.091	26.33	0.017	4.98	0.013
22	0.091	26.71	0.028	8.2	0.013
23	0.087	24.93	0.031	9.04	0.013
Average	0.09		0.026		0.013
Total		622.21		177.74	
30-Day Rlng	0.09		0.028		

365-Day Rlng 62403

2/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.46	0.023	6.61	0.013
1	0.093	27.13	0.031	9.1	0.013
2	0.09	26.51	0.024	7.03	0.013
3	0.092	26.7	0.029	8.51	0.013
4	0.09	26.4	0.029	8.53	0.013
5	0.092	27.15	0.032	9.53	0.013
6	0.088	25.96	0.022	6.42	0.013
7	0.086	26.29	0.019	5.73	0.013
8	0.081	25.66	0.018	5.7	0.013
9	0.091	26.71	0.022	6.48	0.013
10	0.087	26.1	0.028	8.55	0.012
11	0.086	25.61	0.023	6.96	0.012
12	0.089	25.61	0.024	7	0.013
13	0.092	27.26	0.03	8.99	0.012
14	0.086	24.9	0.023	6.58	0.013
15	0.099	25.25	0.019	4.85	0.013
16	0.099	28.55	0.02	5.73	0.013
17	0.092	26.83	0.021	6.08	0.013
18	0.089	25.39	0.022	6.42	0.013
19	0.091	26.01	0.029	8.33	0.013
20	0.094	26.98	0.031	8.87	0.013
21	0.092	26.02	0.032	8.92	0.013
22	0.091	26.33	0.02	5.79	0.013
23	0.092	26.7	0.027	7.8	0.013
Average	0.09		0.025		0.013
Total		631.51		174.51	
30-Day Rlng	0.09		0.027		
365-Day Rlng				62428	

2/18/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.77	0.028	7.96	0.013
1	0.087	25.68	0.03	8.76	0.013
2	0.089	26.68	0.023	6.87	0.013
3	0.09	26.41	0.027	7.79	0.013
4	0.088	25.16	0.026	7.42	0.013
5	0.093	27.14	0.025	7.26	0.013
6	0.091	26.5	0.026	7.53	0.013
7	0.088	25.68	0.023	6.77	0.013
8	0.086	26.91	0.035	10.77	0.013
9	0.086	25.51	0.026	7.56	0.013
10	0.088	26.09	0.025	7.25	0.013
11	0.091	26.48	0.031	8.93	0.013
12	0.086	25	0.025	7.18	0.013
13	0.086	24.72	0.026	7.6	0.013

14	0.094	26.58	0.033	9.48	0.013
15	0.089	25.17	0.024	6.83	0.013
16	0.092	27.01	0.021	6.2	0.013
17	0.09	26.39	0.019	5.42	0.013
18	0.09	25.94	0.029	8.23	0.013
19	0.091	26.18	0.03	8.6	0.013
20	0.091	26.16	0.027	7.78	0.013
21	0.089	25.43	0.025	7.2	0.013
22	0.093	26.14	0.029	8.18	0.013
23	0.093	26.59	0.031	8.86	0.013
Average	0.09		0.027		0.013
Total		625.32		186.43	
30-Day Rlng	0.09		0.027		
365-Day Rlng				62475	

2/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	26.19	0.03	8.37	0.013
1	0.09	26.59	0.031	9.05	0.013
2	0.09	26.11	0.023	6.76	0.013
3	0.094	27.25	0.03	8.56	0.013
4	0.089	25.75	0.027	7.77	0.013
5	0.093	26.75	0.03	8.54	0.013
6	0.09	25.82	0.028	7.96	0.013
7	0.09	26.3	0.019	5.68	0.013
8	0.089	27.41	0.028	8.57	0.013
9	0.093	26.55	0.034	9.54	0.013
10	0.093	26.94	0.017	5	0.013
11	0.088	25.38	0.042	12.01	0.013
12	0.093	25	0.042	11.34	0.013
13	0.101	27.64	0.026	7.21	0.013
14	0.094	26.55	0.031	8.78	0.013
15	0.094	27	0.021	5.9	0.013
16	0.089	26.42	0.024	7.14	0.013
17	0.089	25.83	0.025	7.21	0.013
18	0.089	26.16	0.024	7.14	0.013
19	0.089	25.79	0.029	8.3	0.013
20	0.091	26.28	0.028	8.15	0.013
21	0.091	25.88	0.024	6.71	0.013
22	0.09	25.71	0.027	7.67	0.013
23	0.092	26.1	0.031	8.71	0.013
Average	0.091		0.028		0.013
Total		631.4		192.07	
30-Day Rlng	0.09		0.027		
365-Day Rlng				62519	

2/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	26.77	0.027	7.65	0.013

1	0.089	25.44	0.028	8.07	0.014
2	0.094	26.67	0.025	6.98	0.013
3	0.094	26.77	0.034	9.82	0.013
4	0.088	25.2	0.03	8.53	0.013
5	0.095	27.04	0.032	9.09	0.013
6	0.093	26.67	0.025	7.07	0.013
7	0.097	28.7	0.027	7.96	0.014
8	0.083	25.38	0.035	10.81	0.013
9	0.093	26.77	0.021	6.08	0.013
10	0.096	28.1	0.035	10.22	0.013
11	0.087	24.81	0.027	7.53	0.013
12	0.092	26.19	0.022	6.38	0.013
13	0.094	26.89	0.03	8.59	0.013
14	0.092	26.66	0.028	8.29	0.013
15	0.087	25.2	0.03	8.83	0.012
16	0.094	27.46	0.029	8.54	0.013
17	0.096	27.65	0.024	6.86	0.013
18	0.089	25.39	0.031	8.68	0.013
19	0.092	26.35	0.029	8.44	0.02
20	0.089	25.39	0.03	8.63	0.013
21	0.089	25.03	0.023	6.33	0.013
22	0.091	25.81	0.028	7.92	0.013
23	0.087	24.74	0.031	8.78	0.016
Average	0.092		0.028		0.013
Total		631.08		196.08	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62560	

2/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.22	0.029	8.21	0.013
1	0.088	25.19	0.029	8.14	0.013
2	0.089	25.07	0.03	8.27	0.013
3	0.089	25.24	0.04	11.25	0.013
4	0.086	24.14	0.03	8.53	0.013
5	0.088	24.42	0.027	7.51	0.013
6	0.094	26.42	0.038	10.69	0.013
7	0.09	25.88	0.021	6.15	0.013
8	0.089	26.34	0.018	5.15	0.013
9	0.097	27.97	0.031	8.99	0.013
10	0.088	25.15	0.023	6.49	0.013
11	0.092	26.31	0.031	8.71	0.013
12	0.094	26.53	0.033	9.23	0.013
13	0.093	26.61	0.038	10.71	0.013
14	0.092	27.18	0.027	8.06	0.012
15	0.086	24.4	0.027	7.69	0.013
16	0.09	26.36	0.027	8.05	0.013
17	0.092	26.81	0.03	8.74	0.013

18	0.092	26.36	0.021	6.04	0.013
19	0.089	25.7	0.027	7.96	0.013
20	0.084	23.82	0.024	6.95	0.013
21	0.089	24.9	0.024	6.88	0.013
22	0.093	26.43	0.034	9.62	0.013
23	0.086	24.55	0.025	7.18	0.013
Average	0.09		0.029		0.013
Total		617		195.2	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62604	

2/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.29	0.034	9.66	0.013
1	0.09	25.91	0.031	8.97	0.013
2	0.088	25.04	0.022	6.32	0.013
3	0.092	26.15	0.029	8.19	0.013
4	0.088	25.54	0.028	8.18	0.013
5	0.089	25.7	0.035	10.18	0.013
6	0.09	25.99	0.029	8.39	0.013
7	0.094	27.48	0.032	9.45	0.013
8	0.087	26.76	0.03	9.38	0.013
9	0.085	24.08	0.02	5.63	0.013
10	0.091	26.15	0.027	7.75	0.013
11	0.092	26.55	0.027	7.82	0.013
12	0.096	26.47	0.034	9.47	0.013
13	0.091	25.87	0.039	11.19	0.013
14	0.091	25.92	0.023	6.69	0.013
15	0.09	25.97	0.029	8.37	0.013
16	0.092	26.65	0.03	8.85	0.013
17	0.091	26.65	0.037	10.8	0.013
18	0.09	26.21	0.039	11.25	0.013
19	0.086	25.26	0.027	7.85	0.013
20	0.089	25.68	0.027	7.62	0.013
21	0.085	24.73	0.032	9.14	0.013
22	0.091	26.26	0.023	6.69	0.013
23	0.086	25.02	0.022	6.3	0.013
Average	0.09		0.029		0.013
Total		621.33		204.14	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62671	

2/23/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	26.04	0.021	6.12	0.013
1	0.092	26.88	0.023	6.71	0.013
2	0.089	25.83	0.027	7.91	0.013
3	0.09	26.59	0.022	6.45	0.013
4	0.087	25.34	0.032	9.4	0.013

5	0.09	26.66	0.022	6.42	0.013
6	0.091	26	0.025	7.29	0.013
7	0.086	25.26	0.036	10.53	0.013
8	0.086	26.2	0.033	10.22	0.013
9	0.09	26.67	0.029	8.56	0.013
10	0.089	26.71	0.031	9.25	0.013
11	0.086	25.62	0.024	7.28	0.013
12	0.087	25.6	0.028	8.13	0.012
13	0.088	25.65	0.025	7.49	0.013
14	0.086	25.19	0.038	11.17	0.013
15	0.091	26.08	0.021	6.2	0.014
16	0.091	26.36	0.033	9.52	0.013
17	0.091	25.77	0.034	9.62	0.013
18	0.094	26.91	0.036	10.17	0.013
19	0.088	25.35	0.029	8.18	0.013
20	0.09	26.02	0.038	10.91	0.013
21	0.088	24.89	0.034	9.82	0.013
22	0.095	27.53	0.048	13.94	0.013
23	0.089	25.91	0.03	8.75	0.013
Average	0.089		0.03		0.013
Total		625.06		210.04	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62720	

2/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	24.5	0.032	9.14	0.013
1	0.095	26.96	0.03	8.47	0.013
2	0.091	25.52	0.019	5.35	0.013
3	0.097	27.23	0.025	6.99	0.013
4	0.09	25.66	0.031	8.81	0.013
5	0.094	26.96	0.024	6.84	0.013
6	0.091	25.23	0.034	9.51	0.013
7	0.095	27.15	0.033	9.31	0.013
8	0.088	25.54	0.028	8	0.014
9	0.095	26.96	0.033	9.33	0.013
10	0.09	25.59	0.031	8.88	0.013
11	0.092	26.17	0.028	8.09	0.013
12	0.091	26.17	0.032	9.35	0.013
13	0.091	26.61	0.032	9.3	0.013
14	0.088	25.88	0.031	9.24	0.013
15	0.088	25.42	0.028	8.03	0.013
16	0.092	26.78	0.026	7.59	0.013
17	0.087	25.97	0.031	9.14	0.013
18	0.088	25.36	0.027	7.72	0.013
19	0.091	26.83	0.037	10.92	0.013
20	0.085	24.87	0.02	6.02	0.013
21	0.093	27.2	0.035	10.36	0.013

	22	0.088	25.72	0.037	10.82	0.013
	23	0.088	25.97	0.023	6.69	0.013
Average		0.091		0.029		0.013
Total			626.25		203.9	
30-Day Rlng		0.09		0.028		
365-Day Rlng					62766	

2/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	26.36	0.025	7.18	0.013
1	0.089	25.53	0.036	10.28	0.013
2	0.093	26.16	0.037	10.43	0.013
3	0.092	26.37	0.025	7.16	0.013
4	0.088	25.47	0.031	9.12	0.013
5	0.093	27.25	0.032	9.29	0.013
6	0.092	25.85	0.018	5.18	0.013
7	0.089	25.9	0.038	10.99	0.013
8	0.088	26.46	0.028	8.18	0.013
9	0.09	25.56	0.018	5.17	0.013
10	0.087	23.7	0.027	7.37	0.013
11	0.09	24.17	0.023	6.26	0.013
12	0.097	27.1	0.03	8.39	0.013
13	0.094	26.67	0.034	9.65	0.013
14	0.092	26.23	0.025	7.14	0.013
15	0.092	25.87	0.028	7.91	0.013
16	0.092	26.23	0.028	7.83	0.013
17	0.096	27.23	0.03	8.6	0.013
18	0.091	25.15	0.024	6.57	0.013
19	0.094	26.6	0.027	7.74	0.013
20	0.097	27.27	0.03	8.47	0.013
21	0.092	25.87	0.023	6.37	0.013
22	0.094	26.82	0.026	7.3	0.013
23	0.091	26.05	0.021	5.95	0.013
Average	0.092		0.028		0.013
Total		625.87		188.53	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62785	

2/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	26.29	0.029	8.06	0.013
1	0.086	23.51	0.028	7.52	0.013
2	0.185	18.67	0.034	3.59	Inval
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 DCAL	DCAL	DCAL	DCAL	DCAL	DCAL
8 Down	Down	Down	Down	Down	Down

9 Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down
Average	0.122		0.03	0.013
Total		68.47		19.17
30-Day Rlng	0.091		0.028	
365-Day Rlng				62627

2/27/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 DCAL	DCAL	DCAL	DCAL	DCAL	DCAL
8 DCAL	DCAL	DCAL	DCAL	DCAL	DCAL
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	

30-Day Rlng 0.091 0.028
 365-Day Rlng 62454
 2/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Maint	Maint	Maint	Maint	Maint	Maint
23 Maint	Maint	Maint	Maint	Maint	Maint
Average	Maint	Maint	Maint	Maint	Maint
Total		Maint		Maint	
30-Day Rlng	0.091		0.028		
365-Day Rlng				62296	

2/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Maint	Maint	Maint	Maint	Maint	Maint
1 Maint	Maint	Maint	Maint	Maint	Maint
2 Maint	Maint	Maint	Maint	Maint	Maint
3 Maint	Maint	Maint	Maint	Maint	Maint
4 Maint	Maint	Maint	Maint	Maint	Maint
5 Maint	Maint	Maint	Maint	Maint	Maint
6	0.143	49.45 Cal		Cal	0.013
7	0.117	13.69	0.04	6.1	0.024
8 Cal	Cal	Cal	Cal	Cal	
9 OOC	OOC	OOC	OOC	OOC	OOR
10 OOC	OOC	OOC	OOC	OOC	OOR
11 OOC	OOC	OOC	OOC	OOC	0.021
12	0.068	18.57 Cal		Cal	0.016

13	0.384	41.88	0.038	3.97	Inval
14	0.138	23.28	0.027	4.66	Inval
15	0.106	28.06	0.055	14.62	0.014
16	0.093	25.33	0.027	7.42	0.013
17	0.098	28.11	0.046	13.05	0.013
18	0.095	26.83	0.051	14.24	0.013
19	0.093	25.82	0.051	14.16	0.013
20	0.11	28.53	0.038	10.08	0.014
21	0.11	30.68	0.036	10.06	0.013
22	0.115	32.81	0.037	10.55	0.013
23	0.123	34.82	0.029	8.33	0.013
Average	0.128		0.04		0.015
Total		407.86		117.24	
30-Day Rlng	0.091		0.028		
365-Day Rlng				62404	

3/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	23.01	0.029	7.81	0.014
1	0.097	26.36	0.039	10.72	0.013
2	0.092	24.63	0.032	8.63	0.014
3	0.098	26.05	0.023	6.02	0.014
4	0.094	25.19	0.031	8.28	0.014
5	0.098	26.17	0.04	10.64	0.014
6	0.09	24.05	0.035	9.34	0.014
7	0.09	26.45	0.038	11.23	0.013
8	0.089	26.47	0.04	11.95	0.013
9	0.088	25.28	0.025	7.08	0.013
10	0.093	26.16	0.047	13.12	0.013
11	0.093	26.44	0.019	5.29	0.013
12	0.094	27.01	0.044	12.68	0.013
13	0.091	26.43	0.053	15.29	0.013
14	0.092	25.98	0.022	6.21	0.013
15	0.092	25.87	0.04	11.34	0.013
16	0.089	25.92	0.033	9.6	0.013
17	0.09	26.52	0.031	9.1	0.013
18	0.088	25.76	0.029	8.62	0.013
19	0.092	27.06	0.029	8.63	0.013
20	0.092	26.32	0.028	7.88	0.013
21	0.094	26.65	0.037	10.62	0.013
22	0.093	26.27	0.038	10.94	0.013
23	0.094	26.68	0.03	8.48	0.013
Average	0.092		0.034		0.013
Total		622.73		229.5	
30-Day Rlng	0.092		0.028		
365-Day Rlng				62634	

3/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
------	--------------	---------	--------------	---------	-------------

0	0.094	26.38	0.038	10.77	0.013
1	0.093	26.63	0.037	10.49	0.013
2	0.096	26.54	0.018	5.08	0.014
3	0.097	26.17	0.03	8.03	0.014
4	0.096	26.61	0.032	8.9	0.014
5	0.094	26.14	0.031	8.63	0.014
6	0.087	24.78	0.033	9.43	0.013
7	0.089	27.73	0.028	8.67	0.013
8	0.078	23.2	0.042	13.41	0.013
9	0.096	26.79	0.033	9.18	0.013
10	0.093	26.7	0.034	9.85	0.013
11	0.093	26.09	0.04	11.31	0.013
12	0.089	25.21	0.036	9.98	0.013
13	0.098	27.36	0.04	11.06	0.013
14	0.09	26.59	0.023	6.68	0.013
15	0.09	26.48	0.022	6.67	0.013
16	0.088	26.14	0.035	10.41	0.013
17	0.085	25.78	0.023	6.97	0.013
18	0.086	25.61	0.032	9.46	0.013
19	0.092	26.97	0.024	7.11	0.013
20	0.093	26.77	0.033	9.63	0.013
21	0.091	26.28	0.025	7.03	0.013
22	0.092	26.46	0.018	5.14	0.013
23	0.094	27.02	0.037	10.49	0.013
Average	0.091		0.031		0.013
Total		630.43		214.38	
30-Day Rlng	0.092		0.028		
365-Day Rlng				62848	

3/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	26.41	0.024	6.85	0.013
1	0.092	26.69	0.03	8.72	0.013
2	0.091	26.58	0.027	7.89	0.013
3	0.092	26.26	0.038	10.81	0.013
4	0.093	26.55	0.035	9.9	0.013
5	0.093	26.9	0.032	9.18	0.013
6	0.096	27.53	0.042	12.11	0.013
7	0.096	28.06	0.043	12.67	0.013
8	0.089	29.14	Cal	Cal	0.013
9	0.06	17.22	0.03	8.24	0.013
10	0.095	26.71	0.042	11.71	0.013
11	0.092	25.72	0.05	13.99	0.013
12	0.096	26.39	0.026	7.15	0.013
13	0.097	26.52	0.031	8.59	0.013
14	0.094	26.66	0.033	9.4	0.013
15	0.096	26.91	0.034	9.55	0.013
16	0.093	26.72	0.026	7.46	0.013

17	0.093	26.69	0.02	5.67	0.013
18	0.09	25.81	0.023	6.67	0.013
19	0.092	26.64	0.029	8.36	0.013
20	0.093	27.02	0.035	10.13	0.013
21	0.092	26.52	0.031	9.03	0.013
22	0.092	26.66	0.035	10.06	0.013
23	0.093	27.19	0.03	8.85	0.013
Average	0.092		0.032		0.013
Total		633.5		212.99	
30-Day Rlng	0.092		0.029		
365-Day Rlng				62904	

3/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.6	0.034	9.76	0.013
1	0.092	26.25	0.027	7.8	0.014
2	0.091	26.53	0.03	8.92	0.013
3	0.091	26.31	0.021	6.02	0.013
4	0.092	27.05	0.036	10.72	0.013
5	0.089	25.55	0.035	10.18	0.014
6	0.091	25.61	0.044	12.28	0.014
7	0.094	27.41	0.033	9.7	0.014
8	0.079	24.55	0.031	9.65	0.013
9	0.086	25.27	0.029	8.58	0.013
10	0.091	26.75	0.031	9.11	0.013
11	0.091	26.57	0.03	8.81	0.013
12	0.091	26.55	0.026	7.51	0.013
13	0.091	26.82	0.029	8.49	0.013
14	0.09	26.29	0.028	8.16	0.013
15	0.091	26.14	0.035	10.11	0.013
16	0.091	26.71	0.038	11.03	0.013
17	0.092	26.83	0.033	9.76	0.013
18	0.091	26.24	0.024	6.91	0.013
19	0.091	26.69	0.028	8.12	0.013
20	0.092	27.07	0.032	9.27	0.013
21	0.092	27.26	0.029	8.66	0.013
22	0.089	26.24	0.026	7.69	0.013
23	0.092	27.07	0.03	8.76	0.013
Average	0.09		0.031		0.013
Total		633.36		216	
30-Day Rlng	0.092		0.029		
365-Day Rlng				62945	

3/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	25.86	0.039	11.52	0.013
1	0.094	26.81	0.029	8.17	0.014
2	0.093	26.47	0.02	5.68	0.014
3	0.092	26.86	0.037	10.76	0.013

4	0.091	26.62	0.037	10.81	0.013
5	0.093	27.13	0.029	8.51	0.013
6	0.091	26.36	0.025	7.15	0.013
7	0.092	27.63	0.031	9.43	0.013
8	0.075	22.72	0.024	7.34	0.013
9	0.09	26.13	0.029	8.35	0.013
10	0.09	26.46	0.032	9.41	0.013
11	0.093	27.04	0.018	5.28	0.013
12	0.092	26.23	0.018	5.14	0.013
13	0.09	26.27	0.031	8.96	0.013
14	0.095	27.36	0.03	8.6	0.013
15	0.091	25.92	0.031	8.93	0.013
16	0.091	26.42	0.034	9.75	0.013
17	0.093	26.81	0.032	9.26	0.013
18	0.09	25.9	0.037	10.57	0.013
19	0.094	27.48	0.027	8.01	0.013
20	0.09	26.57	0.024	7.06	0.013
21	0.091	26.7	0.028	8.24	0.013
22	0.09	26.15	0.031	9.05	0.013
23	0.092	27.03	0.027	7.83	0.013
Average	0.091		0.029		0.013
Total		634.93		203.81	
30-Day Rlng	0.092		0.029		
365-Day Rlng				62955	

3/6/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.53	0.029	8.59	0.013
1	0.091	26.48	0.028	8.19	0.013
2	0.091	26.95	0.027	8.05	0.013
3	0.089	26.41	0.031	9.14	0.013
4	0.09	26.76	0.027	8.08	0.013
5	0.091	26.62	0.029	8.55	0.013
6	0.091	26.58	0.031	8.88	0.013
7	0.093	27.74	0.027	8.08	0.013
8	0.087	26.92	0.027	8.26	0.014
9	0.089	26.01	0.026	7.62	0.014
10	0.091	26.34	0.026	7.43	0.014
11	0.097	29.75	0.021	6.44	0.013
12 Maint	Maint	Maint	Maint	Maint	Maint
13	0.1	26.35	0.028	7.62	0.014
14	0.101	26.13	0.035	9.22	0.014
15	0.103	26.5	0.025	6.43	0.014
16	0.104	27.3	0.039	10.29	0.014
17	0.098	26.16	0.03	8.1	0.013
18	0.099	25.91	0.032	8.51	0.014
19	0.101	26.94	0.025	6.83	0.014
20	0.093	25.02	0.035	9.37	0.014

21	0.087	23.36	0.034	9.18	0.013
22	0.093	25.55	0.038	10.37	0.013
23	0.097	26.09	0.026	7.15	0.014
Average	0.094		0.029		0.013
Total		608.4		190.38	
30-Day Rlng	0.092		0.029		
365-Day Rlng				62926	

3/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.096	25.29	0.037	9.68	0.014
1	0.097	26.32	0.027	7.3	0.014
2	0.095	25.54	0.037	10.01	0.014
3	0.098	26.64	0.031	8.54	0.013
4	0.097	26.48	0.034	9.42	0.013
5	0.093	25.37	0.039	10.59	0.014
6	0.098	26.61	0.023	6.21	0.014
7	0.1	28.12	0.032	8.8	0.013
8	0.097	28.78	0.03	9.12	0.013
9	0.09	25.3	0.029	8.09	0.013
10	0.098	27.09	0.042	11.61	0.013
11	0.095	25.74	0.027	7.18	0.014
12	0.097	25.9	0.018	4.68	0.014
13	0.101	27.8	0.033	9.11	0.013
14	0.097	26.12	0.032	8.57	0.014
15	0.095	22.33	0.025	5.91	0.015
16	0.095	25.94	0.026	6.93	0.013
17	0.099	26.66	0.018	4.71	0.013
18	0.097	25.79	0.025	6.62	0.014
19	0.095	25.69	0.031	8.25	0.014
20	0.096	26.09	0.031	8.57	0.013
21	0.092	24.74	0.024	6.3	0.014
22	0.095	26.01	0.028	7.61	0.014
23	0.093	25.68	0.029	8.06	0.013
Average	0.096		0.03		0.014
Total		626.03		191.87	
30-Day Rlng	0.092		0.029		
365-Day Rlng				62949	

3/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	24.64	0.027	7.38	0.014
1	0.095	26.31	0.034	9.37	0.013
2	0.094	25.5	0.028	7.66	0.014
3	0.094	25.5	0.033	8.78	0.013
4	0.092	25.25	0.031	8.48	0.013
5	0.097	26.6	0.035	9.73	0.013
6	0.1	26.99	0.034	9.26	0.014
7	0.101	28.32	0.031	8.71	0.013

8	0.088	25.19	0.022	6.45	0.013
9	0.095	26.11	0.032	8.69	0.013
10	0.106	28.22	0.034	9.06	0.014
11	0.086	23.71	0.035	9.78	0.013
12	0.093	25.54	0.022	6.11	0.014
13	0.1	27.47	0.034	9.44	0.014
14	0.096	26.19	0.024	6.42	0.014
15	0.097	26.47	0.022	6.07	0.014
16	0.096	26.18	0.031	8.47	0.014
17	0.097	26.42	0.034	9.3	0.014
18	0.095	26.24	0.033	9.15	0.013
19	0.09	24.2	0.033	8.9	0.014
20	0.095	25.03	0.024	6.39	0.014
21	0.094	25.19	0.031	8.23	0.014
22	0.096	26.05	0.032	8.63	0.014
23	0.1	26.44	0.026	6.89	0.014
Average	0.095		0.03		0.014
Total		623.76		197.35	
30-Day Rlng	0.092		0.029		
365-Day Rlng				63001	

3/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.097	25.4	0.032	8.25	0.014
1	0.096	25.66	0.039	10.47	0.014
2	0.098	26.21	0.04	10.82	0.014
3	0.096	25.1	0.041	10.79	0.014
4	0.096	25.53	0.032	8.48	0.014
5	0.1	27.02	0.022	5.82	0.014
6	0.089	23.32	0.03	8.18	0.015
7	0.08	16.62	0.022	4.59	0.017
8	0.092	24.32	0.022	5.72	0.014
9	0.101	26.84	0.026	6.94	0.013
10	0.098	26.79	0.034	9.2	0.013
11	0.093	25.97	0.022	6.21	0.014
12	0.072	18.11	0.025	6.26	0.017
13	0.082	19.91	0.019	4.82	0.015
14	0.117	27.37	0.036	8.34	0.015
15	0.099	26.55	0.028	7.56	0.013
16	0.105	25.23	0.019	4.59	0.015
17	0.123	26.48	0.026	5.65	0.016
18	0.093	23.11	0.04	9.75	0.014
19	0.103	23.94	0.024	5.5	0.015
20	0.113	25.16	0.026	5.77	0.015
21	0.102	22.85	0.024	5.53	0.015
22	0.098	22.2	0.029	6.46	0.015
23	0.069	13.8	0.023	4.6	0.016
Average	0.096		0.028		0.015

Total		573.49		170.3	
30-Day Rlng	0.093		0.028		
365-Day Rlng				63025	
3/10/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	20.13	0.03	7.2	0.014
1	0.091	21.06	0.025	5.94	0.015
2	0.088	22.28	0.04	10.21	0.014
3	0.097	24.67	0.029	7.44	0.014
4	0.095	24.77	0.03	7.96	0.014
5	0.101	26.54	0.027	7.07	0.015
6	0.101	24.45	0.026	6.32	0.016
7	0.084	22.49	0.018	4.78	0.015
8	0.094	25.07	0.04	10.88	0.015
9	0.089	23.07	0.023	6.14	0.016
10	0.091	26.23	0.043	12.45	0.014
11	0.13	26.62	0.022	4.52	0.019
12	0.092	25.06	0.018	4.77	0.013
13	0.103	30.95	0.024	7.11	0.013
14	0.098	26.23	0.015	3.96	0.013
15	0.098	24.59	0.019	4.79	0.013
16	0.109	26.85	0.033	8.18	0.013
17	0.104	26.35	0.02	5	0.013
18	0.101	24.68	0.028	6.85	0.013
19	0.107	26.17	0.029	7.09	0.013
20	0.112	27.9	0.03	7.4	0.013
21	0.105	25.84	0.033	8.04	0.013
22	0.102	25.64	0.02	5.01	0.013
23	0.109	26.42	0.021	5.23	0.013
Average	0.099		0.027		0.014
Total		604.06		164.34	
30-Day Rlng	0.093		0.029		
365-Day Rlng				63021	
3/11/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.112	27.44	0.043	10.43	0.013
1	0.095	21.35	0.02	4.43	0.014
2	0.1	20.52	0.022	4.61	0.016
3	0.105	25.51	0.034	8.11	0.014
4	0.101	27.41	0.026	6.99	0.013
5	0.102	23.78	0.022	5.2	0.015
6	0.095	20.85	0.021	4.23	0.013
7	0.116	18.58	0.016	2.58	0.014
8	0.109	16.25	0.018	2.64	0.016
9	0.086	12.1	0.018	2.5	0.015
10	0.107	14.91	0.017	2.43	0.015
11	0.101	14.29	0.017	2.45	0.015

12	0.101	14.15	0.017	2.43	0.015
13	0.101	14.2	0.018	2.46	0.015
14	0.099	14.16	0.017	2.48	0.015
15	0.101	14.16	0.018	2.48	0.016
16	0.1	14.18	0.018	2.52	0.016
17	0.098	14.15	0.018	2.52	0.015
18	0.101	14.35	0.018	2.48	0.015
19	0.099	14.11	0.018	2.52	0.016
20	0.099	14.11	0.018	2.52	0.016
21	0.102	14.36	0.018	2.49	0.016
22	0.1	14.17	0.018	2.52	0.016
23	0.099	14.09	0.018	2.52	0.016
Average	0.101		0.02		0.015
Total		413.18		86.54	
30-Day Rlng	0.093		0.028		
365-Day Rlng				62903	

3/12/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.101	14.24	0.018	2.49	0.016
1	0.1	14.17	0.018	2.54	0.016
2	0.088	15.13	0.018	3.22	0.015
3	0.081	22.03	0.031	8.4	0.013
4	0.088	25.62	0.02	5.72	0.013
5	0.088	25.81	0.026	7.64	0.013
6	0.087	26.28	0.029	8.8	0.013
7	0.088	26.01	0.027	7.94	0.013
8	0.092	26.94	0.026	7.56	0.013
9	0.091	27.17	0.023	6.76	0.013
10	0.093	27.18	0.028	8.16	0.013
11	0.082	23.89	0.022	6.42	0.013
12	0.094	26.2	0.02	5.59	0.013
13	0.107	15.64	0.02	2.84	0.017
14	0.1	15.03	0.018	2.63	0.015
15	0.103	14.57	0.018	2.52	0.016
16	0.11	15.2	0.018	2.48	0.016
17	0.116	16.24	0.018	2.51	0.016
18	0.075	10.53	0.018	2.51	0.016
19	0.078	15.83	0.017	3.34	0.015
20	0.103	28.67	0.03	8.34	0.013
21	0.083	25.48	0.03	9.12	0.013
22	0.093	28.33	0.027	8.14	0.013
23	0.084	24.63	0.022	6.37	0.013
Average	0.093		0.023		0.014
Total		510.82		132.04	
30-Day Rlng	0.093		0.028		
365-Day Rlng				62823	

3/13/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	25.1	0.026	7.72	0.013
1	0.088	26.1	0.026	7.59	0.013
2	0.087	26.34	0.036	10.75	0.013
3	0.088	26.52	0.037	10.98	0.013
4	0.086	25.29	0.032	9.39	0.013
5	0.093	27.34	0.025	7.32	0.013
6	0.083	26.16	0.03	9.42	0.013
7	0.088	26.46	0.032	9.72	0.013
8	0.09	26.65	0.027	7.95	0.013
9	0.088	26.1	0.023	6.77	0.013
10	0.091	27.01	0.035	10.3	0.013
11	0.089	26.33	0.024	7.15	0.013
12	0.092	26.56	0.021	6.14	0.013
13	0.089	26.1	0.02	5.96	0.013
14	0.093	27.36	0.031	9.15	0.013
15	0.089	26.59	0.032	9.43	0.013
16	0.086	25.42	0.021	6.39	0.013
17	0.092	27.4	0.027	8.2	0.013
18	0.086	26.28	0.026	7.86	0.013
19	0.085	25.33	0.029	8.66	0.013
20	0.092	25.29	0.04	11.23	0.014
21	0.107	26.63	0.021	5.11	0.014
22	0.098	27.45	0.02	5.71	0.013
23	0.092	26.17	0.015	4.21	0.013
Average	0.09		0.027		0.013
Total		631.98		193.11	
30-Day Rng	0.093		0.028		
365-Day Rng				62823	

3/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.096	27.91	0.017	5	0.013
1	0.086	25.32	0.026	7.62	0.013
2	0.086	25.69	0.034	10.01	0.013
3	0.089	26.82	0.032	9.52	0.013
4	0.088	26.14	0.031	9.34	0.013
5	0.09	27.65	0.025	7.72	0.013
6	0.084	27.34	0.022	7.17	0.013
7	0.082	26.18	0.028	8.86	0.013
8	0.092	27.96	0.032	9.68	0.013
9	0.086	25.94	0.031	9.24	0.013
10	0.089	26.18	0.022	6.57	0.013
11	0.091	27.29	0.023	6.8	0.013
12	0.089	26.09	0.029	8.49	0.013
13	0.091	26.4	0.024	6.96	0.013
14	0.092	27.01	0.03	8.99	0.012
15	0.089	26.16	0.025	7.38	0.012

16	0.091	27.29	0.035	10.4	0.012
17	0.085	24.95	0.024	7.1	0.013
18	0.09	27.07	0.027	8.23	0.013
19	0.087	26.59	0.027	8.25	0.012
20	0.088	26.21	0.024	7.12	0.012
21	0.09	26.2	0.029	8.5	0.013
22	0.089	26.03	0.03	8.68	0.013
23	0.086	25.75	0.027	8.02	0.013
Average	0.089		0.027		0.013
Total		636.17		195.65	
30-Day Rlng	0.093		0.028		
365-Day Rlng				62811	

3/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	26.85	0.026	7.78	0.013
1	0.088	25.97	0.037	10.83	0.013
2	0.093	26.79	0.023	6.57	0.013
3	0.094	27.63	0.034	10.05	0.013
4	0.089	25.84	0.037	10.6	0.013
5	0.086	26.08	0.036	10.83	0.013
6	0.082	25.85	0.027	8.41	0.013
7	0.087	26.3	0.03	8.98	0.013
8	0.091	27.1	0.032	9.36	0.013
9	0.09	26.17	0.037	10.84	0.013
10	0.096	26.93	0.028	7.77	0.013
11	0.09	26.4	0.03	8.87	0.013
12	0.092	27.01	0.031	9.12	0.013
13	0.088	25.72	0.034	9.97	0.013
14	0.091	26.42	0.028	8.21	0.013
15	0.09	26.42	0.024	7.02	0.013
16	0.095	27.35	0.03	8.75	0.013
17	0.091	26.8	0.031	9.14	0.013
18	0.089	26.11	0.036	10.62	0.013
19	0.091	26.8	0.032	9.54	0.012
20	0.088	25.69	0.026	7.57	0.012
21	0.05	14.12	0.024	6.87	0.013
22	0.057	16.47	0.028	8.03	0.013
23	0.092	26.71	0.035	10.2	0.012
Average	0.087		0.031		0.013
Total		613.53		215.93	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62853	

3/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.62	0.03	8.56	0.012
1	0.091	26.39	0.039	11.35	0.012
2	0.092	26.59	0.026	7.61	0.013

3	0.092	26.84	0.026	7.64	0.013
4	0.093	26.64	0.03	8.68	0.013
5	0.093	27.57	0.034	10.02	0.012
6	0.081	24.66	0.037	11.08	0.014
7	0.089	26.24	0.035	10.22	0.013
8	0.087	25.94	0.03	8.98	0.013
9	0.087	26.18	0.026	7.77	0.013
10	0.091	27.32	0.028	8.35	0.013
11	0.085	25.01	0.021	6.05	0.013
12	0.091	26.84	0.027	8.09	0.013
13	0.088	25.8	0.036	10.42	0.013
14	0.089	26.32	0.027	7.96	0.013
15	0.092	26.04	0.029	8.15	0.013
16	0.089	25.85	0.023	6.81	0.013
17	0.091	26.75	0.025	7.31	0.013
18	0.092	26.74	0.028	8.09	0.013
19	0.091	26.49	0.031	8.89	0.013
20	0.092	26.38	0.025	7.33	0.013
21	0.093	26.4	0.027	7.65	0.013
22	0.093	26.5	0.026	7.49	0.013
23	0.094	27.19	0.028	8.25	0.013
Average	0.09		0.029		0.013
Total		632.3		202.75	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62884	

3/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.6	0.027	7.77	0.013
1	0.09	26.32	0.031	8.92	0.013
2	0.091	26.66	0.026	7.57	0.013
3	0.09	26.84	0.033	9.72	0.013
4	0.089	25.78	0.024	6.8	0.013
5	0.093	26.97	0.024	7	0.013
6	0.089	27.33	0.034	10.54	0.013
7	0.084	24.71	0.033	9.59	0.013
8	0.088	25.97	0.027	7.83	0.013
9	0.089	26.16	0.025	7.18	0.013
10	0.091	26.38	0.023	6.59	0.013
11	0.09	26.61	0.031	9.12	0.013
12	0.091	26.88	0.033	9.84	0.013
13	0.091	26.2	0.022	6.43	0.013
14	0.091	27.15	0.026	7.77	0.013
15	0.09	26.47	0.029	8.51	0.013
16	0.087	25.23	0.026	7.45	0.013
17	0.088	26.79	0.027	8.18	0.013
18	0.086	26.26	0.032	9.65	0.013
19	0.088	26.16	0.033	9.87	0.013

20	0.088	26.17	0.038	11.34	0.013
21	0.087	26.36	0.031	9.3	0.013
22	0.092	27.02	0.026	7.46	0.013
23	0.09	26.55	0.026	7.63	0.013
Average	0.089		0.029		0.013
Total		633.57		202.06	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62898	
3/18/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.97	0.026	7.7	0.013
1	0.09	26.51	0.028	8.33	0.013
2	0.091	26.19	0.027	7.75	0.013
3	0.09	26.94	0.029	8.61	0.013
4	0.086	25.68	0.025	7.58	0.013
5	0.088	25.96	0.025	7.45	0.013
6	0.084	26.4	0.029	9.03	0.013
7	0.082	24.42	0.033	9.81	0.013
8	0.086	25.77	0.037	10.96	0.013
9	0.086	25.93	0.036	10.95	0.013
10	0.089	26.71	0.027	8.11	0.013
11	0.087	25.95	0.03	8.79	0.013
12	0.09	27.28	0.032	9.7	0.013
13	0.089	26.22	0.035	10.35	0.013
14	0.088	25.86	0.028	8.13	0.013
15	0.094	27.74	0.026	7.79	0.013
16	0.084	24.48	0.025	7.16	0.013
17	0.087	26.26	0.025	7.68	0.013
18	0.089	26.64	0.029	8.81	0.013
19	0.086	26.23	0.035	10.66	0.013
20	0.091	28.28	0.03	9.15	0.013
21	0.083	25.16	0.035	10.59	0.013
22	0.087	26.27	0.029	8.64	0.013
23	0.089	26.59	0.029	8.68	0.013
Average	0.088		0.03		0.013
Total		630.44		212.41	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62924	

3/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	27.14	0.032	9.74	0.013
1	0.087	26.62	0.029	8.88	0.013
2	0.085	25.55	0.028	8.48	0.013
3	0.09	20.48	0.031	6.84	0.013
4 Down	Down	Down	Down	Down	Down
5	0.188	17.23	0.036	3.23	0.1
6	0.078	22.93	0.023	6.88	0.013

7	0.088	26.27	0.032	9.53	0.014
8	0.088	26.54	0.029	8.88	0.013
9	0.087	25.63	0.036	10.59	0.013
10	0.093	27.07	0.032	9.44	0.013
11	0.088	25.47	0.035	10.1	0.013
12	0.09	26.43	0.036	10.49	0.013
13	0.093	26.49	0.035	9.96	0.013
14	0.093	26.81	0.023	6.54	0.013
15	0.094	26.68	0.023	6.62	0.013
16	0.089	25.64	0.027	7.75	0.013
17	0.092	26.85	0.028	8.03	0.013
18	0.092	26.35	0.027	7.79	0.013
19	0.093	26.67	0.026	7.46	0.013
20	0.09	25.82	0.026	7.51	0.013
21	0.094	26.6	0.026	7.37	0.013
22	0.094	26.45	0.026	7.23	0.013
23	0.095	27.12	0.027	7.6	0.013
Average	0.094		0.029		0.017
Total		588.84		186.94	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62912	

3/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	26.51	0.028	7.99	0.013
1	0.092	26.67	0.029	8.28	0.013
2	0.092	26.59	0.025	7.19	0.013
3	0.092	26.5	0.027	7.92	0.013
4	0.09	26.22	0.028	8.13	0.013
5	0.094	27.34	0.026	7.64	0.013
6	0.084	25.94	0.027	8.5	0.013
7	0.087	26.12	0.033	9.92	0.013
8	0.091	26.66	0.025	7.33	0.013
9	0.09	26.19	0.023	6.81	0.013
10	0.095	27.63	0.025	7.28	0.013
11	0.087	25.44	0.023	6.74	0.013
12	0.091	26.43	0.028	8.16	0.013
13	0.09	26.12	0.024	6.93	0.013
14	0.09	26.12	0.025	7.22	0.013
15	0.094	27.72	0.03	8.77	0.013
16	0.094	27.06	0.024	7.06	0.013
17	0.087	25.61	0.024	7.17	0.013
18	0.091	27.05	0.033	9.87	0.013
19	0.089	25.84	0.023	6.77	0.013
20	0.09	26.95	0.031	9.27	0.013
21	0.09	27.03	0.029	8.61	0.013
22	0.088	26.32	0.021	6.15	0.013
23	0.087	26.08	0.025	7.46	0.013

Average	0.09		0.027		0.013
Total		636.14		187.17	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62889	

3/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	27.17	0.028	8.42	0.013
1	0.095	27.53	0.029	8.58	0.013
2	0.085	24.03	0.038	10.84	0.013
3	0.093	26.5	0.037	10.45	0.013
4	0.094	26.37	0.027	7.43	0.013
5	0.093	27.73	0.021	6.23	0.013
6 Cal	Cal	Cal	Cal	Cal	
7	0.085	24.86	0.028	8.35	0.014
8	0.094	27.14	0.027	7.73	0.013
9	0.094	26.64	0.024	6.84	0.013
10	0.096	27.53	0.029	8.23	0.013
11	0.085	24.44	0.019	5.58	0.013
12	0.094	26.53	0.03	8.49	0.013
13	0.093	26.19	0.028	7.89	0.013
14	0.097	27.45	0.032	8.95	0.013
15	0.088	25.13	0.021	5.99	0.013
16	0.099	28.01	0.028	8.01	0.013
17	0.087	24.72	0.023	6.61	0.013
18	0.095	27.22	0.032	9.06	0.013
19	0.093	26.28	0.027	7.73	0.013
20	0.092	26.57	0.026	7.44	0.013
21	0.093	27.14	0.028	7.98	0.013
22	0.088	24.7	0.022	6.14	0.013
23	0.096	27.23	0.029	8.17	0.013
Average	0.092		0.028		0.013
Total		607.11		181.14	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62856	

3/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	26.44	0.036	10.18	0.013
1	0.092	25.77	0.03	8.39	0.013
2	0.094	26.28	0.031	8.75	0.013
3	0.098	27.39	0.027	7.53	0.013
4	0.092	25.51	0.024	6.77	0.013
5	0.096	27.17	0.025	7.06	0.013
6	0.095	28.41	0.025	7.36	0.013
7	0.095	26.99	0.027	7.75	0.013
8	0.092	26.14	0.028	7.88	0.013
9	0.091	26.24	0.029	8.27	0.013
10	0.097	27.55	0.016	4.45	0.013

11	0.094	26.5	0.022	6.37	0.013
12	0.094	26.71	0.03	8.56	0.013
13	0.094	26.31	0.025	7.04	0.013
14	0.096	27.24	0.025	7.14	0.013
15	0.093	26.26	0.024	6.88	0.013
16	0.097	27.14	0.03	8.39	0.013
17	0.095	27	0.029	8.24	0.013
18	0.092	26.14	0.027	7.63	0.013
19	0.095	26.96	0.028	7.96	0.013
20	0.091	26.12	0.03	8.58	0.013
21	0.094	26.65	0.025	7.05	0.013
22	0.094	26.44	0.025	6.92	0.013
23	0.093	26.22	0.025	7.15	0.013
Average	0.094		0.027		0.013
Total		639.58		182.3	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62830	
3/23/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.096	27.24	0.031	8.63	0.013
1	0.093	26.42	0.026	7.35	0.013
2	0.094	27.34	0.027	7.81	0.013
3	0.088	25.57	0.024	6.86	0.013
4	0.099	28.09	0.026	7.38	0.013
5	0.105	30.04	0.029	8.4	0.013
6	0.072	21.75	0.027	8.12	0.013
7	0.087	25.17	0.021	6.28	0.013
8	0.092	27.21	0.027	8.12	0.013
9	0.091	26.37	0.021	5.98	0.013
10	0.093	26.46	0.029	8.09	0.013
11	0.096	27.42	0.023	6.7	0.013
12	0.094	26.89	0.025	7.31	0.013
13	0.095	26.49	0.031	8.74	0.013
14	0.093	26.73	0.037	10.73	0.013
15	0.092	26.44	0.034	9.87	0.013
16	0.088	24.85	0.019	5.45	0.013
17	0.09	25.68	0.027	7.64	0.013
18	0.096	27.34	0.027	7.59	0.013
19	0.099	28.27	0.037	10.37	0.013
20	0.094	27.03	0.029	8.4	0.014
21	0.085	22.26	0.023	6.11	0.014
22	0.079	18.24	0.02	4.54	0.016
23	0.087	25.05	0.025	7.11	0.013
Average	0.092		0.027		0.013
Total		624.35		183.58	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62809	

3/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.41	0.027	7.85	0.013
1	0.09	25.67	0.03	8.44	0.013
2	0.093	27.01	0.032	9.4	0.013
3	0.094	27.54	0.028	8.05	0.013
4	0.087	24.83	0.021	6.05	0.013
5	0.092	27.02	0.026	7.68	0.013
6	0.083	25.96	0.031	9.55	0.013
7	0.091	27.62	0.031	9.43	0.013
8	0.084	25.51	0.029	8.84	0.013
9	0.085	25.73	0.027	8.08	0.013
10	0.089	26.74	0.038	11.26	0.013
11	0.09	26.77	0.028	8.45	0.013
12	0.087	26.05	0.03	8.83	0.012
13	0.088	26.37	0.034	10.18	0.012
14	0.09	27.36	0.031	9.26	0.012
15	0.085	25.29	0.024	7.13	0.012
16	0.086	25.3	0.022	6.48	0.012
17	0.09	26.89	0.028	8.33	0.014
18	0.094	28.45	0.025	7.66	0.012
19	0.085	25.42	0.037	10.94	0.012
20	0.089	26.34	0.036	10.65	0.012
21	0.088	26.09	0.022	6.46	0.013
22	0.087	25.5	0.02	5.82	0.013
23	0.092	27.38	0.023	6.92	0.013
Average	0.089		0.028		0.013
Total		632.25		201.74	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62789	

3/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.82	0.029	8.55	0.013
1	0.092	27.24	0.031	9.13	0.012
2	0.09	26.58	0.029	8.53	0.013
3	0.092	27.48	0.034	10.11	0.012
4	0.081	23.84	0.026	7.49	0.013
5	0.092	27.69	0.024	7.22	0.013
6	0.092	29.23	0.027	8.49	0.012
7	0.086	26	0.02	6.17	0.013
8	0.094	28.43	0.025	7.59	0.012
9	0.086	25.88	0.024	7.35	0.012
10	0.094	27.71	0.03	8.8	0.012
11	0.094	28.28	0.03	8.86	0.012
12	0.095	28.53	0.028	8.5	0.012
13	0.096	28.3	0.028	8.3	0.012
14	0.097	29.04	0.039	11.73	0.012

15	0.082	24.22	0.034	10.08	0.012
16	0.086	25.28	0.025	7.52	0.012
17	0.087	25.67	0.025	7.33	0.012
18	0.084	25.2	0.027	7.98	0.012
19	0.083	24.51	0.024	7.15	0.012
20	0.096	28.77	0.028	8.43	0.012
21	0.079	23.2	0.024	7.12	0.012
22	0.067	19.6	0.021	6.02	0.013
23	0.095	28.12	0.027	7.94	0.012
Average	0.089		0.027		0.012
Total		635.62		196.39	
30-Day Rlng	0.093		0.029		
365-Day Rlng				62776	

3/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	28.07	0.026	7.8	0.012
1	0.084	24.48	0.021	6.21	0.012
2	0.088	25.71	0.027	7.85	0.013
3	0.092	26.85	0.028	8.06	0.013
4	0.084	24.44	0.019	5.61	0.013
5	0.089	26.17	0.022	6.51	0.013
6	0.096	30.95 Cal	Cal	Cal	
7	0.086	29.53 Cal	Cal	Cal	
8	0.081	24.13	0.019	5.72	0.013
9	0.091	27.62	0.03	9.2	0.013
10	0.09	26.3	0.024	6.97	0.013
11	0.088	25.23	0.023	6.56	0.013
12	0.097	27.99	0.032	9.08	0.013
13	0.093	26.76	0.033	9.38	0.013
14	0.091	26.65	0.022	6.37	0.013
15	0.092	26.21	0.027	7.72	0.013
16	0.083	23.79	0.022	6.13	0.013
17	0.092	26.64	0.026	7.57	0.013
18	0.091	26.08	0.026	7.56	0.013
19	0.091	25.64	0.029	8.01	0.013
20	0.093	24.8	0.02	5.49	0.013
21	0.226	2.64	0.043	0.51	0.038
22 Down		Down	Down	Down	Down
23 Down		Down	Down	Down	Down
Average	0.096		0.026		0.014
Total		556.68		138.31	
30-Day Rlng	0.093		0.028		
365-Day Rlng				62698	

3/27/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down		Down	Down	Down	Down
1 Down		Down	Down	Down	Down

2 Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down
5 DCal	DCal	DCal	DCal	DCal
6 DCal	DCal	DCal	DCal	DCal
7 Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down
Average	Down	Down	Down	Down
Total		Down	Down	
30-Day Rlng	0.093		0.028	
365-Day Rlng				62517

3/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down

	19	Down	Down	Down	Down	Down
	20	Down	Down	Down	Down	Down
	21	Down	Down	Down	Down	Down
	22	Down	Down	Down	Down	Down
	23	Down	Down	Down	Down	Down
Average		Down		Down		Down
Total			Down		Down	
30-Day Rlng		0.093		0.028		
365-Day Rlng					62307	
3/29/2020						
Hour		NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0	Maint	Maint	Maint	Maint	Maint
	1	Maint	Maint	Maint	Maint	Maint
	2	Maint	Maint	Maint	Maint	Maint
	3	Maint	Maint	Maint	Maint	Maint
	4	Inval	5.91	Inval		4.11
	5	Inval	OOC	Inval	OOC	OOC
	6	Inval	OOC	Inval	OOC	Inval
	7	Inval	OOC	Inval	OOC	Inval
	8	Inval	OOC	Inval	OOC	Inval
	9	Inval	OOC	Inval	OOC	Inval
	10	0.19	OOC		0.087	OOC
	11	0.196	OOC		0.072	OOC
	12	0.205	OOC		0.072	OOC
	13	0.211	OOC		0.072	OOC
	14	0.21	OOC		0.054	OOC
	15	0.291		68.46	0.044	10.16
	16	0.236		22.57	0.041	3.88
	17	0.185		9.83	0.072	3.84
	18	0.172		8.71	0.076	3.84
	19	0.177		7.89	0.079	3.51
	20	Down	Down	Down	Down	Down
	21	Down	Down	Down	Down	Down
	22	Down	Down	Down	Down	Down
	23	Down	Down	Down	Down	Down
Average		0.207			0.067	0.152
Total			123.37			29.34
30-Day Rlng		0.095		0.029		
365-Day Rlng					62157	

3/30/2020

Hour		NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0	Down	Down	Down	Down	Down
	1	Down	Down	Down	Down	Down
	2	Down	Down	Down	Down	Down
	3	Down	Down	Down	Down	Down
	4	Down	Down	Down	Down	Down
	5	DCal	DCal	DCal	DCal	DCal

6	DCal	DCal	DCal	DCal	DCal
7	Down	Down	Down	Down	Down
8	Down	Down	Down	Down	Down
9	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.095		0.029	
365-Day Rlng					61983

3/31/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Down	Down	Down	Down	Down
3	Down	Down	Down	Down	Down
4	Maint	Maint	Maint	Maint	Maint
5	Maint	Maint	Maint	Maint	Maint
6	Maint	Maint	Maint	Maint	Maint
7	Maint	Maint	Maint	Maint	Maint
8	Inval	5.94 Inval		4.14 Inval	
9	Inval	5.9 Inval		4.11 Inval	
10	Inval	6.46 Inval		4.11 Inval	
11	0.189	10.53	0.076	4.21	0.128
12	0.18	11.35	0.067	4.22	0.07
13	0.225	17.99	0.039	3.31	0.112
14	0.309	45.64	0.024	3.59	0.021
15	0.053	13.38	0.033	8.23	0.014
16	0.074	21.48	0.028	8.08	0.012
17	0.09	26.89	0.023	6.84	0.012
18	0.082	26.23	0.019	6.01	0.012
19	0.083	26.16	0.016	4.97	0.014
20	0.083	26.31	0.022	6.84	0.013
21	0.084	27.12	0.025	8.17	0.012
22	0.086	27.76	0.024	7.83	0.012

	23	0.082	26.23	0.023	7.4	0.012
Average		0.125		0.032		0.034
Total			325.37		92.06	
30-Day Rlng		0.095		0.029		
365-Day Rlng					61880	

4/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.081	26.23	0.02	6.6	0.012
1	0.081	25.82	0.024	7.59	0.012
2	0.085	26.54	0.025	7.95	0.012
3	0.085	27	0.026	8.28	0.013
4	0.082	26.38	0.03	9.53	0.012
5	0.085	27.08	0.022	6.97	0.012
6	0.082	27.29	0.027	8.77	0.012
7	0.081	26.03	0.024	7.81	0.012
8	0.085	26.38	0.023	7.15	0.012
9	0.087	26.37	0.026	7.97	0.013
10	0.091	27.69	0.023	7.03	0.012
11	0.086	26.27	0.023	6.85	0.012
12	0.088	26.45	0.032	9.66	0.012
13	0.085	26.55	0.032	9.99	0.012
14	0.088	26.5	0.026	7.69	0.013
15	0.085	26	0.024	7.35	0.012
16	0.087	26.19	0.023	6.75	0.012
17	0.088	26.79	0.023	6.91	0.014
18	0.087	26.93	0.027	8.51	0.013
19	0.091	28.11	0.026	8.14	0.012
20	0.086	26.53	0.031	9.65	0.012
21	0.079	24.08	0.025	7.63	0.012
22	0.083	25.17	0.018	5.42	0.012
23	0.085	25.86	0.023	6.81	0.012
Average	0.085		0.025		0.012
Total		634.24		187.01	
30-Day Rlng	0.095		0.029		
365-Day Rlng				61851	

4/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.082	24.9	0.029	8.85	0.012
1	0.084	25.48	0.026	7.73	0.012
2	0.084	25.61	0.03	9.09	0.014
3	0.084	25.81	0.027	8.33	0.012
4	0.08	24.29	0.021	6.45	0.012
5	0.087	26.71	0.023	7.17	0.012
6	0.082	26.42	0.023	7.36	0.012
7	0.084	25.86	0.024	7.36	0.012
8	0.08	24.54	0.026	7.99	0.013
9	0.085	26.21	0.02	6.2	0.012

10	0.089	27.05	0.026	7.99	0.012
11	0.081	24.22	0.029	8.74	0.013
12	0.086	26.14	0.026	7.92	0.012
13	0.085	25.72	0.021	6.37	0.012
14	0.085	25.91	0.023	7.11	0.012
15	0.084	25.01	0.028	8.49	0.013
16	0.084	25.03	0.021	6.32	0.013
17	0.088	26.41	0.028	8.28	0.013
18	0.085	25.41	0.026	7.62	0.013
19	0.087	26.22	0.027	8	0.012
20	0.084	24.96	0.023	6.87	0.013
21	0.085	25.65	0.026	7.93	0.013
22	0.087	25.74	0.03	8.99	0.013
23	0.086	25.7	0.024	7.16	0.016
Average	0.085		0.025		0.013
Total		615		184.32	
30-Day Rlng	0.094		0.029		
365-Day Rlng				61831	

4/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.084	25.3	0.025	7.43	0.013
1	0.085	25.53	0.021	6.37	0.013
2	0.083	24.83	0.027	8.21	0.013
3	0.088	26.4	0.018	5.48	0.013
4	0.085	25.48	0.018	5.42	0.013
5	0.084	25.77	0.023	7.06	0.013
6	0.078	24.23	0.019	5.95	0.013
7	0.087	26.27	0.026	7.87	0.014
8	0.082	23.9	0.024	6.92	0.013
9	0.089	26.59	0.024	7.14	0.013
10	0.085	24.81	0.023	6.61	0.013
11	0.088	26.64	0.02	6.07	0.013
12	0.084	25.71	0.024	7.56	0.012
13	0.082	24.74	0.023	7.08	0.013
14	0.085	25.71	0.029	8.91	0.013
15	0.085	26.09	0.032	9.95	0.012
16	0.082	24.73	0.027	8.09	0.013
17	0.085	25.61	0.022	6.74	0.013
18	0.088	26.78	0.029	8.73	0.012
19	0.083	24.65	0.03	8.89	0.013
20	0.085	25.49	0.028	8.38	0.013
21	0.086	26.05	0.027	8.25	0.013
22	0.082	24.84	0.022	6.74	0.013
23	0.084	25.3	0.026	7.87	0.013
Average	0.085		0.024		0.013
Total		611.45		177.72	
30-Day Rlng	0.094		0.028		

365-Day Rlng 61799

4/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.44	0.03	8.93	0.013
1	0.086	25.51	0.025	7.63	0.013
2	0.085	25.39	0.032	9.52	0.014
3	0.087	26.7	0.034	10.59	0.012
4	0.082	24.48	0.03	8.95	0.013
5	0.085	25.63	0.022	6.73	0.013
6	0.075	23.41	0.024	7.35	0.013
7	0.085	25.53	0.021	6.22	0.013
8	0.08	23.66	0.02	5.8	0.013
9	0.084	25.04	0.023	6.98	0.013
10	0.084	25.12	0.023	6.91	0.012
11	0.082	24.07	0.024	7.1	0.013
12	0.085	25.12	0.03	9.01	0.013
13	0.086	25.7	0.027	8.03	0.013
14	0.085	25.77	0.019	5.74	0.013
15	0.085	25.7	0.027	8.12	0.013
16	0.086	26.13	0.027	8.13	0.013
17	0.083	25.35	0.025	7.57	0.012
18	0.084	25.65	0.023	6.8	0.012
19	0.087	25.86	0.025	7.36	0.012
20	0.084	25.32	0.026	7.79	0.012
21	0.084	25.3	0.022	6.57	0.013
22	0.088	26.11	0.028	8.11	0.013
23	0.083	24.9	0.025	7.36	0.013
Average	0.084		0.026		0.013
Total		607.89		183.3	
30-Day Rlng	0.094		0.028		
365-Day Rlng				61785	

4/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	25.51	0.027	7.9	0.013
1	0.088	25.72	0.027	7.89	0.013
2	0.084	24.88	0.024	7.31	0.013
3	0.087	25.95	0.021	6.32	0.012
4	0.095	23.51	0.017	4.29	0.014
5	0.088	26.8	0.025	7.61	0.013
6	0.079	25	0.025	8.1	0.013
7	0.084	25.28	0.024	7.19	0.013
8	0.084	25.72	0.025	7.76	0.013
9	0.086	26.02	0.023	6.82	0.013
10	0.085	25.13	0.029	8.67	0.013
11	0.084	25.27	0.03	9.17	0.013
12	0.085	25.54	0.025	7.36	0.013
13	0.087	25.79	0.022	6.58	0.013

14	0.084	25.05	0.025	7.49	0.013
15	0.088	26.79	0.025	7.7	0.012
16	0.085	25.62	0.021	6.48	0.013
17	0.083	25.36	0.024	7.46	0.012
18	0.086	25.99	0.024	7.4	0.012
19	0.085	25.37	0.025	7.54	0.012
20	0.085	25.84	0.028	8.55	0.013
21	0.085	25.6	0.022	6.67	0.013
22	0.086	25.7	0.027	8.11	0.013
23	0.084	25.19	0.024	7.23	0.013
Average	0.086		0.025		0.013
Total		612.63		177.6	
30-Day Rlng	0.093		0.028		
365-Day Rlng				61787	

4/6/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	25.09	0.021	6.34	0.013
1	0.085	25.11	0.03	8.81	0.013
2	0.086	25.44	0.026	7.73	0.013
3	0.087	26.07	0.021	6.4	0.013
4	0.086	25.79	0.025	7.51	0.012
5	0.084	25.08	0.029	8.7	0.013
6	0.08	25.71	0.018	5.69	0.012
7	0.08	25.25	0.025	7.81	0.012
8	0.083	25.26	0.026	7.9	0.013
9	0.084	25.47	0.025	7.48	0.014
10	0.083	24.89	0.022	6.6	0.012
11	0.087	25.81	0.021	6.36	0.013
12	0.086	25.48	0.024	7.06	0.013
13	0.088	25.55	0.026	7.63	0.013
14	0.087	25.54	0.027	7.93	0.013
15	0.085	24.97	0.025	7.22	0.013
16	0.088	26	0.025	7.29	0.013
17	0.084	24.54	0.029	8.43	0.013
18	0.091	26.84	0.026	7.54	0.012
19	0.082	23.88	0.03	8.66	0.012
20	0.088	25.94	0.024	7.12	0.012
21	0.086	25.29	0.035	10.38	0.012
22	0.082	23.47	0.033	9.38	0.013
23	0.091	26.84	0.019	5.49	0.013
Average	0.085		0.026		0.013
Total		609.31		181.46	
30-Day Rlng	0.093		0.028		
365-Day Rlng				61778	

4/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.04	0.029	8.44	0.013

1	0.085	25.16	0.025	7.28	0.013
2	0.087	25.55	0.022	6.48	0.013
3	0.086	25.07	0.022	6.35	0.013
4	0.091	26.35	0.023	6.63	0.013
5	0.082	24.17	0.031	9.09	0.013
6	0.083	25.67	0.028	8.82	0.013
7	0.088	26.51	0.026	7.83	0.013
8	0.081	24.49	0.023	6.95	0.013
9	0.087	26.05	0.026	7.68	0.013
10	0.087	25.21	0.027	7.67	0.013
11	0.088	25.5	0.025	7.09	0.013
12	0.089	25.99	0.026	7.61	0.013
13	0.089	26.08	0.026	7.59	0.013
14	0.086	25.33	0.026	7.55	0.013
15	0.084	24.67	0.022	6.55	0.013
16	0.086	24.97	0.023	6.84	0.013
17	0.097	23.56	0.021	5.13	0.014
18	0.096	19.46	0.017	3.44	0.015
19	0.095	19.52	0.017	3.53	0.015
20	0.091	19.62	0.018	3.79	0.014
21	0.095	20.49	0.023	4.88	0.014
22	0.087	20.22	0.025	5.89	0.013
23	0.086	20.07	0.03	6.93	0.013
Average	0.088		0.024		0.013
Total		575.75		160.04	
30-Day Rlng	0.093		0.028		
365-Day Rlng				61739	

4/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	19.91	0.031	6.7	0.014
1	0.094	20.4	0.027	5.84	0.014
2	0.089	22	0.032	8.03	0.014
3	0.088	24.03	0.022	6.01	0.013
4	0.082	24.05	0.031	9.2	0.013
5	0.088	26.07	0.029	8.49	0.013
6	0.046	9.23	0.02	3.87	0.017
7	0.083	23.83	0.022	6.47	0.013
8	0.078	23.81	0.027	8.15	0.013
9	0.081	24.11	0.024	7.21	0.013
10	0.088	26.7	0.029	8.87	0.012
11	0.085	25.82	0.024	7.18	0.013
12	0.092	27.3	0.027	8.02	0.013
13	0.083	24.4	0.033	9.79	0.013
14	0.09	26.3	0.026	7.45	0.013
15	0.089	26.55	0.027	8.18	0.013
16	0.087	25.47	0.024	7.02	0.013
17	0.093	27.05	0.027	7.76	0.013

18	0.091	26.51	0.027	7.77	0.013
19	0.093	26.59	0.027	7.7	0.013
20	0.09	26.03	0.026	7.55	0.013
21	0.089	26.22	0.029	8.51	0.013
22	0.09	26.39	0.028	8.07	0.013
23	0.089	25.68	0.028	8.07	0.013
Average	0.086		0.027		0.013
Total		584.45		181.91	
30-Day Rlng	0.093		0.027		
365-Day Rlng				61741	

4/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.4	0.025	7.17	0.013
1	0.096	27.46	0.03	8.6	0.013
2	0.089	26.03	0.031	9.18	0.013
3	0.09	26.29	0.029	8.39	0.013
4	0.094	27.36	0.029	8.55	0.013
5	0.089	26.34	0.028	8.3	0.013
6	0.073	23.3	0.033	10.37	0.014
7	0.087	26.36	0.026	7.89	0.013
8	0.088	26.79	0.025	7.73	0.013
9	0.087	26.47	0.03	9.07	0.013
10	0.089	26.89	0.024	7.45	0.013
11	0.086	24.83	0.02	5.88	0.013
12	0.089	27.24	0.027	8.23	0.014
13	0.087	26.31	0.02	6.03	0.013
14	0.089	26.64	0.027	8.12	0.013
15	0.089	26.66	0.023	6.84	0.013
16	0.089	26.6	0.026	7.68	0.013
17	0.087	26.12	0.027	8.2	0.013
18	0.086	25.82	0.035	10.53	0.013
19	0.088	25.55	0.034	9.77	0.013
20	0.089	26.08	0.034	9.9	0.013
21	0.089	25.97	0.021	6.07	0.013
22	0.091	26.17	0.029	8.21	0.013
23	0.09	26.21	0.03	8.61	0.013
Average	0.088		0.028		0.013
Total		629.89		196.77	
30-Day Rlng	0.093		0.027		
365-Day Rlng				61767	

4/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.84	0.038	10.9	0.013
1	0.094	27.01	0.036	10.3	0.013
2	0.091	26.26	0.033	9.41	0.013
3	0.092	26.24	0.032	9.19	0.013
4	0.093	26.81	0.03	8.63	0.013

5	0.091	27.08	0.032	9.41	0.013
6	0.075	23.56	0.033	10.41	0.013
7	0.088	26.66	0.024	7.26	0.013
8	0.087	26.44	0.032	9.53	0.013
9	0.089	26.61	0.029	8.73	0.013
10	0.091	27.27	0.028	8.39	0.013
11	0.085	25.91	0.025	7.75	0.013
12	0.088	26.1	0.026	7.66	0.013
13	0.092	27.55	0.033	9.83	0.013
14	0.088	26.19	0.029	8.75	0.013
15	0.088	26.01	0.023	6.86	0.013
16	0.09	26.69	0.032	9.45	0.013
17	0.091	26.94	0.03	8.98	0.013
18	0.087	25.68	0.027	8.08	0.013
19	0.089	26.13	0.025	7.39	0.013
20	0.089	26.03	0.028	8.14	0.013
21	0.091	27.08	0.023	6.83	0.013
22	0.09	26.1	0.022	6.47	0.013
23	0.089	26.4	0.026	7.68	0.013
Average	0.089		0.029		0.013
Total		632.59		206.03	
30-Day Rlng	0.092		0.027		
365-Day Rlng				61757	

4/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.48	0.029	8.57	0.013
1	0.088	25.71	0.02	5.84	0.013
2	0.089	26.76	0.026	7.78	0.013
3	0.088	25.75	0.047	13.89	0.014
4	0.093	27.07	0.016	4.72	0.013
5	0.092	27.94	0.02	6.14	0.013
6	0.082	26.09	0.022	6.81	0.013
7	0.086	25.83	0.029	8.8	0.013
8	0.088	26.49	0.027	8.09	0.013
9	0.09	26.61	0.033	9.76	0.013
10	0.093	27.5	0.031	9.13	0.013
11	0.088	25.95	0.024	7.09	0.013
12	0.091	26.92	0.026	7.56	0.013
13	0.091	26.58	0.029	8.41	0.013
14	0.09	26.64	0.026	7.67	0.013
15	0.091	27.42	0.038	11.44	0.013
16	0.088	25.7	0.025	7.32	0.013
17	0.09	26.79	0.031	9.11	0.013
18	0.086	25.43	0.023	6.9	0.013
19	0.086	24.04	0.025	7.02	0.013
20	0.107	26.35	0.016	3.94	0.014
21	0.102	28.05	0.027	7.69	0.013

	22	0.086	24.99	0.025	7.14	0.013
	23	0.09	26.79	0.021	6.13	0.013
Average		0.09		0.027		0.013
Total			633.88		186.95	
30-Day Rlng		0.092		0.027		
365-Day Rlng					61746	

4/12/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.72	0.035	10.39	0.013
1	0.091	26.54	0.021	6.23	0.013
2	0.089	26.26	0.028	8.34	0.013
3	0.093	27.74	0.037	10.99	0.013
4	0.087	25.59	0.025	7.23	0.013
5	0.087	26.22	0.031	9.43	0.013
6 Cal		25.76 Cal		10.49 Cal	
7	0.095	25.21	0.025	6.84	0.014
8	0.116	25.81	0.037	8.39	0.015
9	0.114	24.97	0.034	7.54	0.015
10	0.104	22.59	0.036	7.87	0.015
11	0.112	24.4	0.042	9.06	0.015
12	0.102	22.14	0.037	8.16	0.015
13	0.105	22.99	0.037	8.23	0.015
14	0.103	23.07	0.033	7.49	0.015
15	0.099	22.24	0.037	8.41	0.014
16	0.096	21.08	0.04	8.72	0.015
17	0.098	21.24	0.043	9.38	0.015
18	0.105	23.11	0.038	8.4	0.015
19	0.098	21.71	0.035	7.68	0.015
20	0.099	21.29	0.035	7.58	0.015
21	0.102	21.92	0.04	8.66	0.015
22	0.101	21.42	0.049	10.45	0.015
23	0.104	21.96	0.027	5.76	0.015
Average	0.1		0.035		0.014
Total		571.98		201.72	
30-Day Rlng	0.092		0.028		
365-Day Rlng				61750	

4/13/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.106	22.71	0.039	8.42	0.015
1	0.102	22.19	0.033	7.11	0.016
2	0.101	22.28	0.036	8.02	0.014
3	0.101	21.66	0.039	8.35	0.016
4	0.098	21.54	0.032	7.09	0.014
5	0.089	22.74	0.041	10.59	0.015
6 Maint	Maint	Maint	Maint	Maint	Maint
7	0.107	28.48	0.026	6.84	0.016
8	0.092	21.43	0.029	6.7	0.016

9	0.095	21.4	0.031	7.05	0.015
10	0.1	21.6	0.031	6.69	0.015
11	0.101	22.11	0.031	6.78	0.014
12	0.099	21.98	0.043	9.72	0.018
13	0.077	25.4	0.024	7.97	0.014
14	0.065	23.47	0.023	8.22	0.013
15	0.063	22.37	0.023	8.29	0.014
16	0.061	21.76	0.026	9.25	0.012
17	0.06	21.39	0.023	8.1	0.012
18	0.063	22.66	0.028	10	0.012
19	0.071	24.78	0.02	7.13	0.012
20	0.074	26.51	0.027	9.84	0.012
21	0.071	25.8	0.023	8.47	0.012
22	0.084	17.85	0.022	4.68	0.016
23	0.088	15.42	0.021	3.64	0.02
Average	0.086		0.029		0.014
Total		517.53		178.95	
30-Day Rlng	0.092		0.028		
365-Day Rlng				61726	

4/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.064	22.87	0.019	6.8	0.014
1	0.067	24.38	0.024	8.72	0.013
2	0.066	23.79	0.019	6.96	0.012
3	0.069	24.47	0.019	6.72	0.012
4	0.071	26	0.024	8.96	0.011
5	0.069	24.91	0.025	9.05	0.012
6 Cal	Cal	Cal	Cal	Cal	
7	0.081	27.52	0.034	11.53	0.013
8	0.078	24.23	0.018	5.52	0.012
9	0.08	25.12	0.028	8.84	0.012
10	0.08	24.57	0.029	8.86	0.012
11	0.079	24.91	0.02	6.34	0.012
12	0.087	26.12	0.023	6.97	0.015
13	0.08	24.83	0.032	9.94	0.012
14	0.081	24.95	0.023	7.21	0.012
15	0.084	26.09	0.026	8.26	0.012
16	0.077	23.73	0.027	8.35	0.012
17	0.079	24.38	0.028	8.48	0.012
18	0.081	25.42	0.025	7.88	0.012
19	0.084	25.83	0.034	10.64	0.012
20	0.085	26.14	0.025	7.8	0.012
21	0.082	25.1	0.024	7.33	0.012
22	0.086	26.09	0.021	6.53	0.012
23	0.082	25.66	0.029	9.11	0.012
Average	0.078		0.025		0.012
Total		577.11		186.8	

30-Day Rlng 0.091 0.028
 365-Day Rlng 61718
 4/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.079	24.86	0.025	7.8	0.012
1	0.083	26.49	0.031	9.81	0.012
2	0.083	26.04	0.029	8.99	0.012
3	0.081	25.33	0.026	8.21	0.012
4	0.081	25.04	0.024	7.44	0.015
5	0.081	25.57	0.027	8.48	0.012
6 Cal	Cal		0.039	15.07	0.011
7	0.077	27.79	0.032	11.59	0.011
8	0.071	25.65	0.031	11.04	0.012
9	0.07	25.68	0.028	10.37	0.011
10	0.068	25.67	0.026	9.67	0.012
11	0.075	28.08	0.037	13.83	0.012
12	0.067	23.29	0.02	7.05	0.012
13	0.086	29.63	0.026	9.16	0.012
14 Maint	Maint	Maint	Maint	Maint	
15	0.079	25.57	0.041	13.37	0.012
16	0.079	25.58	0.031	9.99	0.012
17	0.074	23.17	0.026	8.03	0.013
18	0.08	25.68	0.019	5.97	0.012
19	0.078	26.11	0.024	7.96	0.012
20	0.077	25.25	0.021	7.04	0.012
21	0.076	25.59	0.03	10.05	0.012
22	0.078	24.95	0.034	10.84	0.012
23	0.081	26.73	0.021	6.76	0.012
Average	0.077		0.028		0.012
Total		567.75		218.52	
30-Day Rlng	0.091		0.028		
365-Day Rlng				61742	

4/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.076	25.64	0.02	6.87	0.012
1	0.073	25.12	0.025	8.54	0.012
2	0.076	25.93	0.021	7.05	0.012
3	0.076	26.2	0.021	7.17	0.012
4	0.071	24.67	0.024	8.56	0.012
5	0.079	26.48	0.032	10.65	0.012
6	0.085	25.37	0.016	4.88	0.013
7	0.086	25.83	0.02	6.11	0.013
8	0.094	26.51	0.033	9.4	0.013
9	0.09	25.86	0.018	5.18	0.013
10	0.091	25.83	0.017	4.7	0.013
11	0.094	26.63	0.027	7.68	0.013
12	0.091	25.45	0.023	6.46	0.013

13	0.093	25.76	0.027	7.33	0.013
14	0.094	25.63	0.022	6.01	0.013
15	0.097	27.2	0.028	7.9	0.013
16	0.096	26.72	0.024	6.7	0.013
17	0.092	26.29	0.037	10.52	0.012
18	0.089	26.18	0.028	8.34	0.012
19	0.088	26.6	0.028	8.43	0.012
20	0.086	26.05	0.031	9.24	0.012
21	0.085	25.48	0.038	11.26	0.012
22	0.086	25.76	0.036	10.67	0.012
23	0.088	25.61	0.02	5.72	0.013
Average	0.087		0.026		0.013
Total		622.8		185.37	
30-Day Rlng	0.091		0.028		
365-Day Rlng				61749	

4/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.06	0.027	7.88	0.013
1	0.091	26.48	0.028	8.26	0.013
2	0.088	26.04	0.021	6.18	0.012
3	0.088	26.55	0.028	8.33	0.012
4	0.089	26.6	0.025	7.61	0.012
5	0.084	25.58	0.026	7.96	0.012
6	0.084	25.74	0.027	8.19	0.013
7	0.089	26.69	0.022	6.62	0.014
8	0.088	25.98	0.026	7.57	0.013
9	0.088	25.8	0.027	7.83	0.013
10	0.089	26.13	0.021	6.27	0.015
11	0.088	25.75	0.026	7.51	0.012
12	0.09	26.42	0.029	8.46	0.013
13	0.086	26.06	0.023	6.91	0.012
14	0.091	26.44	0.03	8.59	0.012
15	0.09	26.32	0.024	7.07	0.013
16	0.089	26.24	0.032	9.37	0.012
17	0.088	26.11	0.03	8.97	0.013
18	0.09	27.13	0.035	10.61	0.012
19	0.087	25.49	0.037	10.99	0.012
20	0.089	26.71	0.032	9.75	0.012
21	0.087	26.02	0.029	8.69	0.013
22	0.086	25.29	0.026	7.57	0.012
23	0.089	25.97	0.026	7.57	0.012
Average	0.088		0.027		0.013
Total		627.6		194.76	
30-Day Rlng	0.091		0.028		
365-Day Rlng				61764	

4/18/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
------	--------------	---------	--------------	---------	-------------

0	0.09	26.18	0.026	7.5	0.012
1	0.09	26.54	0.029	8.61	0.012
2	0.088	26.21	0.026	7.69	0.012
3	0.088	25.95	0.027	7.98	0.012
4	0.09	26.52	0.025	7.45	0.012
5	0.088	26.42	0.027	8.06	0.012
6	0.083	26.08	0.023	7.19	0.013
7	0.087	26.39	0.022	6.62	0.012
8	0.087	26.16	0.024	7.35	0.012
9	0.086	25.3	0.025	7.47	0.012
10	0.091	26.76	0.03	8.83	0.012
11	0.087	25.7	0.022	6.61	0.013
12	0.09	26.43	0.02	5.87	0.013
13	0.089	26.04	0.028	8.3	0.013
14	0.088	26.27	0.03	8.81	0.012
15	0.086	25.82	0.023	6.98	0.012
16	0.088	25.86	0.028	8.17	0.012
17	0.088	26.17	0.034	10.09	0.013
18	0.089	26.44	0.029	8.7	0.013
19	0.087	26.07	0.028	8.48	0.012
20	0.085	25.3	0.028	8.38	0.012
21	0.089	26.6	0.03	8.86	0.012
22	0.089	26.4	0.032	9.31	0.014
23	0.085	25.42	0.03	8.93	0.012
Average	0.088		0.027		0.012
Total		627.03		192.24	
30-Day Rlng	0.091		0.028		
365-Day Rlng				61768	

4/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.13	0.025	7.39	0.012
1	0.087	25.94	0.027	8.14	0.012
2	0.089	26.72	0.029	8.55	0.012
3	0.087	25.86	0.033	9.8	0.012
4	0.088	25.66	0.025	7.37	0.015
5	0.089	26.47	0.028	8.18	0.012
6	0.086	26.56	0.033	10.16	0.013
7	0.089	26.46	0.029	8.74	0.012
8	0.089	26.3	0.022	6.57	0.012
9	0.086	25.56	0.024	7.22	0.012
10	0.09	25.95	0.03	8.72	0.013
11	0.088	25.73	0.023	6.82	0.012
12	0.091	26.43	0.029	8.36	0.012
13	0.088	25.84	0.028	8.11	0.012
14	0.089	26.46	0.027	8.06	0.013
15	0.089	26.03	0.024	7.12	0.012
16	0.089	26.01	0.028	8.2	0.012

17	0.087	25.87	0.037	10.92	0.012
18	0.087	26.25	0.025	7.44	0.012
19	0.082	24.05	0.028	8.24	0.015
20	0.091	26.97	0.027	7.9	0.012
21	0.088	25.98	0.027	7.9	0.012
22	0.088	25.87	0.036	10.7	0.012
23	0.087	26.12	0.023	6.78	0.013
Average	0.088		0.028		0.012
Total		625.22		197.39	
30-Day Rlng	0.091		0.028		
365-Day Rlng				61778	

4/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.91	0.032	9.29	0.012
1	0.089	25.63	0.025	7.18	0.012
2	0.089	26.64	0.032	9.62	0.012
3	0.086	26.15	0.031	9.23	0.012
4	0.088	26.26	0.03	9.01	0.012
5	0.085	25.81	0.04	12.15	0.012
6	0.087	26.89	0.024	7.55	0.013
7	0.089	25.93	0.023	6.68	0.013
8	0.088	25.91	0.024	6.97	0.013
9	0.091	26.64	0.026	7.69	0.012
10	0.089	25.9	0.031	9.04	0.012
11	0.088	25.14	0.032	9.13	0.012
12	0.092	26.06	0.034	9.49	0.013
13	0.088	25.43	0.024	7.02	0.012
14	0.09	26.28	0.03	8.83	0.012
15	0.089	25.11	0.048	13.57	0.013
16	0.094	26.82	0.023	6.66	0.013
17	0.089	26.19	0.026	7.54	0.012
18	0.092	26.65	0.027	7.74	0.013
19	0.091	25.78	0.022	6.16	0.013
20	0.091	26.52	0.026	7.51	0.013
21	0.09	26.25	0.03	8.89	0.013
22	0.087	25.5	0.035	10.21	0.013
23	0.092	26.36	0.02	5.63	0.013
Average	0.089		0.029		0.013
Total		625.76		202.79	
30-Day Rlng	0.091		0.028		
365-Day Rlng				61981	

4/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.24	0.03	8.58	0.013
1	0.091	26.62	0.024	6.99	0.012
2	0.087	25.52	0.034	9.86	0.013
3	0.09	26.51	0.023	6.87	0.012

4	0.09	26.3	0.025	7.41	0.012
5	0.086	25.69	0.03	8.95	0.012
6	0.087	26.69	0.032	9.78	0.013
7	0.087	25.72	0.028	8.13	0.013
8	0.088	25.83	0.029	8.62	0.013
9	0.089	25.99	0.028	7.98	0.013
10	0.09	26.02	0.031	8.99	0.013
11	0.092	27.02	0.027	7.96	0.013
12	0.088	25.62	0.029	8.44	0.014
13	0.089	25.89	0.028	8.26	0.013
14	0.09	26.74	0.032	9.35	0.012
15	0.085	24.92	0.027	7.87	0.012
16	0.091	26.51	0.031	9.13	0.012
17	0.089	25.77	0.03	8.79	0.012
18	0.09	27.23	0.033	10.03	0.013
19	0.088	25.89	0.033	9.77	0.015
20	0.086	25.44	0.036	10.57	0.013
21	0.088	26.09	0.032	9.61	0.013
22	0.089	25.81	0.028	7.98	0.012
23	0.09	26.47	0.028	8.16	0.013
Average	0.089		0.03		0.013
Total		626.53		208.08	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62189	

4/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.57	0.034	9.88	0.012
1	0.088	26.02	0.038	11.34	0.013
2	0.087	25.99	0.037	11.19	0.013
3	0.086	25.61	0.026	7.72	0.013
4	0.088	26.06	0.031	9.12	0.012
5	0.089	26.46	0.031	9.32	0.012
6	0.087	27.17	0.028	8.77	0.013
7	0.085	25.41	0.026	7.7	0.012
8	0.088	26.3	0.027	8.05	0.012
9	0.086	25.99	0.027	8.15	0.012
10	0.087	25.42	0.025	7.15	0.012
11	0.09	26.22	0.034	10.02	0.013
12	0.091	26.45	0.035	10.28	0.012
13	0.089	25.47	0.025	7.2	0.012
14	0.09	26.15	0.029	8.57	0.014
15	0.091	26.26	0.032	9.22	0.012
16	0.089	25.63	0.025	7.34	0.014
17	0.091	26.43	0.028	8.09	0.012
18	0.093	26.95	0.033	9.41	0.013
19	0.089	25.44	0.032	9.12	0.013
20	0.091	26.6	0.039	11.33	0.012

21	0.088	25.34	0.03	8.51	0.012
22	0.091	26.09	0.027	7.72	0.012
23	0.091	26.68	0.041	12.05	0.012
Average	0.089		0.031		0.012
Total		626.71		217.25	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62391	

4/23/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.3	0.015	4.25	0.013
1	0.088	25.41	0.019	5.35	0.012
2	0.089	26.18	0.026	7.75	0.012
3	0.088	26.13	0.03	9	0.013
4	0.089	26.62	0.025	7.42	0.012
5	0.086	26.08	0.025	7.74	0.012
6	0.073	22.04	0.029	8.85	0.012
7	0.091	26.96	0.028	8.42	0.012
8	0.085	25.13	0.033	9.74	0.012
9	0.088	26.29	0.031	9.26	0.012
10	0.088	25.65	0.02	5.96	0.012
11	0.087	25.08	0.031	8.87	0.013
12	0.084	25.22	0.033	9.79	0.012
13	0.085	25.74	0.031	9.42	0.012
14	0.087	25.42	0.024	7.1	0.012
15	0.08	22.93	0.021	6.04	0.013
16	0.084	24.06	0.031	8.76	0.012
17	0.088	25.5	0.022	6.46	0.012
18	0.095	27.21	0.03	8.69	0.014
19	0.089	25.75	0.03	8.8	0.012
20	0.091	25.52	0.028	7.81	0.013
21	0.092	27.32	0.028	8.46	0.012
22	0.086	24.6	0.026	7.64	0.013
23	0.094	27.13	0.03	8.74	0.016
Average	0.087		0.027		0.013
Total		614.27		190.32	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62421	

4/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	24.73	0.031	8.62	0.016
1	0.095	27.1	0.028	8.14	0.012
2	0.086	24.7	0.029	8.44	0.013
3	0.094	27.04	0.031	8.76	0.012
4	0.087	24.66	0.028	7.94	0.012
5	0.085	23.09	0.018	4.74	0.013
6	0.075	22.96	0.033	10.25	0.013
7	0.084	24.91	0.027	8.11	0.012

8	0.087	25.97	0.025	7.49	0.012
9	0.09	26.9	0.031	9.4	0.012
10	0.088	25.29	0.024	7	0.012
11	0.091	26.36	0.028	8.27	0.012
12	0.088	25.51	0.034	10	0.012
13	0.085	24.89	0.03	8.6	0.012
14	0.089	26.33	0.029	8.68	0.012
15	0.088	26.19	0.028	8.42	0.012
16	0.088	25.61	0.031	9.14	0.012
17	0.087	24.98	0.029	8.35	0.012
18	0.092	27.33	0.036	10.52	0.013
19	0.087	25.36	0.036	10.4	0.012
20	0.09	26.68	0.038	11.14	0.012
21	0.088	25.81	0.028	8.1	0.013
22	0.088	25	0.022	6.2	0.013
23	0.094	26.04	0.027	7.63	0.013
Average	0.088		0.029		0.012
Total		613.44		204.34	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62429	

4/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	27.05	0.033	9.55	0.013
1	0.093	26.27	0.026	7.26	0.013
2	0.089	25.2	0.028	8.04	0.013
3	0.092	26.29	0.023	6.68	0.013
4	0.092	25.86	0.023	6.48	0.013
5	0.087	24.89	0.025	7.02	0.014
6	0.082	24.85	0.031	9.3	0.013
7	0.089	26.32	0.032	9.41	0.013
8	0.089	26.34	0.031	9.08	0.012
9	0.089	25.93	0.029	8.35	0.012
10	0.09	26.28	0.031	9.13	0.012
11	0.085	24.83	0.028	8.22	0.012
12	0.087	25.39	0.031	9.08	0.012
13	0.086	25.16	0.029	8.44	0.012
14	0.089	26.28	0.029	8.48	0.012
15	0.087	25.37	0.029	8.35	0.012
16	0.085	24.79	0.029	8.53	0.012
17	0.086	25.27	0.025	7.41	0.012
18	0.09	25.3	0.027	7.59	0.012
19	0.093	26.27	0.029	8.14	0.012
20	0.092	26.26	0.026	7.36	0.012
21	0.091	26.02	0.031	8.7	0.012
22	0.089	24.85	0.021	5.89	0.013
23	0.096	24.73	0.027	6.91	0.014
Average	0.089		0.028		0.013

Total		615.8		193.4	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62415	
4/26/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.01	0.025	7	0.012
1	0.093	26.31	0.033	9.27	0.012
2	0.091	25.91	0.029	8.18	0.012
3	0.09	26	0.023	6.57	0.012
4	0.09	25.17	0.023	6.3	0.013
5	0.092	26.64	0.025	7.41	0.013
6	0.078	22.18	0.02	5.81	0.013
7	0.081	25.12	0.026	8.13	0.012
8	0.088	25.66	0.041	11.98	0.012
9	0.081	23.97	0.029	8.61	0.014
10	0.088	25.56	0.022	6.2	0.013
11	0.091	26.43	0.028	8.25	0.012
12	0.087	25.95	0.029	8.51	0.012
13	0.086	25.22	0.034	9.88	0.013
14	0.089	25.81	0.027	7.97	0.012
15	0.092	26.88	0.024	6.99	0.012
16	0.089	26.05	0.028	8.15	0.012
17	0.088	25.84	0.028	8.25	0.012
18	0.089	26.54	0.028	8.46	0.013
19	0.088	25.79	0.027	7.91	0.013
20	0.094	26.36	0.027	7.59	0.012
21	0.09	24.84	0.032	8.72	0.012
22	0.097	27.15	0.023	6.54	0.012
23	0.092	25.18	0.026	7.08	0.013
Average	0.089		0.027		0.012
Total		616.57		189.76	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62495	
4/27/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.096	26.62	0.034	9.35	0.012
1	0.095	26.38	0.026	7.27	0.012
2	0.094	26.54	0.024	6.91	0.012
3	0.092	25.7	0.026	7.28	0.012
4	0.095	26.31	0.025	7.04	0.012
5	0.093	26.45	0.032	9.31	0.012
6	0.086	26.76	0.02	6.2	0.012
7	0.089	27.3	0.035	10.87	0.012
8	0.083	25.33	0.03	9.28	0.012
9	0.087	26.63	0.031	9.51	0.013
10	0.086	25.51	0.031	9.07	0.012
11	0.084	24.42	0.024	6.9	0.012

12	0.09	26.65	0.026	7.63	0.012
13	0.091	27	0.03	8.74	0.012
14	0.087	26.19	0.028	8.41	0.012
15	0.087	25.77	0.028	8.39	0.012
16	0.085	25.27	0.025	7.51	0.012
17	0.089	26.46	0.029	8.5	0.012
18	0.088	25.63	0.028	8.32	0.012
19	0.088	25.84	0.028	8.15	0.012
20	0.088	26.22	0.031	9.1	0.012
21	0.09	26.73	0.034	10.03	0.012
22	0.089	25.88	0.031	8.97	0.012
23	0.092	24.57	0.023	6.29	0.013
Average	0.089		0.028		0.012
Total		626.16		199.03	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62694	

4/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	27.25	0.033	9.72	0.012
1	0.09	26.67	0.033	9.56	0.012
2	0.089	26.37	0.036	10.77	0.012
3	0.089	26.59	0.025	7.35	0.012
4	0.088	24	0.023	6.39	0.013
5	0.093	27.65	0.03	8.97	0.012
6	0.081	25.37	0.031	9.8	0.012
7	0.086	26.05	0.035	10.67	0.012
8	0.087	25.61	0.039	11.43	0.012
9	0.091	26.43	0.033	9.52	0.013
10	0.088	26.06	0.028	8.23	0.012
11	0.089	25.65	0.031	8.96	0.013
12	0.086	25.1	0.037	10.66	0.013
13	0.091	25.69	0.028	8.08	0.013
14	0.093	26.39	0.026	7.48	0.013
15	0.092	26.51	0.032	9.37	0.012
16	0.093	26.21	0.029	8.26	0.013
17	0.09	25.47	0.031	8.8	0.013
18	0.091	26.12	0.034	9.8	0.013
19	0.093	26.61	0.03	8.42	0.013
20	0.091	26.5	0.031	9.04	0.012
21	0.09	25.84	0.026	7.42	0.013
22	0.092	26.36	0.026	7.38	0.012
23	0.092	26.49	0.031	9.01	0.013
Average	0.09		0.031		0.013
Total		626.99		215.09	
30-Day Rlng	0.09		0.028		
365-Day Rlng				62909	

4/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.58	0.033	9.46	0.013
1	0.09	26.15	0.034	9.87	0.012
2	0.088	26	0.034	10.08	0.012
3	0.088	25.68	0.036	10.45	0.012
4	0.091	26.19	0.038	10.92	0.013
5	0.092	26.95	0.032	9.49	0.013
6	0.087	27.04	0.025	7.72	0.013
7	0.088	26.16	0.033	9.87	0.013
8	0.09	26.31	0.026	7.72	0.013
9	0.089	26.14	0.022	6.47	0.013
10	0.091	26.43	0.02	5.9	0.013
11	0.09	26.01	0.023	6.64	0.013
12	0.087	25.54	0.028	8.34	0.012
13	0.086	25.16	0.024	6.99	0.012
14	0.088	25.83	0.029	8.55	0.013
15	0.09	26.37	0.026	7.78	0.012
16	0.088	25.77	0.021	6.16	0.012
17	0.09	26.58	0.03	8.88	0.013
18	0.09	26.51	0.029	8.41	0.012
19	0.088	25.95	0.029	8.43	0.012
20	0.087	25.84	0.03	8.8	0.012
21	0.088	25.64	0.028	8.19	0.012
22	0.086	24.73	0.029	8.4	0.013
23	0.092	26.81	0.031	9.08	0.013
Average	0.089		0.029		0.013
Total		625.37		202.6	
30-Day Rng	0.088		0.028		
365-Day Rng				63112	

4/30/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	26.42	0.028	7.98	0.013
1	0.09	26.36	0.031	9.21	0.012
2	0.089	26.49	0.032	9.72	0.012
3	0.087	26.08	0.032	9.59	0.012
4	0.088	26.12	0.031	9.04	0.012
5	0.089	26.34	0.03	9.03	0.012
6	0.072	22.2	0.018	5.54	0.013
7	0.087	26.13	0.021	6.29	0.013
8	0.087	26.02	0.023	6.89	0.013
9	0.087	26.07	0.026	7.65	0.012
10	0.088	26.04	0.03	8.93	0.012
11	0.088	25.7	0.025	7.22	0.013
12	0.092	26.66	0.032	9.38	0.014
13	0.089	25.72	0.026	7.69	0.012
14	0.087	25.52	0.031	9.07	0.012
15	0.09	26.24	0.027	7.74	0.012

16	0.09	26.11	0.031	8.89	0.012
17	0.09	26.56	0.031	9.13	0.013
18	0.089	26.29	0.027	7.95	0.012
19	0.088	26.11	0.027	8.17	0.014
20	0.087	25.6	0.022	6.42	0.012
21	0.089	26.08	0.031	8.9	0.012
22	0.089	26.54	0.032	9.63	0.012
23	0.086	25.16	0.027	7.94	0.013
Average	0.088		0.028		0.012
Total		622.56		198	
30-Day Rlng	0.087		0.028		
365-Day Rlng				63310	

5/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.72	0.028	8.27	0.012
1	0.086	25.55	0.028	8.22	0.012
2	0.088	26.15	0.025	7.27	0.012
3	0.091	27.18	0.031	9.29	0.012
4	0.087	26.14	0.033	9.87	0.012
5	0.084	25.55	0.02	6.23	0.012
6	0.078	21.5	0.028	7.77	0.014
7	0.095	23.09	0.017	4.15	0.015
8	0.094	25.71	0.026	6.98	0.013
9	0.09	25.6	0.034	9.88	0.014
10	0.087	25.22	0.026	7.39	0.013
11	0.089	25.79	0.024	6.89	0.013
12	0.089	26.13	0.027	7.96	0.012
13	0.086	26.06	0.026	7.98	0.012
14	0.08	23.74	0.026	7.83	0.012
15	0.087	26.16	0.027	8.25	0.012
16	0.09	26.82	0.028	8.41	0.012
17	0.086	25.69	0.029	8.49	0.012
18	0.09	27.09	0.031	9.23	0.012
19	0.087	26.04	0.029	8.62	0.012
20	0.085	25.72	0.029	8.7	0.012
21	0.085	25.71	0.029	8.66	0.012
22	0.089	27.02	0.034	10.36	0.013
23	0.084	25.5	0.029	8.92	0.012
Average	0.087		0.028		0.012
Total		615.88		195.62	
30-Day Rlng	0.087		0.028		
365-Day Rlng				63506	

5/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	25.64	0.028	8.16	0.012
1	0.089	26.52	0.031	9.24	0.012
2	0.087	26.32	0.032	9.52	0.012

3	0.089	26.81	0.031	9.27	0.012
4	0.081	24.32	0.022	6.53	0.012
5	0.09	27.6	0.024	7.35	0.015
6	0.084	26.8	0.029	9.37	0.012
7	0.087	26.28	0.024	7.14	0.013
8	0.085	25.68	0.023	7.07	0.012
9	0.085	25.34	0.021	6.11	0.012
10	0.09	26.09	0.026	7.46	0.013
11	0.089	25.92	0.033	9.6	0.013
12	0.089	26.28	0.031	9.03	0.012
13	0.089	26.16	0.031	8.95	0.012
14	0.089	26.25	0.031	8.98	0.012
15	0.089	26.38	0.029	8.51	0.012
16	0.088	25.45	0.021	6.12	0.012
17	0.088	26.01	0.028	8.18	0.013
18	0.092	26.98	0.024	6.94	0.014
19	0.088	26.11	0.032	9.56	0.016
20	0.083	24.7	0.03	8.98	0.012
21	0.088	26.06	0.026	7.85	0.012
22	0.094	27.71	0.03	8.93	0.012
23	0.085	25.19	0.029	8.64	0.013
Average		0.088	0.028		0.013
Total		626.6		197.49	
30-Day Rlng	0.088		0.028		
365-Day Rlng				63703	

5/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.29	0.037	10.9	0.013
1	0.091	26.07	0.034	9.76	0.014
2	0.091	25.81	0.03	8.47	0.013
3	0.092	26.3	0.03	8.67	0.013
4	0.093	26.22	0.028	7.83	0.013
5	0.089	25.76	0.027	7.84	0.013
6 Cal		19.26 Cal		8.52 Cal	
7	0.092	24.23	0.035	9.54	0.013
8	0.102	25.99	0.037	9.47	0.013
9	0.103	26.07	0.034	8.65	0.013
10	0.102	25.19	0.035	8.62	0.014
11	0.104	25.9	0.035	8.83	0.013
12	0.101	24.83	0.037	9.03	0.014
13	0.107	26.24	0.034	8.24	0.014
14	0.104	24.77	0.033	7.78	0.014
15	0.101	23.6	0.036	8.45	0.019
16	0.105	25.58	0.033	7.94	0.013
17	0.106	26.1	0.035	8.74	0.013
18	0.106	26.43	0.033	8.32	0.013
19	0.105	26.12	0.037	9.26	0.013

20	0.104	26.02	0.033	8.27	0.013
21	0.105	26.18	0.034	8.55	0.013
22	0.105	25.92	0.038	9.34	0.014
23	0.103	25.33	0.032	7.81	0.014
Average	0.1		0.034		0.014
Total		610.21		208.83	
30-Day Rlng	0.088		0.028		
365-Day Rlng				63912	

5/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.108	26.94	0.036	8.91	0.013
1	0.103	25.26	0.033	8	0.014
2	0.106	26.49	0.037	9.23	0.013
3	0.106	26.99	0.037	9.39	0.013
4	0.1	25.04	0.038	9.57	0.013
5	0.104	26.48	0.036	9.16	0.014
6	0.092	23.98	0.033	8.77	0.013
7	0.102	25.21	0.034	8.35	0.014
8	0.101	25.16	0.038	9.44	0.014
9	0.103	25.82	0.035	8.77	0.016
10	0.091	22.29	0.035	8.65	0.013
11	0.095	23.12	0.035	8.51	0.013
12	0.106	26.41	0.044	11.01	0.013
13	0.098	24.34	0.043	10.67	0.013
14	0.103	24.56	0.04	9.39	0.014
15	0.109	26.85	0.039	9.56	0.014
16	0.109	26.48	0.035	8.43	0.014
17	0.106	25.97	0.034	8.32	0.014
18	0.106	25.95	0.037	9.13	0.014
19	0.103	25.05	0.04	9.79	0.014
20	0.105	25.83	0.042	10.29	0.014
21	0.108	26.32	0.042	10.17	0.014
22	0.11	26.7	0.038	9.26	0.014
23	0.103	25.08	0.036	8.96	0.014
Average	0.103		0.037		0.014
Total		612.32		221.73	
30-Day Rlng	0.089		0.028		
365-Day Rlng				64134	

5/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.113	26.14	0.033	7.49	0.014
1	0.109	26.07	0.038	8.97	0.015
2	0.109	25.87	0.032	7.51	0.014
3	0.113	26.68	0.041	9.65	0.014
4	0.109	24.63	0.038	8.62	0.014
5 Inval		6.39 Inval		2.75 Inval	
6 DCal		DCal	DCal	DCal	DCal

7 Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down
Average	0.111		0.036	0.014
Total		135.78		44.99
30-Day Rlng	0.089		0.029	
365-Day Rlng				64179

5/6/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down	Down

Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.089		0.029	
365-Day Rlng					64179

5/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.089		0.029	
365-Day Rlng					64179

5/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Inval	Inval	Inval	Inval	Inval	Inval
9 Inval	Inval	Inval	Inval	Inval	Inval
10 Inval	Inval	Inval	Inval	Inval	Inval

11	Inval	Inval	Inval	Inval	Inval
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Inval		Inval		Inval
Total		Inval		Inval	
30-Day Rlng		0.089		0.029	
365-Day Rlng					64179

5/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Down	Down	Down	Down	Down
3	Down	Down	Down	Down	Down
4	Down	Down	Down	Down	Down
5	Down	Down	Down	Down	Down
6	Down	Down	Down	Down	Down
7	Down	Down	Down	Down	Down
8	Down	Down	Down	Down	Down
9	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.089		0.029	
365-Day Rlng					64146

5/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.089		0.029	
365-Day Rlng					64057

5/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down

	15 Down	Down	Down	Down	Down
	16 Down	Down	Down	Down	Down
	17 Down	Down	Down	Down	Down
	18 Down	Down	Down	Down	Down
	19 Down	Down	Down	Down	Down
	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.089		0.029	
365-Day Rlng					64012

5/12/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0 Down	Down	Down	Down	Down
	1 Down	Down	Down	Down	Down
	2 Down	Down	Down	Down	Down
	3 Down	Down	Down	Down	Down
	4 Down	Down	Down	Down	Down
	5 Down	Down	Down	Down	Down
	6 Down	Down	Down	Down	Down
	7 Down	Down	Down	Down	Down
	8 Down	Down	Down	Down	Down
	9 Down	Down	Down	Down	Down
	10 Down	Down	Down	Down	Down
	11 Down	Down	Down	Down	Down
	12 Down	Down	Down	Down	Down
	13 Down	Down	Down	Down	Down
	14 Down	Down	Down	Down	Down
	15 Down	Down	Down	Down	Down
	16 Down	Down	Down	Down	Down
	17 Down	Down	Down	Down	Down
	18 Down	Down	Down	Down	Down
	19 Down	Down	Down	Down	Down
	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.089		0.029	
365-Day Rlng					63884

5/13/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0 Down	Down	Down	Down	Down
	1 Down	Down	Down	Down	Down

2 Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down
Average	Down	Down	Down	Down
Total		Down	Down	
30-Day Rlng	0.089		0.029	
365-Day Rlng				63680

5/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down

	19	Down	Down	Down	Down
	20	Down	Down	Down	Down
	21	Down	Down	Down	Down
	22	Down	Down	Down	Down
	23	Down	Down	Down	Down
Average		Down		Down	Down
Total			Down		Down
30-Day Rlng		0.089		0.029	
365-Day Rlng					63479

5/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Down	Down	Down	Down	Down
3	Down	Down	Down	Down	Down
4	Down	Down	Down	Down	Down
5	Down	Down	Down	Down	Down
6	Down	Down	Down	Down	Down
7	Down	Down	Down	Down	Down
8	Down	Down	Down	Down	Down
9	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.089		0.029	
365-Day Rlng					63295

5/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Maint	Maint	Maint	Maint	Maint
3	Maint	Maint	Maint	Maint	Maint
4	Maint	Maint	Maint	Maint	Maint
5	Maint	Maint	Maint	Maint	Maint

6	Maint	Maint	Maint	Maint	Maint
7	Maint	Maint	Maint	Maint	Maint
8	Maint	Maint	Maint	Maint	Maint
9	Maint	Maint	Maint	Maint	Maint
10	Maint	Maint	Maint	Maint	Maint
11	Maint	Maint	Maint	Maint	Maint
12	Maint	Maint	Maint	Maint	Maint
13	Maint	Maint	Maint	Maint	Maint
14	Maint	Maint	Maint	Maint	Maint
15	Maint	Maint	Maint	Maint	Maint
16	Maint	Maint	Maint	Maint	Maint
17	Maint	Maint	Maint	Maint	Maint
18	Maint	Maint	Maint	Maint	Maint
19	Maint	Maint	Maint	Maint	Maint
20	OOC	OOC	OOC	OOC	OOC
21	OOC	OOC	OOC	OOC	OOC
22	OOC	OOC	OOC	OOC	OOC
23	OOC	OOC	OOC	OOC	OOC
Average	Maint		Maint		Maint
Total		Maint		Maint	
30-Day Rlng		0.089		0.029	
365-Day Rlng					63092

5/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 OOC	OOC	OOC	OOC	OOC	OOC
1 OOC	OOC	OOC	OOC	OOC	OOC
2 OOC	OOC	OOC	OOC	OOC	OOC
3 OOC	OOC	OOC	OOC	OOC	OOC
4 OOC	OOC	OOC	OOC	OOC	OOC
5 Cal	Cal	Cal	Cal	Cal	Cal
6	0.093	27.84	0.068	20.44	0.012
7	0.086	25.88	0.042	12.65	0.013
8	0.1	24.61	0.021	5.07	0.015
9	0.095	25.24	0.019	5.11	0.013
10	0.097	25.98	0.019	5.16	0.013
11	0.078	26.71	0.038	13.11	0.012
12	0.083	26.52	0.035	11.18	0.012
13	0.082	25.94	0.028	8.87	0.012
14	0.084	26.34	0.034	10.77	0.012
15	0.084	26.49	0.031	9.82	0.012
16	0.083	25.73	0.033	10.37	0.012
17	0.086	26.44	0.031	9.36	0.012
18	0.085	26.01	0.035	10.62	0.012
19	0.085	25.87	0.03	8.97	0.012
20	0.086	25.93	0.031	9.24	0.012
21	0.087	26.49	0.029	8.73	0.012
22	0.085	25.67	0.034	10.08	0.012

	23	0.089	26.37	0.034	10.26	0.012
Average		0.087		0.033		0.012
Total			470.06		179.81	
30-Day Rlng		0.089		0.029		
365-Day Rlng					63076	

5/18/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	26.34	0.033	9.78	0.012
1	0.088	24.96	0.021	6.03	0.013
2	0.095	27.47	0.028	8.01	0.013
3	0.085	25.94	0.03	9.05	0.012
4	0.086	26.74	0.033	10.07	0.012
5	0.086	27.06	0.031	9.9	0.012
6	0.081	26.12	0.034	10.85	0.012
7	0.073	22.99	0.026	8.12	0.012
8	0.092	25.4	0.018	5.05	0.013
9	0.082	25.6	0.027	8.43	0.012
10	0.084	26.12	0.028	8.7	0.012
11	0.086	26.33	0.028	8.66	0.012
12	0.084	25.74	0.03	9.03	0.012
13	0.084	25.76	0.033	10.08	0.012
14	0.087	26.52	0.031	9.51	0.012
15	0.085	25.82	0.029	8.95	0.012
16	0.086	26.73	0.033	10.32	0.012
17	0.083	25.71	0.028	8.73	0.012
18	0.084	25.88	0.028	8.64	0.012
19	0.084	25.57	0.029	9.05	0.012
20	0.085	25.81	0.03	9.02	0.012
21	0.085	26.69	0.029	9.07	0.012
22	0.085	26.14	0.028	8.74	0.012
23	0.085	26.09	0.026	7.91	0.012
Average	0.085		0.029		0.012
Total		623.53		211.7	
30-Day Rlng	0.089		0.029		
365-Day Rlng				63079	

5/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.081	25.17	0.031	9.55	0.012
1	0.084	26.17	0.034	10.74	0.012
2	0.085	26.13	0.029	8.95	0.012
3	0.085	26.37	0.032	10.04	0.012
4	0.083	25.98	0.025	7.79	0.015
5	0.085	26.02	0.036	11.12	0.012
6	0.086	27.67	0.038	12.07	0.012
7	0.075	25.88	0.027	9.31	0.012
8	0.081	26.23	0.029	9.4	0.012
9	0.082	26.1	0.017	5.27	0.012

10	0.082	26.09	0.032	10.15	0.012
11	0.083	26.34	0.026	8.2	0.012
12	0.083	25.83	0.039	12.24	0.012
13	0.084	26.2	0.022	6.84	0.012
14	0.085	26.06	0.024	7.47	0.012
15	0.086	26.66	0.025	7.91	0.012
16	0.083	26.05	0.024	7.46	0.012
17	0.082	25.43	0.022	6.85	0.012
18	0.085	26.3	0.023	6.99	0.012
19	0.084	25.88	0.026	7.85	0.012
20	0.086	26.28	0.029	8.79	0.012
21	0.084	26.01	0.028	8.55	0.013
22	0.088	26.15	0.021	6.22	0.013
23	0.088	26.09	0.027	8.04	0.013
Average	0.084		0.028		0.012
Total		627.09		207.8	
30-Day Rlng	0.089		0.029		
365-Day Rlng				63081	

5/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	26.25	0.026	7.74	0.013
1	0.086	26.14	0.026	7.86	0.013
2	0.087	26.52	0.027	8.3	0.012
3	0.085	26.43	0.025	7.7	0.012
4	0.085	26.07	0.027	8.09	0.012
5	0.084	25.71	0.024	7.19	0.012
6	0.084	26.74	0.022	6.92	0.012
7	0.079	27.56	0.025	8.86	0.012
8	0.079	25.62	0.018	5.64	0.012
9	0.082	25.9	0.018	5.73	0.012
10	0.082	26.22	0.021	6.78	0.012
11	0.084	25.94	0.025	7.72	0.012
12	0.085	26.57	0.027	8.48	0.012
13	0.084	26.24	0.031	9.8	0.012
14	0.085	26.04	0.024	7.38	0.012
15	0.083	25.87	0.019	6.09	0.012
16	0.084	26.44	0.022	6.96	0.012
17	0.088	25.4	0.02	5.72	0.013
18	0.086	26.67	0.021	6.52	0.012
19	0.083	25.89	0.028	8.56	0.012
20	0.085	26.34	0.031	9.58	0.012
21	0.084	26.13	0.02	6.22	0.012
22	0.083	25.85	0.024	7.47	0.012
23	0.085	25.99	0.026	7.91	0.012
Average	0.084		0.024		0.012
Total		628.53		179.22	
30-Day Rlng	0.089		0.029		

365-Day Rlng 63053

5/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	26.18	0.026	7.97	0.012
1	0.084	26.31	0.026	8.1	0.012
2	0.084	26.09	0.026	7.96	0.012
3	0.084	26.23	0.023	7.36	0.012
4	0.086	26.4	0.023	7.18	0.012
5	0.084	26.23	0.026	8.03	0.012
6	0.083	26.63	0.028	8.94	0.012
7	0.081	27.27	0.033	11.23	0.012
8	0.081	25.55	0.029	9.01	0.012
9	0.084	26.14	0.026	8.22	0.012
10	0.085	26.35	0.023	7.05	0.012
11	0.083	26.06	0.024	7.56	0.012
12	0.082	25.16	0.038	11.65	0.012
13	0.087	26.84	0.026	8.03	0.012
14	0.088	26.3	0.019	5.54	0.012
15	0.087	26.06	0.031	9.19	0.012
16	0.086	26.04	0.025	7.48	0.012
17	0.085	25.87	0.026	7.83	0.012
18	0.086	25.68	0.028	8.44	0.012
19	0.084	26.62	0.018	5.5	0.012
20	0.08	25.27	0.024	7.61	0.012
21	0.086	26.95	0.027	8.53	0.012
22	0.081	25.47	0.022	6.96	0.013
23	0.081	25.41	0.022	6.84	0.012
Average	0.084		0.026		0.012
Total		627.11		192.21	
30-Day Rlng	0.088		0.029		
365-Day Rlng				63046	

5/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.08	24.82	0.022	6.68	0.012
1	0.083	25.91	0.027	8.35	0.012
2	0.079	26	0.029	9.35	0.012
3	0.083	25.67	0.029	9.04	0.012
4	0.085	26.33	0.026	8	0.012
5	0.08	25.5	0.025	7.88	0.012
6	0.085	26.96	0.026	8.31	0.012
7	0.081	28.31	0.03	10.47	0.012
8	0.081	26.16	0.029	9.37	0.012
9	0.083	26.35	0.034	10.92	0.012
10	0.083	25.85	0.033	10.44	0.012
11	0.084	26.75	0.027	8.68	0.012
12	0.083	26.55	0.034	11.09	0.012
13	0.1	25.88	0.025	6.51	0.015

14	0.088	26.03	0.025	7.47	0.013
15	0.087	26.44	0.029	8.96	0.012
16	0.085	25.91	0.023	6.9	0.012
17	0.087	26.19	0.024	7.14	0.012
18	0.088	26.56	0.025	7.71	0.012
19	0.084	25.5	0.024	7.26	0.012
20	0.083	25.56	0.026	7.85	0.012
21	0.085	26.48	0.031	9.79	0.012
22	0.086	25.92	0.024	7.19	0.012
23	0.084	25.81	0.029	8.74	0.012
Average	0.084		0.027		0.012
Total		627.44		204.1	
30-Day Rlng	0.088		0.029		
365-Day Rlng				63046	

5/23/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	26.52	0.033	10.15	0.012
1	0.088	26.05	0.03	8.81	0.012
2	0.086	26.47	0.022	6.76	0.012
3	0.084	26.21	0.026	7.92	0.012
4	0.083	26.03	0.027	8.45	0.012
5	0.087	26.2	0.021	6.36	0.012
6	0.087	27.11	0.041	12.87	0.012
7	0.078	25.68	0.022	7.2	0.012
8	0.084	26.06	0.026	7.95	0.012
9	0.083	26.24	0.025	7.71	0.012
10	0.084	26.49	0.022	7	0.012
11	0.082	25.71	0.025	7.79	0.012
12	0.083	25.78	0.027	8.31	0.012
13	0.084	25.88	0.024	7.38	0.012
14	0.086	26.03	0.025	7.44	0.012
15	0.085	26.15	0.023	6.95	0.012
16	0.086	26.87	0.025	7.69	0.012
17	0.083	25.21	0.024	7.22	0.012
18	0.084	26.04	0.027	8.51	0.012
19	0.084	26.06	0.018	5.63	0.012
20	0.086	26.24	0.023	7.18	0.012
21	0.086	26.53	0.025	7.89	0.012
22	0.085	25.98	0.022	6.75	0.012
23	0.084	25.91	0.026	8.18	0.012
Average	0.085		0.025		0.012
Total		627.45		188.1	
30-Day Rlng	0.088		0.028		
365-Day Rlng				63089	

5/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	26.18	0.027	8.42	0.012

1	0.086	26.18	0.025	7.47	0.012
2	0.088	26.25	0.026	7.77	0.012
3	0.086	26.11	0.027	8.35	0.012
4	0.087	26.3	0.023	6.94	0.012
5	0.087	26.35	0.027	8.12	0.012
6	0.089	26.77	0.029	8.57	0.012
7	0.079	24.69	0.026	8.32	0.012
8	0.086	25.97	0.031	9.42	0.012
9	0.083	25.51	0.029	8.94	0.012
10	0.087	26.09	0.027	8.01	0.012
11	0.088	26.12	0.027	7.95	0.012
12	0.084	25.98	0.027	8.38	0.012
13	0.085	25.84	0.027	8.14	0.012
14	0.085	26.01	0.031	9.44	0.012
15	0.086	26.13	0.019	5.79	0.012
16	0.086	26.03	0.027	8.1	0.012
17	0.043	12.92	0.034	10.28	0.012
18	0.083	25.95	0.028	8.71	0.012
19	0.084	25.88	0.023	7.17	0.012
20	0.087	26.2	0.028	8.4	0.012
21	0.086	26.55	0.024	7.55	0.012
22	0.084	25.82	0.025	7.63	0.012
23	0.085	25.93	0.024	7.27	0.012
Average	0.084		0.027		0.012
Total		611.76		195.14	
30-Day Rlng	0.088		0.029		
365-Day Rlng				63089	

5/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	26.45	0.034	10.45	0.012
1	0.086	26.21	0.029	8.73	0.012
2	0.087	25.94	0.023	6.87	0.012
3	0.086	26.22	0.027	8.34	0.012
4	0.086	26.46	0.024	7.43	0.012
5	0.086	26.18	0.024	7.37	0.012
6	0.084	25.98	0.027	8.29	0.012
7	0.085	29.48	0.031	10.81	0.012
8	0.083	26.24	0.024	7.51	0.012
9	0.081	25.6	0.023	7.36	0.012
10	0.084	25.99	0.025	7.84	0.012
11	0.084	25.38	0.022	6.73	0.012
12	0.087	26.08	0.023	7.01	0.012
13	0.087	26.28	0.025	7.63	0.012
14	0.085	26.18	0.028	8.66	0.012
15	0.085	26.75	0.04	12.41	0.012
16	0.083	25.4	0.032	9.81	0.012
17	0.087	26.69	0.02	6.05	0.012

18	0.083	25.85	0.018	5.67	0.012
19	0.084	25.85	0.016	4.98	0.012
20	0.087	26.46	0.022	6.52	0.012
21	0.086	26.39	0.029	8.98	0.014
22	0.084	26.45	0.028	8.82	0.012
23	0.083	25.84	0.029	8.94	0.012
Average	0.085		0.026		0.012
Total		630.35		193.21	
30-Day Rlng	0.088		0.028		
365-Day Rlng				63078	

5/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.084	26.12	0.025	7.67	0.012
1	0.084	26.4	0.026	8.27	0.012
2	0.085	26.47	0.023	7.26	0.012
3	0.08	25.33	0.024	7.75	0.012
4	0.084	26.67	0.024	7.54	0.012
5	0.084	26	0.026	8.01	0.012
6	0.085	26.49	0.023	7.19	0.012
7	0.091	31.04	0.039	13.51	0.012
8	0.083	25.44	0.023	6.97	0.012
9	0.084	26.36	0.026	8.14	0.012
10	0.083	25.82	0.028	8.63	0.012
11	0.086	26.43	0.032	9.91	0.012
12	0.084	26.05	0.029	8.96	0.012
13	0.084	25.57	0.033	9.96	0.012
14	0.086	25.81	0.029	8.89	0.012
15	0.085	26.18	0.035	10.67	0.012
16	0.087	26.18	0.034	10.42	0.012
17	0.084	25.63	0.023	6.97	0.012
18	0.083	26.01	0.032	10.04	0.012
19	0.084	26.24	0.031	9.81	0.012
20	0.083	25.8	0.034	10.52	0.012
21	0.083	26.46	0.029	9.08	0.012
22	0.083	26.42	0.022	7.05	0.012
23	0.081	25.58	0.02	6.26	0.012
Average	0.084		0.028		0.012
Total		630.5		209.48	
30-Day Rlng	0.088		0.029		
365-Day Rlng				63095	

5/27/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	26.14	0.022	6.79	0.012
1	0.085	26.44	0.026	8.13	0.012
2	0.08	26	0.025	8.18	0.012
3	0.084	25.85	0.022	6.85	0.012
4	0.084	25.8	0.027	8.18	0.012

5	0.086	26.09	0.026	7.68	0.012
6	0.086	26.8	0.02	6.34	0.012
7	0.079	26.8	0.027	9.29	0.012
8	0.083	25.91	0.02	6.19	0.012
9	0.085	26.3	0.021	6.37	0.012
10	0.084	26.14	0.027	8.23	0.012
11	0.086	25.71	0.026	7.84	0.012
12	0.087	26.36	0.035	10.57	0.012
13	0.086	26.58	0.028	8.58	0.012
14	0.083	25.1	0.028	8.51	0.012
15	0.087	26.43	0.033	9.94	0.012
16	0.084	25.97	0.033	10.3	0.012
17	0.085	26.1	0.034	10.47	0.012
18	0.084	26.01	0.032	9.9	0.012
19	0.084	26.3	0.031	9.67	0.012
20	0.081	25.33	0.032	10.01	0.012
21	0.083	26.58	0.031	9.89	0.012
22	0.083	26.13	0.033	10.42	0.012
23	0.083	25.38	0.023	7.02	0.012
Average	0.084		0.028		0.012
Total		626.25		205.35	
30-Day Rlng	0.088		0.029		
365-Day Rlng				63115	

5/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	26.24	0.024	7.38	0.012
1	0.086	26.63	0.027	8.45	0.012
2	0.081	25.9	0.031	9.74	0.012
3	0.082	26.4	0.031	9.94	0.012
4	0.084	26.29	0.035	10.86	0.012
5	0.076	25.63	0.028	9.45	0.012
6	0.086	26.78	0.022	6.83	0.012
7	0.085	28.03	0.05	17.02	0.012
8	0.087	25.45	0.019	5.55	0.013
9	0.086	26.09	0.032	9.7	0.013
10	0.088	25.9	0.037	10.98	0.013
11	0.086	25.67	0.036	10.67	0.012
12	0.088	25.69	0.031	9.15	0.013
13	0.089	26.03	0.04	11.73	0.012
14	0.09	26.49	0.029	8.56	0.012
15	0.087	25.94	0.024	7.16	0.012
16	0.086	26.02	0.024	7.33	0.012
17	0.087	25.69	0.026	7.63	0.012
18	0.089	26.55	0.02	5.93	0.012
19	0.086	26.25	0.031	9.64	0.012
20 Inval		Inval	Inval	Inval	Inval
21 Inval		Inval	Inval	Inval	Inval

	22	Inval	Inval	Inval	Inval	Inval
	23	Inval	Inval	Inval	Inval	Inval
Average		0.086		0.03		0.012
Total			523.67		183.7	
30-Day Rlng		0.088		0.029		
365-Day Rlng					63103	

5/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Inval	Inval	Inval	Inval	Inval
1	Inval	Inval	Inval	Inval	Inval
2	Inval	Inval	Inval	Inval	Inval
3	Inval	Inval	Inval	Inval	Inval
4	Inval	Inval	Inval	Inval	Inval
5	0.087	26.48	0.03	9.11	0.012
6	0.077	23.29	0.026	7.83	0.012
7	0.058	17.97	0.044	14.34	0.013
8	0.075	22.48	0.029	8.74	0.013
9	0.086	26.27	0.035	10.66	0.013
10	0.077	23.27	0.031	9.41	0.013
11	0.08	23.86	0.044	12.9	0.012
12	0.075	22.56	0.032	9.65	0.013
13	0.076	22.87	0.033	10.07	0.012
14	0.081	24.33	0.029	8.69	0.012
15	0.073	22.35	0.031	9.55	0.012
16	0.069	20.68	0.036	10.85	0.013
17	0.076	22.33	0.035	10.31	0.013
18	0.089	26.17	0.037	10.8	0.013
19	0.087	26.07	0.022	6.49	0.013
20	0.088	26.11	0.036	10.64	0.013
21	0.088	26.4	0.03	9.03	0.013
22	0.088	26.21	0.023	6.94	0.013
23	0.087	25.17	0.036	10.29	0.013
Average	0.08		0.033		0.013
Total		454.87		186.3	
30-Day Rlng	0.088		0.029		
365-Day Rlng				63126	

5/30/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	25	0.036	10.15	0.013
1	0.082	24.32	0.035	10.41	0.013
2	0.089	26.25	0.029	8.76	0.013
3	0.089	26.15	0.036	10.61	0.013
4	0.088	25.85	0.039	11.43	0.013
5	0.073	21.38	0.028	8.09	0.013
6	0.069	20.95	0.027	8.19	0.013
7	0.072	23.31	0.025	8.28	0.013
8	0.082	25.1	0.03	9.25	0.013

9	0.085	26.44	0.02	6.33	0.013
10	0.082	25.66	0.015	4.61	0.012
11	0.081	25.34	0.029	9.06	0.012
12	0.083	25.23	0.032	9.68	0.013
13	0.083	25.49	0.036	11.11	0.012
14	0.085	25.4	0.036	10.84	0.013
15	0.085	26.05	0.029	9.05	0.012
16	0.086	26.4	0.028	8.54	0.012
17	0.085	25.86	0.03	8.89	0.012
18	0.091	26.7	0.022	6.53	0.013
19	0.087	25.91	0.034	10.26	0.012
20	0.087	25.87	0.034	10.03	0.012
21	0.087	26.15	0.028	8.42	0.012
22	0.087	26.07	0.02	5.9	0.012
23	0.088	26.08	0.018	5.25	0.012
Average	0.084		0.029		0.013
Total		606.96		209.67	
30-Day Rlng	0.088		0.029		
365-Day Rlng				63149	

5/31/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	26.16	0.028	8.36	0.013
1	0.087	26.23	0.026	7.77	0.013
2	0.087	26.06	0.027	8.05	0.012
3	0.087	26.14	0.025	7.61	0.013
4	0.087	26.09	0.021	6.1	0.013
5	0.088	25.93	0.026	7.74	0.013
6	0.08	24.64	0.03	9.36	0.012
7	0.07	22.34	0.033	11.21	0.013
8	0.084	25.6	0.031	9.38	0.013
9	0.085	26.1	0.029	8.87	0.012
10	0.082	25.19	0.036	10.99	0.012
11	0.084	25.03	0.024	7.31	0.012
12	0.075	22.42	0.035	10.49	0.013
13	0.084	25.45	0.029	8.82	0.012
14	0.081	24.78	0.034	10.28	0.012
15	0.085	25.88	0.03	9.25	0.012
16	0.086	26.28	0.035	10.63	0.012
17	0.085	25.46	0.034	10.06	0.012
18	0.087	26.22	0.026	7.82	0.012
19	0.086	26.33	0.025	7.7	0.012
20	0.085	25.81	0.036	10.78	0.012
21	0.089	26.04	0.03	8.9	0.013
22	0.088	26.39	0.036	10.79	0.013
23	0.093	27.1	0.021	6.28	0.013
Average	0.085		0.029		0.012
Total		613.67		214.55	

30-Day Rlng 0.087
 365-Day Rlng 0.029
 63173
 6/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	25.34	0.032	9.3	0.013
1	0.054	15.94	0.033	9.76	0.013
2	0.05	14.48	0.035	10.29	0.013
3	0.07	21.08	0.032	9.88	0.013
4	0.076	24.61	0.032	10.35	0.013
5	0.081	25.63	0.027	8.4	0.012
6	0.086	26.45	0.024	7.49	0.012
7	0.085	26.19	0.024	7.38	0.012
8	0.085	25.95	0.025	7.5	0.012
9	0.085	26.18	0.022	6.67	0.012
10	0.085	27.73	0.028	9.31	0.012
11 Maint	Maint	Maint	Maint	Maint	
12	0.078	26.46	0.018	6.07	0.012
13	0.067	25.68	0.022	8.45	0.012
14	0.068	26.27	0.018	7.02	0.012
15	0.082	25.8	0.023	7.24	0.012
16	0.082	24.02	0.024	7.15	0.013
17	0.084	26.22	0.028	8.63	0.012
18	0.083	25.9	0.017	5.34	0.012
19	0.083	26.22	0.018	5.48	0.012
20	0.085	26.32	0.025	7.81	0.012
21	0.084	25.93	0.023	6.95	0.012
22	0.083	26.29	0.022	6.99	0.012
23	0.082	25.45	0.027	8.48	0.012
Average	0.078		0.025		0.012
Total		570.14		181.94	
30-Day Rlng	0.087		0.029		
365-Day Rlng				63160	

6/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	26.55	0.022	6.55	0.012
1	0.085	25.82	0.023	7.07	0.012
2	0.086	26.66	0.025	7.86	0.012
3	0.084	26.69	0.031	9.7	0.012
4 OOC	OOC		0.018	6.18	0.012
5	0.079	25.45	0.026	8.69	0.012
6	0.082	24.44	0.033	9.72	0.012
7	0.089	26.08	0.031	9.21	0.012
8	0.083	24.7	0.031	9.1	0.012
9	0.086	26	0.028	8.41	0.012
10	0.087	26.34	0.035	10.47	0.012
11	0.086	25.63	0.024	7.06	0.012
12	0.088	26.21	0.029	8.54	0.012

13	0.086	25.98	0.025	7.61	0.012
14	0.084	25.57	0.027	8.12	0.012
15	0.086	26.46	0.04	12.38	0.012
16	0.083	25.76	0.032	9.72	0.012
17	0.082	25.6	0.023	7.09	0.012
18	0.084	26.2	0.034	10.56	0.012
19	0.084	25.98	0.025	7.82	0.012
20	0.084	25.88	0.032	9.97	0.012
21	0.085	26.32	0.027	8.49	0.012
22	0.085	26.45	0.031	9.48	0.012
23	0.085	24.2	0.023	6.58	0.013
Average	0.085		0.028		0.012
Total		594.97		206.38	
30-Day Rlng	0.087		0.029		
365-Day Rlng				63163	

6/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.48	0.029	8.65	0.012
1	0.088	26.23	0.016	4.72	0.012
2	0.089	26.04	0.018	5.27	0.012
3	0.089	26.17	0.024	7.16	0.012
4	0.086	27.9	0.032	10.27	0.012
5	0.086	26.48	0.023	7.09	0.012
6	0.081	25.56	0.022	6.8	0.012
7	0.076	22.73	0.022	6.69	0.012
8	0.076	21.85	0.021	5.99	0.012
9	0.086	12.46	0.02	2.89	0.017
10	0.076	18.93	0.019	4.98	0.013
11	0.082	26.01	0.021	6.83	0.012
12	0.081	26.15	0.025	7.89	0.012
13	0.081	25.96	0.026	8.21	0.012
14	0.083	26.27	0.03	9.61	0.012
15	0.082	25.88	0.021	6.6	0.012
16	0.083	26.35	0.026	8.22	0.012
17	0.081	25.82	0.024	7.65	0.012
18	0.081	26.19	0.021	6.77	0.012
19	0.081	26.73	0.029	9.48	0.012
20	0.08	26.06	0.026	8.38	0.012
21	0.081	26.4	0.029	9.53	0.012
22	0.08	26.22	0.023	7.44	0.012
23	0.085	25.57	0.025	7.62	0.012
Average	0.083		0.024		0.012
Total		600.44		174.74	
30-Day Rlng	0.087		0.028		
365-Day Rlng				63154	

6/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
------	--------------	---------	--------------	---------	-------------

0	0.085	25.69	0.023	6.98	0.012
1	0.084	26.36	0.029	9.16	0.012
2	0.086	26.4	0.028	8.68	0.012
3	0.084	26.61	0.029	9.38	0.012
4	0.077	26.44	0.031	10.68	0.012
5	0.081	26.03	0.031	9.91	0.012
6	0.079	25.75	0.033	10.54	0.012
7	0.08	26.01	0.027	8.69	0.012
8	0.082	26.1	0.022	6.93	0.012
9	0.082	26.29	0.018	5.8	0.012
10	0.081	25.78	0.031	9.88	0.012
11	0.082	26.21	0.027	8.76	0.012
12	0.083	26.42	0.022	6.88	0.012
13	0.082	25.9	0.025	8.04	0.012
14	0.084	26.03	0.031	9.54	0.012
15	0.082	26.15	0.031	9.8	0.012
16	0.081	25.86	0.023	7.36	0.012
17	0.084	26.35	0.028	8.84	0.012
18	0.081	25.94	0.03	9.57	0.012
19	0.081	26.08	0.031	9.84	0.012
20	0.084	25.96	0.034	10.57	0.012
21	0.085	26.41	0.023	7.27	0.012
22	0.083	26.02	0.026	8.19	0.012
23	0.084	25.55	0.031	9.35	0.012
Average	0.082		0.028		0.012
Total		626.34		210.64	
30-Day Rlng	0.086		0.028		
365-Day Rlng				63172	

6/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	25.98	0.033	9.99	0.012
1	0.085	26.36	0.035	10.8	0.012
2	0.085	26.21	0.023	7.21	0.012
3	0.083	26.31	0.031	9.93	0.012
4	0.081	27.06	0.04	13.45	0.012
5	0.083	26.94	0.026	8.51	0.012
6	0.08	26.37	0.027	8.83	0.012
7	0.08	26.54	0.026	8.53	0.012
8	0.079	25.91	0.028	9.25	0.012
9	0.079	25.65	0.032	10.4	0.012
10	0.079	26.11	0.024	7.83	0.012
11	0.08	25.82	0.025	7.9	0.012
12	0.08	25.94	0.032	10.3	0.012
13	0.083	26.76	0.026	8.39	0.012
14	0.079	25.31	0.041	13.25	0.012
15	0.081	25.84	0.017	5.39	0.012
16	0.083	26.74	0.024	7.73	0.012

17	0.082	25.55	0.022	6.89	0.012
18	0.084	25.89	0.033	10.24	0.012
19	0.085	26.34	0.024	7.52	0.012
20	0.087	26.92	0.024	7.32	0.012
21	0.082	25.79	0.029	9.16	0.012
22	0.083	25.96	0.026	8.15	0.012
23	0.082	25.72	0.031	9.72	0.012
Average	0.082		0.028		0.012
Total		628.02		216.69	
30-Day Rlng	0.086		0.028		
365-Day Rlng				63194	

6/6/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	26.43	0.033	10.37	0.012
1	0.084	26.15	0.03	9.23	0.012
2	0.085	26.76	0.032	9.96	0.012
3	0.081	25.9	0.032	10.19	0.012
4	0.082	25.99	0.04	12.74	0.012
5	0.084	26.73	0.019	6.15	0.012
6	0.084	27.55	0.026	8.48	0.012
7	0.08	26.06	0.028	9.11	0.012
8	0.081	26.16	0.031	9.93	0.012
9	0.082	25.65	0.031	9.76	0.012
10	0.082	26.06	0.023	7.4	0.012
11	0.081	25.79	0.02	6.37	0.012
12	0.084	25.84	0.017	5.22	0.012
13	0.085	26.72	0.028	8.85	0.012
14	0.084	25.68	0.023	7.17	0.012
15	0.085	26.15	0.025	7.64	0.012
16	0.082	25.99	0.022	7.14	0.012
17	0.082	26.07	0.019	5.9	0.012
18	0.082	25.85	0.019	5.9	0.012
19	0.083	26.44	0.028	8.97	0.012
20	0.083	26.03	0.027	8.62	0.012
21	0.083	26	0.032	9.94	0.012
22	0.083	26.21	0.034	10.69	0.012
23	0.084	25.81	0.019	6.03	0.012
Average	0.083		0.027		0.012
Total		628.02		201.76	
30-Day Rlng	0.086		0.028		
365-Day Rlng				63212	

6/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	26.02	0.026	7.82	0.012
1	0.084	26.1	0.032	9.98	0.012
2	0.083	26.06	0.032	10.06	0.012
3	0.083	25.86	0.032	9.92	0.012

4	0.084	26.81	0.03	9.38	0.012
5	0.081	26	0.03	9.59	0.012
6	0.081	26.99	0.024	8.04	0.012
7	0.084	24.68	0.02	5.85	0.012
8	0.084	26.76	0.026	8.35	0.012
9	0.08	25.31	0.02	6.32	0.012
10	0.082	26.02	0.026	8.18	0.012
11	0.083	26.55	0.032	10.2	0.012
12	0.079	24.16	0.025	7.62	0.012
13	0.086	26.83	0.031	9.63	0.012
14	0.083	25.95	0.023	7.16	0.012
15	0.083	26.65	0.021	6.62	0.012
16	0.082	26.12	0.021	6.86	0.012
17	0.084	26.3	0.019	6.11	0.012
18	0.082	25.62	0.031	9.8	0.012
19	0.083	26.1	0.018	5.79	0.012
20	0.086	25.92	0.023	7.05	0.012
21	0.09	26.65	0.027	7.87	0.012
22	0.084	25.63	0.031	9.54	0.012
23	0.087	26.38	0.031	9.44	0.012
Average	0.083		0.026		0.012
Total		625.47		197.18	
30-Day Rlng	0.086		0.028		
365-Day Rlng				63224	

6/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.084	25.33	0.028	8.57	0.012
1	0.085	26.07	0.028	8.67	0.012
2	0.088	26.91	0.029	8.8	0.012
3	0.086	26.11	0.026	7.84	0.012
4	0.084	25.31	0.028	8.41	0.012
5	0.088	27.2	0.028	8.71	0.012
6	0.093	28.52	0.031	9.46	0.012
7	0.086	25.46	0.024	7.16	0.012
8	0.089	26.4	0.023	6.75	0.012
9	0.085	25.19	0.023	6.87	0.012
10	0.088	26.51	0.032	9.65	0.012
11	0.087	25.88	0.03	9.03	0.012
12	0.086	25.4	0.031	8.99	0.012
13	0.088	26.12	0.019	5.6	0.012
14	0.088	26.12	0.025	7.39	0.012
15	0.089	26.11	0.024	6.93	0.012
16	0.091	26.96	0.027	8.01	0.012
17	0.088	26.05	0.024	7.13	0.012
18	0.088	25.84	0.03	8.9	0.012
19	0.088	25.8	0.028	8.04	0.012
20	0.086	25.2	0.024	7.17	0.012

21	0.087	25.64	0.028	8.19	0.012
22	0.088	26.4	0.027	8.09	0.012
23	0.087	25.19	0.029	8.32	0.012
Average	0.087		0.027		0.012
Total		625.72		192.68	
30-Day Rlng	0.086		0.028		
365-Day Rlng				63231	

6/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.94	0.025	7.18	0.012
1	0.088	25.35	0.026	7.41	0.012
2	0.09	25.57	0.027	7.58	0.013
3	0.087	25.14	0.027	7.61	0.012
4	0.087	25.14	0.029	8.25	0.013
5	0.082	25.1	0.024	7.24	0.012
6	0.078	27.43 Cal	Cal		0.012
7	0.088	25.85	0.026	7.71	0.012
8	0.092	26.91	0.026	7.72	0.012
9	0.088	25.76	0.025	7.2	0.012
10	0.087	25.53	0.03	8.81	0.012
11	0.089	26.42	0.026	7.88	0.012
12	0.089	26.06	0.026	7.44	0.012
13	0.088	26	0.034	10.12	0.012
14	0.086	25.98	0.032	9.53	0.012
15	0.088	25.48	0.019	5.56	0.012
16	0.089	26.44	0.026	7.85	0.012
17	0.088	26.49	0.03	8.97	0.012
18	0.086	25.68	0.028	8.34	0.012
19	0.084	25.19	0.035	10.54	0.012
20	0.086	25.69	0.019	5.74	0.012
21	0.089	26.08	0.023	6.87	0.012
22	0.085	25.92	0.029	8.99	0.012
23	0.079	23.29	0.02	5.89	0.012
Average	0.087		0.027		0.012
Total		618.44		180.43	
30-Day Rlng	0.086		0.028		
365-Day Rlng				63216	

6/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.081	23.93	0.026	7.73	0.012
1	0.085	25.3	0.027	8.14	0.012
2	0.091	27.25	0.028	8.33	0.012
3	0.081	24.3	0.027	7.95	0.012
4	0.085	25.84	0.026	7.91	0.012
5	0.088	26.75	0.023	6.88	0.012
6	0.082	26.35	0.021	6.69	0.012
7	0.085	26.25	0.024	7.27	0.012

8	0.075	21.96	0.019	5.54	0.013
9	0.084	25.52	0.024	7.28	0.012
10	0.085	26.47	0.032	10.01	0.012
11	0.086	26.03	0.016	4.83	0.012
12	0.084	24.78	0.015	4.47	0.012
13	0.088	26.34	0.03	9.06	0.012
14	0.088	26.26	0.029	8.48	0.012
15	0.087	25.91	0.029	8.46	0.012
16	0.087	25.67	0.029	8.6	0.012
17	0.086	25.95	0.024	7.34	0.012
18	0.086	25.94	0.03	9.03	0.012
19	0.087	26.68	0.027	8.24	0.012
20	0.083	25.55	0.027	8.26	0.012
21	0.083	25.64	0.029	8.82	0.012
22	0.084	25.9	0.025	7.76	0.012
23	0.083	25.38	0.025	7.62	0.012
Average	0.085		0.026		0.012
Total		615.95		184.7	
30-Day Rlng	0.086		0.028		
365-Day Rlng				63224	

6/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.082	25.12	0.024	7.2	0.012
1	0.084	26.08	0.029	8.87	0.012
2	0.086	26.54	0.027	8.45	0.012
3	0.082	24.6	0.021	6.22	0.012
4	0.086	25.76	0.029	8.53	0.012
5	0.09	27.58	0.028	8.64	0.012
6	0.083	28.28	0.034	12.1	0.012
7	0.083	25.35	0.026	7.99	0.012
8	0.086	26.37	0.027	8.37	0.012
9	0.085	25.88	0.027	8.33	0.012
10	0.086	26.31	0.023	7.01	0.012
11	0.087	26.31	0.02	5.98	0.012
12	0.087	25.76	0.035	10.37	0.012
13	0.088	26.11	0.024	7.24	0.012
14	0.086	26.08	0.027	8.16	0.012
15	0.086	25.63	0.021	6.15	0.012
16	0.089	26.61	0.04	12.08	0.012
17	0.086	25.78	0.03	9.06	0.012
18	0.084	25.35	0.024	7.16	0.012
19	0.084	26.07	0.026	8.17	0.012
20	0.085	26.46	0.029	8.86	0.012
21	0.087	26.33	0.027	8.22	0.012
22	0.087	26.56	0.029	8.92	0.012
23	0.083	25.3	0.023	7.09	0.012
Average	0.086		0.027		0.012

Total		626.22		199.17	
30-Day Rlng	0.086		0.028		
365-Day Rlng				63249	
6/12/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.083	25.38	0.027	8.32	0.012
1	0.083	25.3	0.029	8.94	0.012
2	0.086	26.63	0.03	9.13	0.012
3	0.082	25.38	0.026	8.12	0.012
4	0.087	26.94	0.027	8.22	0.012
5	0.079	24.8	0.029	8.95	0.012
6	0.081	26.82	0.026	8.55	0.012
7	0.084	26.32	0.022	7.02	0.012
8	0.08	26.31	0.025	8.14	0.012
9	0.083	26.16	0.027	8.52	0.012
10	0.085	26.6	0.022	6.96	0.012
11	0.083	25.96	0.022	6.93	0.012
12	0.083	25.62	0.029	8.82	0.012
13	0.084	25.8	0.028	8.66	0.012
14	0.086	27.21	0.03	9.63	0.012
15	0.081	24.78	0.027	8.25	0.012
16	0.084	26.36	0.029	9.05	0.012
17	0.085	26.39	0.028	8.79	0.012
18	0.083	25.63	0.024	7.27	0.012
19	0.08	24.79	0.018	5.7	0.012
20	0.085	26.07	0.025	7.85	0.012
21	0.087	27	0.026	7.91	0.012
22	0.085	26.26	0.031	9.72	0.012
23	0.083	25.86	0.019	5.81	0.012
Average	0.083		0.026		0.012
Total		624.37		195.26	
30-Day Rlng	0.085		0.028		
365-Day Rlng				63269	
6/13/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	26.22	0.027	8.41	0.012
1	0.082	25.16	0.033	10.19	0.012
2	0.085	25.52	0.026	7.86	0.012
3	0.088	26.66	0.03	9.23	0.012
4	0.088	26.94	0.035	10.62	0.012
5	0.079	24.33	0.026	7.82	0.012
6	0.078	25.83	0.024	8.02	0.012
7	0.085	26.71	0.024	7.54	0.012
8	0.082	25.9	0.023	7.36	0.012
9	0.082	25.21	0.026	8.07	0.012
10	0.085	26.55	0.029	9.17	0.012
11	0.083	25.83	0.027	8.35	0.012

12	0.087	26.79	0.029	8.75	0.012
13	0.083	25.71	0.033	10.31	0.012
14	0.084	26.69	0.023	7.3	0.012
15	0.081	25	0.027	8.25	0.012
16	0.087	26.94	0.033	10.26	0.012
17	0.084	26.08	0.033	10.08	0.012
18	0.084	25.02	0.021	6.17	0.012
19	0.087	26.36	0.026	7.75	0.012
20	0.087	26.3	0.027	8.24	0.012
21	0.085	25.98	0.022	6.82	0.012
22	0.084	25.87	0.023	7.11	0.012
23	0.087	26.23	0.018	5.38	0.012
Average	0.084		0.027		0.012
Total		623.83		199.06	
30-Day Rlng	0.084		0.027		
365-Day Rlng				63275	

6/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	25.74	0.029	8.58	0.012
1	0.086	26.32	0.025	7.73	0.012
2	0.087	26.28	0.029	8.76	0.012
3	0.085	26.23	0.027	8.37	0.012
4	0.083	25.59	0.024	7.44	0.012
5	0.086	27.02	0.024	7.57	0.012
6	0.078	25.85	0.031	10.37	0.012
7	0.081	25.48	0.028	8.95	0.012
8	0.086	27.03	0.026	8.26	0.012
9	0.081	25.66	0.026	8.15	0.012
10	0.082	25.63	0.025	7.94	0.012
11	0.085	27.12	0.025	7.92	0.012
12	0.083	25.38	0.026	8.01	0.012
13	0.083	25.63	0.027	8.29	0.012
14	0.083	25.95	0.024	7.62	0.012
15	0.083	25.96	0.032	10.03	0.012
16	0.084	25.5	0.033	10.07	0.012
17	0.088	27.67	0.03	9.51	0.012
18	0.083	25.55	0.024	7.55	0.012
19	0.084	26.59	0.029	9.31	0.012
20	0.082	26.54	0.027	8.69	0.012
21	0.085	26.57	0.025	7.83	0.012
22	0.082	25.3	0.02	6.03	0.012
23	0.084	26.17	0.019	5.96	0.012
Average	0.084		0.026		0.012
Total		626.76		198.94	
30-Day Rlng	0.084		0.027		
365-Day Rlng				63281	

6/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	25.9	0.032	9.69	0.012
1	0.085	26.13	0.029	8.82	0.012
2	0.085	26.45	0.029	8.95	0.012
3	0.088	27.01	0.032	9.71	0.012
4	0.085	26.42	0.031	9.58	0.012
5	0.081	25.38	0.027	8.4	0.012
6	0.084	28.85	0.029	10.06	0.021
7	0.085	27.14	0.026	8.13	0.012
8	0.081	25.56	0.027	8.59	0.012
9	0.084	26.34	0.027	8.55	0.012
10	0.085	26.27	0.034	10.56	0.012
11	0.083	25.57	0.018	5.51	0.012
12	0.086	25.87	0.029	8.66	0.012
13	0.087	25.76	0.035	10.28	0.012
14	0.089	27.03	0.028	8.61	0.012
15	0.084	25	0.034	9.96	0.012
16	0.089	26.88	0.032	9.67	0.012
17	0.086	26.48	0.024	7.29	0.012
18	0.085	25.87	0.026	7.91	0.012
19	0.082	25.64	0.028	8.93	0.012
20	0.083	25.22	0.036	10.84	0.012
21	0.088	26.24	0.033	10	0.012
22	0.087	26.32	0.016	4.81	0.012
23	0.087	26.78	0.022	6.78	0.012
Average	0.085		0.029		0.012
Total		630.11		210.29	
30-Day Rng	0.084		0.027		
365-Day Rng				63300	

6/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	25.75	0.025	7.49	0.012
1	0.085	25.71	0.024	7.34	0.012
2	0.085	26.06	0.023	7.02	0.012
3	0.085	26.13	0.029	8.91	0.012
4	0.085	26.39	0.021	6.32	0.012
5	0.083	25.72	0.023	7.12	0.012
6	0.085	28.12	0.032	10.69	0.012
7	0.083	25.73	0.04	12.36	0.012
8	0.086	26.21	0.029	8.75	0.012
9	0.086	26.04	0.029	8.8	0.012
10	0.084	26.11	0.034	10.53	0.012
11	0.083	25.7	0.028	8.55	0.012
12	0.088	26.38	0.033	9.76	0.012
13	0.085	25.97	0.034	10.42	0.012
14	0.086	26.55	0.021	6.38	0.012
15	0.083	25.6	0.029	8.82	0.012

16	0.083	26.08	0.03	9.42	0.012
17	0.084	26.58	0.027	8.61	0.012
18	0.083	25.36	0.031	9.41	0.012
19	0.083	24.52	0.032	9.39	0.012
20	0.055	9.99	0.02	3.59	0.017
21	0.059	10.36	0.02	3.58	0.018
22	0.046	8.31	0.02	3.62	0.018
23	0.043	7.94	0.02	3.65	0.017
Average	0.079		0.027		0.013
Total		557.31		190.53	
30-Day Rlng	0.084		0.027		
365-Day Rlng				63298	

6/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.054	9.87	0.02	3.61	0.017
1	0.035	6.71	0.019	3.66	0.017
2	0.024	5.46	0.017	3.85	0.014
3	0.072	21.49	0.026	7.69	0.012
4	0.088	27.18	0.024	7.44	0.012
5	0.085	26.07	0.025	7.78	0.012
6	0.085	28.24	0.033	11.32	0.012
7	0.084	26.27	0.027	8.5	0.012
8	0.085	26	0.022	6.61	0.012
9	0.085	25.81	0.031	9.26	0.012
10	0.085	26.42	0.032	9.95	0.012
11	0.084	26.24	0.021	6.67	0.012
12	0.084	25.8	0.022	6.81	0.012
13	0.085	21.54	0.026	6.77	0.012
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down	Down
Average	0.074		0.025		0.013
Total		303.1		99.92	
30-Day Rlng	0.084		0.027		
365-Day Rlng				63206	

6/18/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down

3 Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down
5 Down	Down	DCal	DCal	DCal
6 DCAL	DCal	DCal	DCal	DCal
7 Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down
Average	Down		Down	Down
Total		Down		Down
30-Day Rng	0.084		0.027	
365-Day Rng				63014

6/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down

	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.084		0.027	
365-Day Rlng					62814

6/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0 Down	Down	Down	Down	Down
	1 Down	Down	Down	Down	Down
	2 Down	Down	Down	Down	Down
	3 Down	Down	Down	Down	Down
	4 Down	Down	Down	Down	Down
	5 Down	Down	Down	Down	Down
	6 Down	Down	Down	Down	Down
	7 Down	Down	Down	Down	Down
	8 Down	Down	Down	Down	Down
	9 Down	Down	Down	Down	Down
	10 Down	Down	Down	Down	Down
	11 Down	Down	Down	Down	Down
	12 Down	Down	Down	Down	Down
	13 Down	Down	Down	Down	Down
	14 Down	Down	Down	Down	Down
	15 Down	Down	Down	Down	Down
	16 Down	Down	Down	Down	Down
	17 Down	Down	Down	Down	Down
	18 Down	Down	Down	Down	Down
	19 Down	Down	Down	Down	Down
	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.084		0.027	
365-Day Rlng					62619

6/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0 Down	Down	Down	Down	Down
	1 Down	Down	Down	Down	Down
	2 Down	Down	Down	Down	Down
	3 Down	Down	Down	Down	Down
	4 Down	Down	Down	Down	Down
	5 Down	Down	Down	Down	Down
	6 Down	Down	Down	Down	Down

7 Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down
Average	Down	Down	Down	Down
Total		Down	Down	
30-Day Rlng	0.084		0.027	
365-Day Rlng				62431

6/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down	Down

Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.084		0.027	
365-Day Rlng					62244

6/23/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.084		0.027	
365-Day Rlng					62056

6/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down

11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.084		0.027	
365-Day Rlng					61862

6/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Down	Down	Down	Down	Down
3	Down	Down	Down	Down	Down
4	Down	Down	Down	Down	Down
5	Down	Down	Down	Down	Down
6	Down	Down	Down	Down	Down
7	Down	Down	Down	Down	Down
8	Down	Down	Down	Down	Down
9	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.084		0.027	
365-Day Rlng					61670

6/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Maint	Maint	Maint	Maint	Maint	Maint
19 Maint	Maint	Maint	Maint	Maint	Maint
20 Maint	Maint	Maint	Maint	Maint	Maint
21 Maint	Maint	Maint	Maint	Maint	Maint
22 Maint	Maint	Maint	Maint	Maint	Maint
23 Maint	Maint	Maint	Maint	Maint	Maint
Average	Maint		Maint		Maint
Total		Maint		Maint	
30-Day Rlng		0.084		0.027	
365-Day Rlng					61471

6/27/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Maint	Maint	Maint	Maint	Maint	Maint
1 Maint	Maint	Maint	Maint	Maint	Maint
2 Maint	Maint	Maint	Maint	Maint	Maint
3 Maint	Maint	Maint	Maint	Maint	Maint
4 Maint	Maint	Maint	Maint	Maint	Maint
5 Maint	Maint	Maint	Maint	Maint	Maint
6	0.072	26.4	0.124	45.57	0.012
7	0.076	25.97	0.062	21.1	0.012
8	0.082	26.29	0.019	5.97	0.012
9	0.082	25.78	0.019	5.9	0.012
10	0.085	26.44	0.017	5.25	0.012
11	0.086	26.68	0.016	4.93	0.012
12	0.085	25.56	0.028	8.42	0.012
13	0.086	26.2	0.029	8.95	0.012
14	0.086	26.32	0.023	7.08	0.012

15	0.086	26.07	0.024	7.26	0.012
16	0.086	26.26	0.02	6.2	0.012
17	0.083	25.23	0.014	4.12	0.012
18	0.077	23.75	0.021	6.43	0.012
19	0.083	25.14	0.026	7.87	0.012
20	0.083	24.9	0.022	6.64	0.012
21	0.083	24.93	0.018	5.24	0.012
22	0.082	24.68	0.033	9.85	0.012
23	0.082	24.3	0.027	7.96	0.012
Average		0.083	0.03		0.012
Total		460.9		174.74	
30-Day Rlng	0.084		0.027		
365-Day Rlng				61449	

6/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.084	25.21	0.035	10.55	0.012
1	0.081	24.67	0.022	6.67	0.012
2	0.084	25.64	0.029	8.8	0.012
3	0.087	26.13	0.023	7.04	0.012
4	0.081	24.21	0.025	7.56	0.012
5	0.082	25.96	0.019	6.1	0.012
6	0.08	27.41	0.026	8.84	0.012
7	0.078	24.85	0.023	7.37	0.012
8	0.078	24.4	0.018	5.55	0.012
9	0.081	25.22	0.037	11.62	0.012
10	0.082	25.78	0.031	9.64	0.012
11	0.075	24.4	0.027	8.73	0.012
12	0.077	24.12	0.023	7.38	0.012
13	0.084	25.32	0.021	6.2	0.012
14	0.082	24.96	0.026	7.9	0.012
15	0.084	24.95	0.021	6.16	0.012
16	0.086	25.53	0.029	8.59	0.012
17	0.086	25.49	0.018	5.23	0.012
18	0.083	24.17	0.025	7.31	0.012
19	0.086	24.94	0.024	7.05	0.012
20	0.081	23.86	0.022	6.46	0.012
21	0.09	26.63	0.028	8.17	0.012
22	0.08	23.96	0.025	7.54	0.012
23	0.085	22.31	0.024	6.63	0.012
Average		0.082	0.025		0.012
Total		600.12		183.09	
30-Day Rlng	0.083		0.027		
365-Day Rlng				61437	

6/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.099	19.38	0.035	6.88	0.012
1	0.087	15.47	0.034	6.01	0.012

2	0.105	21.14	0.045	9.04	0.012
3	0.093	18.11	0.018	3.57	0.012
4	0.103	20.19	0.033	6.53	0.012
5	0.1	20.13	0.026	5.31	0.012
6	0.091	23.69	0.022	5.53	0.012
7	0.088	18.09	0.021	4.41	0.012
8	0.085	20.74	0.015	3.92	0.012
9	0.069	20.19	0.015	4.51	0.012
10	0.067	19.89	0.018	5.18	0.012
11	0.069	20.63	0.019	5.71	0.012
12	0.065	19.08	0.018	5.24	0.012
13	0.071	19.85	0.018	4.92	0.012
14	0.073	21	0.027	7.88	0.012
15	0.073	21.08	0.018	5.13	0.012
16	0.069	19.96	0.027	7.76	0.012
17	0.072	21.25	0.02	5.94	0.012
18	0.084	24.76	0.028	8.24	0.012
19	0.086	25.52	0.036	10.64	0.012
20	0.086	24.96	0.027	7.85	0.012
21	0.091	26.72	0.03	8.65	0.012
22	0.088	26.02	0.032	9.46	0.012
23	0.086	24.63	0.039	11.1	0.012
Average	0.083		0.026		0.012
Total		512.48		159.41	
30-Day Rlng	0.083		0.027		
365-Day Rlng				61405	

6/30/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.077	21.98	0.036	10.1	0.012
1	0.083	23.77	0.032	9.31	0.012
2	0.09	25.84	0.027	7.76	0.012
3	0.088	25.3	0.026	7.52	0.012
4	0.089	25.43	0.023	6.61	0.012
5	0.09	27.06	0.028	8.39	0.012
6	0.082	26.31	0.026	8.2	0.012
7	0.089	26.44	0.03	8.94	0.012
8	0.085	25.69	0.033	9.87	0.012
9	0.086	25.89	0.027	8.2	0.012
10	0.087	26.27	0.033	9.95	0.012
11	0.088	26.28	0.027	8.2	0.012
12	0.086	25.45	0.021	6.27	0.012
13	0.089	26.35	0.028	8.41	0.012
14	0.092	27.12	0.021	6.22	0.012
15	0.088	25.55	0.031	9.02	0.012
16	0.093	26.75	0.024	6.79	0.012
17	0.084	24.37	0.024	6.88	0.012
18	0.093	26.99	0.031	8.93	0.012

19	0.088	25.79	0.022	6.31	0.012
20	0.088	25.46	0.028	8.14	0.012
21	0.091	26.14	0.023	6.74	0.012
22	0.09	26.06	0.027	7.9	0.012
23	0.089	25.58	0.028	8.14	0.012
Average	0.088		0.027		0.012
Total		617.87		192.8	
30-Day Rlng	0.084		0.027		
365-Day Rlng				61394	

7/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.95	0.031	9	0.012
1	0.087	25.2	0.028	8.13	0.012
2	0.09	26.22	0.032	9.23	0.012
3	0.085	24.84	0.025	7.22	0.012
4	0.088	25.95	0.027	8	0.012
5	0.09	26.51	0.023	6.77	0.012
6	0.072	22.05	0.024	7.47	0.012
7	0.081	30.26	0.025	9.37	0.011
8	0.044	19.72	0.017	7.64	0.009
9	0.093	25.72	0.019	5.13	0.012
10	0.092	26.31	0.029	8.43	0.012
11	0.092	26.24	0.026	7.34	0.012
12	0.091	25.73	0.032	8.89	0.012
13	0.091	26.09	0.034	9.72	0.012
14	0.091	26.03	0.023	6.44	0.012
15	0.091	25.79	0.022	6.32	0.012
16	0.091	26.4	0.024	6.95	0.012
17	0.089	25.72	0.033	9.61	0.012
18	0.086	25.01	0.025	7.27	0.012
19	0.078	22.82	0.034	10.02	0.012
20	0.084	24.19	0.028	8	0.012
21	0.085	24.36	0.037	10.61	0.012
22	0.092	26.34	0.017	4.82	0.012
23	0.09	25.47	0.037	10.44	0.012
Average	0.086		0.027		0.012
Total		608.92		192.82	
30-Day Rlng	0.084		0.027		
365-Day Rlng				61382	

7/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	26.04	0.041	11.5	0.013
1	0.084	24.06	0.025	7.22	0.013
2	0.083	23.75	0.029	8.2	0.012
3	0.092	25.76	0.038	10.73	0.012
4	0.093	26.41	0.03	8.62	0.012
5	0.089	26.48	0.024	7.01	0.012

6	0.083	27.08	0.027	8.77	0.012
7	0.09	26.39	0.027	8.06	0.012
8	0.087	25.99	0.035	10.39	0.012
9	0.088	25.82	0.032	9.41	0.012
10	0.088	25.53	0.031	8.92	0.012
11	0.09	26.43	0.03	8.82	0.012
12	0.091	26.19	0.031	8.93	0.012
13	0.09	25.86	0.04	11.63	0.012
14	0.091	26.55	0.019	5.45	0.012
15	0.09	25.7	0.022	6.27	0.012
16	0.089	26.26	0.031	9.04	0.012
17	0.087	26.01	0.022	6.54	0.012
18	0.086	25.71	0.03	8.79	0.012
19	0.085	26.45	0.036	11.21	0.012
20	0.087	26.01	0.034	10.15	0.012
21	0.089	26.17	0.03	8.71	0.012
22	0.089	26.35	0.022	6.5	0.012
23	0.089	25.61	0.031	8.76	0.012
Average	0.088		0.03		0.012
Total		622.61		209.63	
30-Day Rlng	0.084		0.027		
365-Day Rlng				61411	

7/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.47	0.034	9.45	0.012
1	0.093	26.29	0.031	8.66	0.012
2	0.091	25.98	0.025	7.06	0.012
3	0.095	26.74	0.021	5.99	0.012
4	0.089	25.64	0.03	8.59	0.012
5	0.093	27.52	0.026	7.82	0.012
6	0.084	26.6	0.024	7.61	0.012
7	0.088	26.77	0.03	8.99	0.012
8	0.084	25.3	0.026	7.86	0.012
9	0.09	27.09	0.026	7.66	0.012
10	0.081	26.84	0.023	7.82	0.012
11	0.088	25.36	0.021	6.1	0.012
12	0.091	26.16	0.03	8.46	0.012
13	0.09	26.19	0.026	7.51	0.012
14	0.088	26.63	0.03	9.16	0.012
15	0.086	25.95	0.029	8.79	0.012
16	0.086	25.95	0.021	6.3	0.012
17	0.086	25.9	0.024	7.33	0.012
18	0.089	26.71	0.024	7.35	0.012
19	0.085	26.02	0.016	4.95	0.012
20	0.088	26.3	0.022	6.5	0.012
21	0.086	25.36	0.019	5.76	0.012
22	0.09	25.7	0.032	9.21	0.012

	23	0.084	23.76	0.018	5.05	0.012
Average		0.088		0.025		0.012
Total			626.23		179.98	
30-Day Rlng		0.084		0.027		
365-Day Rlng					61399	

7/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	26.68	0.021	5.99	0.012
1	0.088	25.75	0.022	6.39	0.012
2	0.09	26.48	0.024	7.13	0.012
3	0.09	26.34	0.033	9.48	0.012
4	0.087	25.76	0.018	5.4	0.012
5	0.085	25.65	0.028	8.59	0.012
6	0.084	28.05 OOC	OOC	OOC	
7	0.079	24.64	0.021	6.7	0.012
8	0.087	26.09	0.025	7.53	0.012
9	0.083	24.7	0.021	6.35	0.012
10	0.088	26.65	0.021	6.5	0.012
11	0.086	26.21	0.027	8.36	0.012
12	0.085	25.34	0.024	7.11	0.012
13	0.088	26.38	0.03	8.8	0.012
14	0.088	26.16	0.022	6.57	0.012
15	0.086	25.24	0.032	9.27	0.012
16	0.088	26.4	0.029	8.58	0.012
17	0.086	25.85	0.025	7.46	0.012
18	0.086	24.91	0.03	8.52	0.012
19	0.095	27.09	0.024	6.96	0.012
20	0.088	25.58	0.023	6.72	0.012
21	0.087	25.61	0.028	8.27	0.012
22	0.091	27.2	0.027	8.02	0.012
23	0.084	24.7	0.027	7.92	0.012
Average	0.087		0.025		0.012
Total		623.46		172.62	
30-Day Rlng	0.084		0.027		
365-Day Rlng				61369	

7/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.56	0.023	6.91	0.012
1	0.091	27.2	0.032	9.54	0.012
2	0.085	25.47	0.02	5.82	0.012
3	0.088	26.16	0.019	5.55	0.012
4	0.089	26.28	0.03	8.9	0.012
5	0.083	24.99	0.029	8.88	0.012
6	0.093	29.07	0.021	6.49	0.012
7	0.084	25.26	0.02	6	0.012
8	0.087	25.92	0.025	7.5	0.012
9	0.088	26.13	0.03	8.78	0.012

10	0.084	25.18	0.023	6.79	0.012
11	0.087	25.51	0.028	8.3	0.012
12	0.089	25.73	0.03	8.79	0.012
13	0.088	25.98	0.034	9.97	0.012
14	0.087	26.43	0.021	6.35	0.012
15	0.087	25.65	0.017	5.03	0.012
16	0.088	26.07	0.022	6.41	0.012
17	0.088	26.18	0.025	7.42	0.012
18	0.085	25.84	0.02	5.95	0.012
19	0.087	26.58	0.02	6.2	0.012
20	0.087	26.41	0.02	5.97	0.012
21	0.086	25.59	0.029	8.66	0.012
22	0.089	26.17	0.028	8.22	0.012
23	0.089	26.2	0.03	8.71	0.012
Average	0.087		0.025		0.012
Total		626.56		177.14	
30-Day Rlng	0.084		0.027		
365-Day Rlng				61346	

7/6/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	25.39	0.025	7.39	0.012
1	0.087	26.31	0.023	6.98	0.012
2	0.084	25.44	0.028	8.44	0.012
3	0.088	26.88	0.024	7.33	0.012
4	0.086	26.41	0.03	9.09	0.012
5	0.083	26.47	0.023	7.19	0.012
6	0.086	28.37	0.014	4.6	0.012
7	0.089	26.86	0.021	6.3	0.012
8	0.082	25.09	0.026	8.01	0.012
9	0.088	26.71	0.027	8.31	0.012
10	0.089	26.86	0.027	8.1	0.012
11	0.083	25.08	0.026	7.76	0.012
12	0.091	26.96	0.033	9.86	0.012
13	0.082	24.78	0.019	5.89	0.012
14	0.089	27.12	0.027	8.23	0.012
15	0.082	24.84	0.021	6.37	0.012
16	0.088	26.78	0.028	8.42	0.012
17	0.081	25.62	0.019	6.08	0.011
18	0.085	24.52	0.03	8.76	0.012
19	0.09	26.66	0.024	7.26	0.012
20	0.075	17.46	0.019	4.43	0.014
21 Down		Down	Down	Down	Down
22 Down		Down	Down	Down	Down
23 Down		Down	Down	Down	Down
Average	0.085		0.024		0.012
Total		540.61		154.8	
30-Day Rlng	0.084		0.027		

365-Day Rlng 61297

7/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	DCal	DCal	DCal	DCal
6 DCAL	DCAL	DCAL	DCAL	DCAL	DCAL
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.084		0.027	
365-Day Rlng					61093

7/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	DCal	DCal	DCal	DCal
6 DCAL	DCAL	DCAL	DCAL	DCAL	DCAL
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down

	14 Down	Down	Down	Down	Down
	15 Down	Down	Down	Down	Down
	16 Down	Down	Down	Down	Down
	17 Down	Down	Down	Down	Down
	18 Down	Down	Down	Down	Down
	19 Down	Down	Down	Down	Down
	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.084		0.027	
365-Day Rlng					60888

7/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	DCal	DCal	DCal	DCal
6 DCAL	DCAL	DCAL	DCAL	DCAL	DCAL
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 OOC	OOC	OOC	OOC	OOC	OOC
16 OOC	OOC	OOC	OOC	OOC	OOC
17 OOC	OOC	OOC	OOC	OOC	OOC
18 OOC	OOC	OOC	OOC	OOC	OOC
19 OOC	OOC	OOC	OOC	OOC	OOC
20 OOC	OOC	OOC	OOC	OOC	OOC
21 OOC	OOC	OOC	OOC	OOC	OOC
22 OOC	OOC	OOC	OOC	OOC	OOC
23 OOC	OOC	OOC	OOC	OOC	OOC
Average	OOC		OOC		OOC
Total		OOC		OOC	
30-Day Rlng		0.084		0.027	
365-Day Rlng					60694

7/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 OOC	OOC	OOC	OOC	OOC	OOC

1	OOC	OOC	OOC	OOC	OOC
2	OOC	OOC	OOC	OOC	OOC
3	OOC	OOC	OOC	OOC	OOC
4	OOC	OOC	OOC	OOC	OOC
5	OOC	OOC	OOC	OOC	OOC
6		0.065	24.39	0.024	8.95 Cal
7		0.084	25.88	0.021	6.39 0.012
8		0.086	26.71	0.022	6.75 0.012
9		0.085	25.21	0.03	8.84 0.012
10		0.089	26.32	0.032	9.33 0.012
11		0.087	26.11	0.025	7.6 0.012
12		0.088	24.87	0.024	6.95 0.012
13		0.089	25.74	0.018	5.28 0.013
14		0.095	26.82	0.014	3.85 0.012
15		0.089	25.98	0.015	4.31 0.012
16		0.09	26.13	0.033	9.71 0.012
17		0.089	25.91	0.037	10.73 0.012
18		0.092	25.95	0.033	9.19 0.012
19		0.091	26.59	0.033	9.75 0.012
20		0.087	25.02	0.033	9.47 0.012
21		0.092	26.39	0.03	8.76 0.012
22		0.089	25.8	0.032	9.3 0.012
23		0.09	26.17	0.035	10.13 0.012
Average		0.088		0.027	0.012
Total			465.99		145.29
30-Day Rlng		0.084		0.027	
365-Day Rlng					60646

7/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.56	0.034	9.89	0.012
1	0.088	25.7	0.028	8.1	0.012
2	0.089	26.58	0.027	8.14	0.012
3	0.09	26.16	0.024	7.04	0.012
4	0.085	24.81	0.032	9.2	0.012
5	0.089	26.48	0.033	9.68	0.012
6	0.083	25.84	0.034	10.7	0.012
7	0.087	26.28	0.03	8.93	0.012
8	0.09	27.02	0.04	12.12	0.012
9	0.086	25.79	0.035	10.62	0.012
10	0.086	25.97	0.027	8.25	0.012
11	0.086	25.48	0.036	10.67	0.012
12	0.084	24.6	0.025	7.28	0.012
13	0.09	26.25	0.027	7.88	0.012
14	0.089	26.17	0.028	8.06	0.012
15	0.089	25.68	0.027	7.84	0.012
16	0.09	26.46	0.023	6.81	0.012
17	0.087	25.45	0.027	7.7	0.012

18	0.09	26	0.032	9.23	0.012
19	0.089	26.1	0.025	7.25	0.012
20	0.089	26.24	0.029	8.5	0.012
21	0.087	25.49	0.035	10.25	0.012
22	0.09	26.72	0.028	8.33	0.012
23	0.09	26.75	0.027	8.05	0.012
Average	0.088		0.03		0.012
Total		624.58		210.52	
30-Day Rlng	0.085		0.027		
365-Day Rlng				60664	

7/12/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	25.74	0.028	8.28	0.012
1	0.085	25.66	0.028	8.47	0.012
2	0.089	26.59	0.03	9.15	0.012
3	0.088	25.95	0.03	8.8	0.012
4	0.088	26.31	0.025	7.36	0.012
5	0.082	24.41	0.029	8.75	0.012
6	0.081	26.93	0.026	8.32	0.012
7	0.083	25.15	0.03	9.08	0.012
8	0.088	26.23	0.034	10.06	0.012
9	0.087	24.95	0.02	5.71	0.012
10	0.09	26.44	0.032	9.46	0.012
11	0.089	26.55	0.025	7.47	0.012
12	0.087	25.67	0.037	10.8	0.012
13	0.089	26.18	0.032	9.32	0.012
14	0.089	26.3	0.028	8.29	0.011
15	0.087	25.49	0.028	8.19	0.011
16	0.09	26.11	0.027	7.79	0.012
17	0.089	25.86	0.031	9.01	0.012
18	0.089	25.68	0.025	7.38	0.012
19	0.089	26.69	0.034	10.06	0.012
20	0.088	25.91	0.022	6.43	0.012
21	0.089	25.86	0.026	7.46	0.012
22	0.089	25.8	0.024	6.97	0.012
23	0.09	25.89	0.02	5.91	0.012
Average	0.088		0.028		0.012
Total		622.35		198.52	
30-Day Rlng	0.085		0.027		
365-Day Rlng				60670	

7/13/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	26.92	0.035	9.88	0.012
1	0.09	25.33	0.028	7.78	0.012
2	0.091	25.45	0.03	8.32	0.012
3	0.091	26.22	0.035	10.11	0.012
4	0.089	26.08	0.027	7.82	0.012

5	0.087	26	0.03	9.03	0.012
6	0.095	31.61	0.03	9.99 Cal	
7	0.092	26.51	0.023	6.49	0.012
8	0.083	24.07	0.031	8.92	0.012
9	0.089	26.32	0.022	6.53	0.012
10	0.081	24.38	0.027	8.16	0.012
11	0.092	26.99	0.028	8.08	0.012
12	0.087	25	0.032	9.2	0.012
13	0.09	26.72	0.027	8.09	0.012
14	0.09	26.16	0.026	7.56	0.012
15	0.088	25.69	0.025	7.36	0.012
16	0.088	26	0.028	8.29	0.012
17	0.088	25.85	0.029	8.45	0.012
18	0.089	26.25	0.032	9.44	0.012
19	0.091	26.14	0.031	8.95	0.012
20	0.089	25.75	0.03	8.71	0.012
21	0.09	25.8	0.029	8.21	0.012
22	0.091	26.05	0.031	8.97	0.012
23	0.091	26.44	0.032	9.19	0.012
Average	0.089		0.029		0.012
Total		627.73		203.53	
30-Day Rlng	0.085		0.027		
365-Day Rlng				60672	

7/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.07	0.027	7.76	0.012
1	0.089	25.22	0.029	8.23	0.012
2	0.092	26.45	0.03	8.69	0.012
3	0.089	25.99	0.03	8.9	0.012
4	0.09	26.1	0.032	9.19	0.012
5	0.088	26.69	0.026	7.94	0.012
6 Cal	Cal		0.044	14.8	0.011
7	0.09	25.39	0.024	6.64	0.012
8	0.091	25.96	0.028	7.91	0.012
9	0.091	26.01	0.024	6.99	0.012
10	0.09	25.97	0.03	8.48	0.012
11	0.091	26.19	0.039	11.35	0.012
12	0.089	25.22	0.027	7.54	0.012
13	0.092	26.13	0.03	8.38	0.012
14	0.09	26.71	0.031	9.26	0.012
15	0.086	24.99	0.028	8.1	0.012
16	0.091	26.47	0.029	8.38	0.012
17	0.092	26.51	0.028	8.1	0.012
18	0.091	25.68	0.03	8.36	0.012
19	0.092	25.96	0.03	8.44	0.012
20	0.092	26.15	0.026	7.42	0.012
21	0.092	25.96	0.028	7.86	0.014

	22	0.092	25.99	0.033	9.28	0.012
	23	0.088	25.91	0.03	8.86	0.012
Average		0.09		0.03		0.012
Total			597.72		206.86	
30-Day Rlng		0.085		0.027		
365-Day Rlng					60677	

7/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.36	0.034	9.91	0.012
1	0.089	25.49	0.024	6.83	0.012
2	0.091	26.33	0.033	9.39	0.012
3	0.094	26.83	0.03	8.74	0.012
4	0.094	26.84	0.032	9.14	0.012
5	0.09	26.23	0.027	7.99	0.012
6	0.083	24.72	0.024	7.3	0.012
7	0.087	25.86	0.03	8.82	0.012
8	0.092	27	0.029	8.56	0.012
9	0.085	24.97	0.028	8.15	0.012
10	0.088	25.35	0.029	8.37	0.012
11	0.089	26.56	0.022	6.62	0.012
12	0.09	26.58	0.033	9.68	0.012
13	0.084	24.84	0.026	7.67	0.012
14	0.092	26.69	0.018	5.18	0.012
15	0.088	25.94	0.031	9.15	0.012
16	0.088	26.25	0.03	8.99	0.012
17	0.089	25.8	0.029	8.33	0.012
18	0.089	25.79	0.025	7.18	0.012
19	0.091	26.09	0.033	9.41	0.012
20	0.09	25.94	0.023	6.62	0.012
21	0.09	25.66	0.028	7.92	0.012
22	0.09	26.09	0.028	8.09	0.012
23	0.091	26.65	0.033	9.83	0.012
Average	0.089		0.028		0.012
Total		624.86		197.87	
30-Day Rlng	0.086		0.027		
365-Day Rlng				60680	

7/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	25.3	0.03	8.74	0.012
1	0.094	24.43	0.021	5.59	0.013
2	0.091	26.61	0.029	8.38	0.012
3	0.092	26.31	0.03	8.46	0.012
4	0.09	25.8	0.029	8.47	0.012
5	0.092	27.11	0.027	7.96	0.012
6	0.092	28.44	0.028	8.62	0.012
7	0.087	26.03	0.029	8.79	0.012
8	0.082	24.58	0.029	8.67	0.012

9	0.087	26.38	0.033	10	0.012
10	0.084	26.52	0.028	8.87	0.012
11	0.082	26.27	0.027	8.54	0.012
12	0.081	26.12	0.032	10.38	0.012
13	0.082	25.09	0.031	9.37	0.012
14	0.084	26.34	0.031	9.64	0.012
15	0.081	25	0.027	8.5	0.012
16	0.083	26.1	0.031	9.71	0.012
17	0.082	25.7	0.024	7.67	0.012
18	0.084	25.52	0.026	7.84	0.012
19	0.083	24.42	0.033	9.76	0.012
20	0.088	25.87	0.034	10.12	0.012
21	0.087	24.98	0.031	8.94	0.012
22	0.09	26.17	0.023	6.73	0.012
23	0.087	24.92	0.034	9.7	0.013
Average	0.086		0.029		0.012
Total		620.01		209.45	
30-Day Rlng	0.086		0.027		
365-Day Rlng				60685	

7/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.18	0.028	7.98	0.012
1	0.091	26.23	0.026	7.42	0.012
2	0.092	26.18	0.026	7.39	0.012
3	0.09	25.45	0.027	7.66	0.012
4	0.082	21.1	0.019	4.95	0.013
5	0.081	22.43	0.014	4.02	0.013
6	0.088	26.96	0.029	8.8	0.012
7	0.086	26.31	0.018	5.38	0.012
8	0.081	24.41	0.025	7.57	0.012
9	0.089	26.1	0.025	7.35	0.012
10	0.09	26.36	0.03	8.73	0.012
11	0.088	26.68	0.031	9.5	0.012
12	0.081	24.46	0.028	8.62	0.012
13	0.087	25.87	0.027	7.99	0.012
14	0.085	25.65	0.032	9.7	0.012
15	0.09	26.88	0.018	5.28	0.012
16	0.085	25.82	0.028	8.54	0.012
17	0.085	26.22	0.026	8.19	0.012
18	0.086	25.51	0.031	9.15	0.012
19	0.087	26.31	0.027	8	0.012
20	0.086	25.69	0.033	9.92	0.012
21	0.088	25.23	0.032	9.31	0.012
22	0.09	26.18	0.025	7.29	0.012
23	0.088	25.55	0.034	9.96	0.012
Average	0.087		0.027		0.012
Total		612.76		188.7	

30-Day Rlng	0.086	0.027			
365-Day Rlng			60679		
7/18/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.59	0.033	9.21	0.012
1	0.089	25.63	0.037	10.67	0.012
2	0.088	25.24	0.028	8.16	0.012
3	0.086	25.28	0.027	7.96	0.012
4	0.085	25.5	0.028	8.34	0.012
5	0.084	26.31	0.025	7.78	0.012
6	0.084	25.88	0.022	6.71	0.012
7	0.084	26.43	0.029	9.22	0.012
8	0.084	26.01	0.031	9.51	0.012
9	0.087	25.95	0.024	7.07	0.012
10	0.085	25.74	0.029	8.6	0.012
11	0.087	24.43	0.029	7.96	0.014
12	0.088	26.06	0.018	5.33	0.012
13	0.085	25.93	0.025	7.51	0.012
14	0.085	25.86	0.024	7.18	0.012
15	0.086	25.8	0.023	6.82	0.012
16	0.088	26.31	0.027	8.01	0.012
17	0.085	25.7	0.025	7.49	0.012
18	0.088	25.89	0.034	9.98	0.012
19	0.085	25.62	0.023	6.9	0.012
20	0.086	25.57	0.03	9	0.012
21	0.089	25.74	0.023	6.7	0.012
22	0.089	25.75	0.032	9.12	0.012
23	0.087	25.69	0.028	8.13	0.012
Average	0.086		0.027		0.012
Total		617.91		193.36	
30-Day Rlng	0.086		0.027		
365-Day Rlng				60676	
7/19/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	25.14	0.028	8.17	0.012
1	0.09	26.21	0.027	7.96	0.012
2	0.088	25.8	0.028	8.35	0.012
3	0.088	25.58	0.031	8.98	0.012
4	0.087	25.02	0.028	7.94	0.012
5	0.089	26.7	0.041	12.38	0.012
6	0.084	25.7	0.026	8.08	0.012
7	0.086	25.84	0.022	6.51	0.012
8	0.089	26.72	0.021	6.34	0.012
9	0.088	26.09	0.025	7.32	0.012
10	0.089	26.09	0.026	7.62	0.012
11	0.088	26.73	0.023	6.9	0.012
12	0.083	24.81	0.026	7.71	0.012

13	0.09	26.32	0.026	7.54	0.012
14	0.089	26.34	0.028	8.21	0.012
15	0.082	23.71	0.024	6.92	0.012
16	0.091	26.84	0.028	8.31	0.012
17	0.088	25.71	0.024	6.91	0.012
18	0.089	25.86	0.031	8.98	0.012
19	0.089	25.98	0.027	7.88	0.012
20	0.09	26.26	0.025	7.27	0.012
21	0.091	25.95	0.026	7.48	0.012
22	0.088	25.66	0.027	7.81	0.012
23	0.089	25.68	0.03	8.62	0.012
Average	0.088		0.027		0.012
Total		620.74		190.19	
30-Day Rlng	0.086		0.027		
365-Day Rlng				60695	

7/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.15	0.031	8.89	0.012
1	0.092	26.24	0.024	6.76	0.012
2	0.091	25.93	0.026	7.37	0.012
3	0.09	25.55	0.02	5.55	0.012
4	0.088	25.66	0.026	7.59	0.012
5	0.089	26.69	0.024	7.2	0.012
6	0.091	27.01	0.028	8.28	0.012
7	0.086	25.17	0.022	6.49	0.012
8	0.088	25.67	0.018	5.17	0.012
9	0.09	25.87	0.03	8.55	0.012
10	0.09	26.37	0.025	7.24	0.012
11	0.087	26.11	0.024	7.24	0.012
12	0.09	26.07	0.028	8.18	0.012
13	0.089	25.28	0.027	7.58	0.012
14	0.092	25.82	0.026	7.35	0.012
15	0.087	25.08	0.024	7.03	0.012
16	0.092	26.31	0.021	6.11	0.012
17	0.088	25.24	0.022	6.19	0.012
18	0.094	26.58	0.022	6.16	0.012
19	0.096	26.54	0.02	5.57	0.012
20	0.092	25.16	0.029	7.85	0.012
21	0.095	25.67	0.027	7.4	0.012
22	0.095	26.42	0.027	7.58	0.012
23	0.093	26.7	0.027	7.81	0.012
Average	0.091		0.025		0.012
Total		622.29		171.14	
30-Day Rlng	0.086		0.027		
365-Day Rlng				60687	

7/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
------	--------------	---------	--------------	---------	-------------

0	0.093	26.05	0.031	8.62	0.012
1	0.092	25.54	0.028	7.72	0.012
2	0.093	26.09	0.027	7.6	0.012
3	0.094	26.13	0.026	7.3	0.012
4	0.093	27.09	0.034	9.74	0.012
5	0.085	25.76	0.021	6.42	0.012
6	0.084	25.91	0.02	6.15	0.012
7	0.085	26.17	0.023	7.09	0.012
8	0.083	25.55	0.026	7.9	0.012
9	0.088	26.52	0.024	7.33	0.012
10	0.087	26.43	0.019	5.91	0.012
11	0.086	25.68	0.025	7.62	0.012
12	0.088	26.09	0.021	6.22	0.012
13	0.086	26.19	0.02	5.96	0.012
14	0.086	25.99	0.027	8.21	0.012
15	0.088	25.38	0.017	4.9	0.012
16	0.087	26	0.026	7.93	0.012
17	0.086	25.98	0.027	8.21	0.012
18	0.09	26.62	0.018	5.4	0.012
19	0.088	25.89	0.026	7.56	0.012
20	0.088	26.02	0.026	7.6	0.012
21	0.088	25.34	0.026	7.59	0.012
22	0.088	26.32	0.025	7.38	0.012
23	0.087	26.23	0.027	8.02	0.012
Average	0.088		0.025		0.012
Total		624.97		174.38	
30-Day Rlng	0.086		0.027		
365-Day Rlng				60676	

7/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	25.69	0.027	8.01	0.012
1	0.086	26.15	0.025	7.64	0.012
2	0.088	26.77	0.026	7.99	0.012
3	0.083	25.04	0.022	6.6	0.012
4	0.083	26.28	0.027	8.37	0.012
5	0.083	26	0.023	7.14	0.012
6	0.085	26.57	0.021	6.46	0.012
7	0.085	26.55	0.026	8.04	0.012
8	0.086	26.33	0.031	9.65	0.012
9	0.084	25.71	0.023	6.9	0.012
10	0.086	26.66	0.02	6.32	0.012
11	0.085	25.91	0.029	8.83	0.012
12	0.083	24.94	0.03	9.08	0.012
13	0.088	26.22	0.027	8.09	0.012
14	0.09	26.54	0.031	9.1	0.012
15	0.088	25.48	0.02	5.78	0.012
16	0.089	26.35	0.03	8.85	0.012

17	0.086	26.06	0.024	7.07	0.012
18	0.087	25.76	0.029	8.57	0.012
19	0.088	26.19	0.029	8.65	0.012
20	0.089	25.96	0.026	7.62	0.012
21	0.089	25.65	0.029	8.42	0.012
22	0.093	26.84	0.025	7.18	0.012
23	0.089	26.2	0.026	7.59	0.012
Average	0.087		0.026		0.012
Total		625.85		187.95	
30-Day Rlng	0.086		0.027		
365-Day Rlng				60667	

7/23/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.27	0.031	8.97	0.012
1	0.088	25.48	0.029	8.32	0.012
2	0.092	26.47	0.031	8.9	0.012
3	0.09	25.27	0.029	8.01	0.012
4	0.089	26.13	0.029	8.35	0.012
5	0.093	27.36	0.033	9.77	0.012
6	0.081	23.94	0.017	4.92	0.012
7	0.088	25.97	0.029	8.63	0.012
8	0.088	26.28	0.029	8.63	0.012
9	0.088	26.47	0.027	8.18	0.012
10	0.087	26.58	0.028	8.54	0.012
11	0.084	25.93	0.024	7.36	0.012
12	0.088	26.1	0.026	7.88	0.012
13	0.088	25.88	0.024	7	0.012
14	0.089	26.69	0.026	7.9	0.012
15	0.087	25.3	0.029	8.41	0.012
16	0.09	26.22	0.021	6.18	0.012
17	0.085	26.06	0.028	8.43	0.012
18	0.087	25.75	0.028	8.25	0.012
19	0.087	26.34	0.032	9.7	0.012
20	0.089	26.07	0.031	9	0.012
21	0.089	25.77	0.03	8.64	0.012
22	0.089	25.7	0.026	7.46	0.012
23	0.091	26.65	0.025	7.43	0.012
Average	0.088		0.028		0.012
Total		623.68		194.86	
30-Day Rlng	0.086		0.027		
365-Day Rlng				60663	

7/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.68	0.029	8.32	0.012
1	0.086	25.82	0.021	6.25	0.012
2	0.088	25.89	0.026	7.6	0.012
3	0.089	26.16	0.033	9.69	0.012

4	0.089	26.52	0.028	8.32	0.012
5	0.089	26.05	0.032	9.3	0.012
6	0.085	25.55	0.02	5.93	0.012
7	0.085	25.78	0.026	7.74	0.012
8	0.086	26.2	0.025	7.73	0.012
9	0.085	25.9	0.029	8.84	0.012
10	0.086	26.35	0.026	8.02	0.012
11	0.082	25.53	0.025	7.61	0.012
12	0.084	25.64	0.028	8.5	0.012
13	0.086	26.37	0.023	7.18	0.012
14	0.087	26.49	0.032	9.79	0.012
15	0.085	25.6	0.021	6.17	0.012
16	0.086	26.51	0.027	8.3	0.012
17	0.086	25.77	0.031	9.28	0.012
18	0.087	25.97	0.031	9.29	0.012
19	0.088	26.67	0.016	4.86	0.012
20	0.09	27.01	0.027	8.22	0.012
21	0.089	25.35	0.024	6.98	0.012
22	0.086	25.25	0.028	8.25	0.012
23	0.091	26.92	0.031	9.14	0.012
Average	0.087		0.027		0.012
Total		624.98		191.31	
30-Day Rlng	0.087		0.027		
365-Day Rlng				60655	

7/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	24.37	0.023	6.39	0.013
1	0.088	25.73	0.015	4.29	0.012
2	0.087	25.77	0.015	4.41	0.012
3	0.088	25.97	0.016	4.88	0.012
4	0.088	26.19	0.034	10.02	0.012
5	0.09	26.99	0.031	9.41	0.012
6	0.084	25.95	0.028	8.62	0.012
7	0.082	25.58	0.021	6.39	0.012
8	0.084	26.15	0.026	8.02	0.012
9	0.082	25.91	0.03	9.32	0.012
10	0.087	26.24	0.024	7.32	0.012
11	0.085	25.54	0.031	9.49	0.012
12	0.088	26.43	0.025	7.37	0.012
13	0.087	25.99	0.032	9.51	0.012
14	0.087	26.28	0.033	9.87	0.012
15	0.09	25.98	0.031	8.82	0.012
16	0.089	26.5	0.029	8.53	0.012
17	0.085	26.23	0.03	9.32	0.012
18	0.084	25.78	0.028	8.67	0.012
19	0.082	25.5	0.017	5.22	0.012
20	0.089	26.49	0.024	7.14	0.012

21	0.091	25.89	0.03	8.61	0.012
22	0.089	26.1	0.026	7.46	0.012
23	0.091	26.08	0.036	10.19	0.012
Average	0.087		0.026		0.012
Total		623.64		189.27	
30-Day Rlng	0.087		0.027		
365-Day Rlng				60719	

7/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.53	0.02	5.67	0.012
1	0.093	26.73	0.034	9.62	0.012
2	0.09	26.03	0.031	9.09	0.012
3	0.09	25.66	0.033	9.41	0.012
4	0.092	26.91	0.031	9	0.012
5	0.091	27.4	0.029	8.68	0.012
6	0.086	26.53	0.026	7.9	0.012
7	0.088	25.9	0.029	8.56	0.012
8	0.086	25.77	0.029	8.49	0.012
9	0.088	26.48	0.031	9.28	0.012
10	0.086	25.65	0.036	10.74	0.012
11	0.087	26.25	0.031	9.32	0.012
12	0.085	25.08	0.031	9.31	0.012
13	0.086	26.23	0.032	9.66	0.012
14	0.087	26.59	0.036	11.03	0.012
15	0.085	25.2	0.03	8.75	0.012
16	0.087	26.35	0.033	9.89	0.012
17	0.086	26.19	0.03	9.17	0.012
18	0.084	25.13	0.022	6.54	0.012
19	0.085	26.11	0.014	4.3	0.012
20	0.086	25.97	0.02	5.94	0.012
21	0.088	26.25	0.034	10.14	0.012
22	0.089	26.5	0.022	6.66	0.012
23	0.087	25.51	0.03	8.78	0.012
Average	0.088		0.029		0.012
Total		625.95		205.93	
30-Day Rlng	0.087		0.027		
365-Day Rlng				60925	

7/27/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.84	0.029	8.47	0.012
1	0.089	26.43	0.024	7.17	0.012
2	0.088	25.82	0.031	8.98	0.012
3	0.091	26.24	0.034	9.69	0.012
4	0.091	26.54	0.036	10.38	0.012
5	0.091	27	0.033	9.91	0.012
6	0.083	25.1	0.025	7.38	0.012
7	0.085	25.27	0.031	9.22	0.012

8	0.086	25.71	0.033	9.63	0.012
9	0.086	25.76	0.031	9.15	0.012
10	0.087	26.45	0.033	10.01	0.012
11	0.079	24.07	0.027	8.13	0.012
12	0.089	26.71	0.031	9.29	0.012
13	0.084	25.44	0.025	7.62	0.012
14	0.088	26.32	0.03	9.06	0.012
15	0.085	25.62	0.023	7.04	0.012
16	0.085	25.43	0.027	8.18	0.012
17	0.089	26.43	0.031	9.38	0.012
18	0.09	25.99	0.023	6.6	0.012
19	0.088	26.01	0.027	7.97	0.012
20	0.09	25.48	0.028	7.9	0.012
21	0.093	27.12	0.023	6.56	0.012
22	0.088	25.5	0.031	8.85	0.012
23	0.091	25.98	0.028	7.88	0.012
Average	0.088		0.029		0.012
Total		622.26		204.45	
30-Day Rlng	0.087		0.027		
365-Day Rlng				61129	

7/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.43	0.03	8.92	0.012
1	0.086	24.83	0.032	9.2	0.012
2	0.093	26.84	0.031	8.97	0.012
3	0.088	25.17	0.03	8.67	0.012
4	0.092	26.53	0.029	8.42	0.012
5	0.091	26.82	0.027	7.85	0.012
6	0.084	25.8	0.02	6.27	0.012
7	0.088	26.18	0.033	9.71	0.012
8	0.084	23.55	0.031	8.69	0.012
9	0.093	26.27	0.03	8.54	0.014
10	0.088	26.43	0.038	11.33	0.012
11	0.085	25.86	0.034	10.34	0.012
12	0.089	26.09	0.016	4.82	0.012
13	0.086	25.48	0.029	8.53	0.012
14	0.086	25.58	0.028	8.41	0.012
15	0.088	26.24	0.025	7.48	0.012
16	0.088	26.51	0.028	8.34	0.012
17	0.086	25.38	0.026	7.75	0.012
18	0.087	25.58	0.029	8.47	0.012
19	0.088	26.43	0.028	8.33	0.012
20	0.089	26.22	0.029	8.71	0.012
21	0.088	25.99	0.019	5.66	0.012
22	0.089	26.24	0.026	7.52	0.012
23	0.09	25.86	0.03	8.57	0.012
Average	0.088		0.028		0.012

Total		622.31	199.5
30-Day Rlng	0.087	0.027	
365-Day Rlng			61329

7/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	25.14	0.038	11.08	0.012
1	0.095	25.17	0.03	7.84	0.013
2	0.09	25.88	0.027	7.69	0.012
3	0.091	26.57	0.029	8.56	0.012
4	0.091	26.81	0.027	7.86	0.012
5	0.089	26.38	0.029	8.48	0.012
6	0.086	25.58	0.024	7.29	0.012
7	0.088	26.26	0.028	8.49	0.012
8	0.086	26.08	0.029	8.82	0.012
9	0.086	26.43	0.03	9.25	0.012
10	0.082	24.67	0.018	5.57	0.012
11	0.09	27	0.027	8.17	0.012
12	0.087	26.14	0.033	9.85	0.012
13	0.085	25.51	0.021	6.18	0.012
14	0.086	25.82	0.03	8.96	0.012
15	0.09	26.99	0.029	8.82	0.012
16	0.087	25.65	0.021	6.25	0.012
17	0.089	26.33	0.03	8.88	0.012
18	0.088	25.51	0.028	8.2	0.012
19	0.09	26.39	0.029	8.58	0.012
20	0.088	26.16	0.031	9.23	0.012
21	0.088	25.5	0.027	7.87	0.012
22	0.092	26.11	0.029	8.24	0.012
23	0.092	26.3	0.022	6.38	0.012
Average	0.088		0.028		0.012
Total		624.38		196.54	
30-Day Rlng	0.087		0.027		
365-Day Rlng				61386	

7/30/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.67	0.03	8.56	0.012
1	0.084	19.11	0.019	4.42	0.016
2	0.096	20.11	0.017	3.78	0.014
3	0.119	24.44	0.038	7.87	0.014
4	0.125	25.95	0.045	9.37	0.014
5	0.118	25.84	0.027	5.86	0.014
6	0.112	24.92	0.026	5.66	0.014
7	0.118	25.78	0.027	5.96	0.014
8	0.116	25.27	0.02	4.28	0.014
9	0.12	26.01	0.039	8.38	0.014
10	0.118	25.88	0.033	7.33	0.014
11	0.117	26.42	0.04	9.06	0.014

12	0.113	25.36	0.02	4.39	0.014
13	0.115	26.37	0.043	9.79	0.013
14	0.113	25.43	0.022	5.07	0.013
15	0.11	25.06	0.032	7.22	0.013
16	0.114	26.36	0.04	9.34	0.013
17	0.114	25.97	0.036	8.2	0.013
18	0.112	25.57	0.025	5.59	0.013
19	0.12	27.02	0.029	6.5	0.013
20	0.118	24.9	0.026	5.57	0.013
21	0.115	24.14	0.035	7.29	0.014
22	0.104	22.02	0.04	8.54	0.014
23	0.103	21.91	0.027	5.8	0.014
Average	0.112		0.031		0.014
Total		595.51		163.83	
30-Day Rlng	0.088		0.027		
365-Day Rlng				61353	

7/31/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.105	22.47	0.031	6.53	0.014
1	0.102	21.92	0.031	6.64	0.013
2	0.103	21.86	0.031	6.61	0.013
3	0.105	22.17	0.026	5.52	0.014
4	0.105	21.93	0.03	6.26	0.014
5	0.108	24.14	0.034	7.66	0.013
6 OOC	OOC		0.052	12 OOC	
7 Cal	Cal		0.037	10 Cal	
8	0.094	21.83	0.022	5.11	0.014
9	0.096	21.26	0.028	6.16	0.014
10	0.1	22.13	0.031	6.82	0.014
11	0.099	22.21	0.026	5.83	0.014
12	0.097	21.92	0.034	7.62	0.014
13	0.096	22.05	0.021	4.81	0.014
14	0.098	22.37	0.032	7.31	0.014
15	0.094	21.47	0.024	5.35	0.013
16	0.098	22.24	0.034	7.79	0.013
17	0.097	21.96	0.028	6.33	0.013
18	0.099	21.91	0.028	6.22	0.013
19	0.1	22.01	0.028	6.18	0.014
20	0.104	22.53	0.033	7.18	0.014
21	0.104	21.87	0.022	4.6	0.014
22	0.105	22.54	0.03	6.48	0.014
23	0.101	20.86	0.029	6.04	0.014
Average	0.1		0.03		0.014
Total		485.65		161.05	
30-Day Rlng	0.089		0.028		
365-Day Rlng				61308	

8/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.106	22.42	0.037	7.83	0.014
1	0.106	22.51	0.033	7.04	0.014
2	0.103	21.85	0.033	7.13	0.014
3	0.104	22.04	0.034	7.14	0.014
4	0.105	22.73	0.036	7.78	0.014
5	0.099	22.6	0.029	6.7	0.014
6 Cal	Cal	Cal	Cal	Cal	
7	0.089	27.88	0.016	5.05	0.012
8	0.072	22.25	0.02	6.3	0.012
9	0.072	21.54	0.02	5.89	0.012
10	0.073	22.23	0.02	6.22	0.012
11	0.07	21.65	0.019	6.02	0.012
12	0.075	22.68	0.026	7.9	0.012
13	0.073	22.47	0.021	6.39	0.012
14	0.07	21.82	0.02	6.34	0.012
15	0.072	22	0.023	7.11	0.012
16	0.074	23.22	0.021	6.73	0.012
17	0.08	24.82	0.025	7.56	0.012
18	0.087	27.05	0.025	7.81	0.012
19	0.084	25.88	0.029	8.9	0.012
20	0.083	25.75	0.026	8.26	0.012
21	0.086	26.1	0.031	9.56	0.012
22	0.082	25.66	0.031	9.77	0.012
23	0.093	26.88	0.025	7.22	0.012
Average	0.085		0.026		0.013
Total		544.03		166.65	
30-Day Rng	0.089		0.027		
365-Day Rng				61272	

8/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.082	24.04	0.03	8.67	0.012
1	0.087	26.27	0.034	10.32	0.012
2	0.086	26.54	0.024	7.26	0.012
3	0.083	25.23	0.031	9.4	0.012
4	0.088	27.29	0.028	8.74	0.012
5	0.079	24.96	0.023	7.38	0.012
6	0.083	28.23	0.029	10.11 Cal	
7	0.078	26.26	0.017	5.87	0.012
8	0.081	26.01	0.028	8.99	0.012
9	0.083	24.97	0.036	10.84	0.012
10	0.087	26.54	0.02	6.05	0.012
11	0.084	25.54	0.027	8.07	0.012
12	0.086	25.91	0.026	7.79	0.012
13	0.087	26.21	0.028	8.32	0.012
14	0.086	25.34	0.019	5.65	0.012
15	0.091	25.93	0.022	6.22	0.012

16	0.088	26.22	0.026	7.88	0.012
17	0.089	26.4	0.033	9.84	0.012
18	0.085	24.8	0.018	5.32	0.012
19	0.092	26.91	0.032	9.39	0.012
20	0.087	25.61	0.022	6.39	0.012
21	0.095	27.86	0.036	10.36	0.012
22	0.085	24.89	0.027	7.96	0.012
23	0.09	26.27	0.035	10.17	0.012
Average	0.086		0.027		0.012
Total		624.23		196.99	
30-Day Rlng	0.089		0.027		
365-Day Rlng				61266	

8/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.99	0.029	8.33	0.012
1	0.088	25.56	0.034	9.97	0.012
2	0.09	26.17	0.031	9.01	0.012
3	0.087	25.88	0.028	8.43	0.012
4	0.087	25.94	0.026	7.7	0.012
5	0.089	26.72	0.031	9.36	0.012
6	0.084	25.36	0.024	7.19	0.012
7	0.082	23.54	0.014	4.13	0.013
8	0.087	26.29	0.027	8.35	0.012
9	0.086	25.57	0.032	9.43	0.012
10	0.086	25.42	0.026	7.49	0.012
11	0.089	26.28	0.039	11.46	0.012
12	0.09	25.85	0.038	10.96	0.012
13	0.088	25.51	0.028	7.92	0.012
14	0.088	25.85	0.022	6.32	0.012
15	0.092	26.29	0.015	4.38	0.012
16	0.092	26.4	0.029	8.34	0.012
17	0.087	25.38	0.019	5.62	0.012
18	0.089	25.35	0.032	9.05	0.012
19	0.089	26	0.035	10.26	0.012
20	0.091	25.7	0.026	7.25	0.012
21	0.09	25.51	0.022	6.15	0.012
22	0.092	26.65	0.023	6.52	0.012
23	0.091	25.19	0.036	10.1	0.012
Average	0.089		0.028		0.012
Total		618.4		193.72	
30-Day Rlng	0.089		0.027		
365-Day Rlng				61256	

8/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	25.74	0.035	9.59	0.012
1	0.091	26.37	0.036	10.26	0.012
2	0.089	26.72	0.032	9.54	0.012

3	0.088	25.45	0.038	10.86	0.012
4	0.091	26.59	0.018	5.23	0.012
5	0.087	26.08	0.026	7.7	0.012
6	0.078	25.45	Cal	Cal	Cal
7	0.051	22.33	OOC	OOC	0.009
8 Maint	Maint	Maint	Maint	Maint	Maint
9	0.07	23.22	0.018	6.04	0.012
10	0.077	24.26	0.032	10	0.012
11	0.082	25.5	0.02	6.23	0.012
12	0.086	25.71	0.036	10.89	0.012
13	0.086	26.75	0.03	9.26	0.012
14	0.085	26.1	0.024	7.44	0.012
15	0.087	26.18	0.026	7.79	0.012
16	0.088	26.8	0.033	9.93	0.014
17	0.088	25.86	0.021	6.32	0.022
18	0.088	25.82	0.032	9.37	0.03
19	0.089	25.93	0.032	9.32	0.036
20	0.089	25.82	0.029	8.32	0.043
21	0.088	25.12	0.026	7.43	0.048
22	0.088	25.7	0.03	8.69	0.052
23	0.085	27.26	0.031	10.3	0.041
Average	0.085		0.029		0.021
Total		590.76		180.51	
30-Day Rlng	0.089		0.028		
365-Day Rlng				61234	

8/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	23.74	0.017	4.57	0.012
1	0.091	25.91	0.032	9.09	0.012
2	0.091	25.82	0.041	11.66	0.012
3	0.095	26.51	0.04	11.11	0.012
4	0.09	25.23	0.025	7.13	0.013
5	0.094	27.91	0.015	4.31	0.013
6	0.079	23.8	0.021	6.32	0.013
7	0.083	25.78	0.028	8.76	0.013
8	0.086	26.42	0.029	8.76	0.013
9	0.085	25.12	0.021	6.38	0.013
10	0.087	26.31	0.02	5.99	0.013
11	0.085	25.29	0.024	7.25	0.013
12	0.09	25.83	0.03	8.43	0.013
13	0.089	27.57	0.027	8.3	0.013
14	0.085	25.54	0.021	6.29	0.013
15	0.093	27.12	0.037	10.83	0.013
16	0.087	25.84	0.032	9.43	0.013
17	0.09	26.61	0.031	9.15	0.012
18	0.089	25.77	0.025	7.13	0.012
19	0.087	25.32	0.023	6.72	0.012

20	0.091	26.49	0.033	9.65	0.012
21	0.088	25.09	0.017	4.84	0.012
22	0.092	26.59	0.028	8.13	0.012
23	0.086	24.76	0.03	8.62	0.012
Average	0.088		0.027		0.013
Total		620.37		188.85	
30-Day Rlng	0.089		0.028		
365-Day Rlng				61215	
8/6/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.07	0.035	9.88	0.013
1	0.093	26.12	0.023	6.46	0.013
2	0.094	27.51	0.02	5.78	0.012
3	0.087	25.22	0.021	6.15	0.012
4	0.089	26.4	0.024	7.12	0.012
5	0.088	27.24	0.025	7.58	0.013
6	0.082	25.08	0.022	6.89	0.013
7	0.089	26.1	0.024	6.94	0.013
8	0.089	26.56	0.014	4.31	0.013
9	0.086	24.91	0.023	6.44	0.013
10	0.096	27.19	0.036	10.12	0.013
11	0.089	26.12	0.024	7.01	0.012
12	0.089	25.11	0.033	9.23	0.013
13	0.089	26.12	0.026	7.58	0.013
14	0.089	26.49	0.031	9.31	0.013
15	0.088	25.05	0.031	8.86	0.013
16	0.092	27.06	0.035	10.19	0.013
17	0.088	25.45	0.031	8.92	0.013
18	0.093	26.16	0.02	5.72	0.013
19	0.091	25.59	0.029	8.07	0.013
20	0.097	26.91	0.034	9.43	0.012
21	0.096	25.57	0.034	8.98	0.012
22	0.095	25.69	0.023	6.26	0.012
23	0.096	26.51	0.029	7.98	0.012
Average	0.091		0.027		0.013
Total		625.23		185.21	
30-Day Rlng	0.089		0.028		
365-Day Rlng				61200	

8/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	24.82	0.018	4.91	0.012
1	0.094	26.51	0.033	9.39	0.012
2	0.091	25.71	0.023	6.42	0.012
3	0.09	25.32	0.034	9.55	0.012
4	0.092	26.45	0.032	9.07	0.012
5	0.093	26.93	0.034	10.01	0.012
6	0.087	27.26	0.024	7.43	0.012

7	0.09	26.28	0.028	8.15	0.012
8	0.09	25.82	0.034	9.75	0.012
9	0.094	25.56	0.032	8.74	0.012
10	0.092	25.58	0.038	10.41	0.012
11	0.095	25.91	0.024	6.46	0.013
12	0.096	26.55	0.024	6.55	0.013
13	0.089	26.04	0.029	8.51	0.012
14	0.093	26.39	0.031	8.76	0.012
15	0.093	25.38	0.023	6.29	0.012
16	0.094	26.51	0.03	8.51	0.012
17	0.092	25.69	0.034	9.47	0.012
18	0.093	25.23	0.028	7.62	0.012
19	0.093	25.73	0.017	4.72	0.012
20	0.094	25.87	0.016	4.29	0.012
21	0.099	27.15	0.037	10.17	0.012
22	0.092	24.74	0.015	4.04	0.012
23	0.095	25.75	0.035	9.4	0.012
Average	0.093		0.028		0.012
Total		623.18		188.62	
30-Day Rlng	0.089		0.028		
365-Day Rlng				61191	

8/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	25.6	0.029	7.76	0.012
1	0.095	25.66	0.027	7.44	0.012
2	0.1	26.73	0.03	8.11	0.012
3	0.095	25.62	0.026	6.87	0.012
4	0.098	26.2	0.027	7.31	0.012
5	0.107	30.03	0.023	6.6	0.014
6	0.064	19.14	0.023	7.04	0.012
7	0.101	26.29	0.029	7.45	0.012
8	0.097	25.48	0.024	6.25	0.012
9	0.101	26.66	0.03	8	0.012
10	0.096	25.41	0.027	7.24	0.012
11	0.096	26.41	0.021	5.8	0.012
12	0.095	25.26	0.034	9.15	0.012
13	0.097	26.2	0.036	9.63	0.012
14	0.095	26.09	0.027	7.53	0.012
15	0.095	25.43	0.025	6.68	0.012
16	0.099	26.62	0.037	10.02	0.012
17	0.092	25.13	0.034	9.36	0.012
18	0.098	26.5	0.034	9.19	0.012
19	0.093	25.14	0.02	5.34	0.012
20	0.098	26.63	0.026	7	0.012
21	0.096	25.56	0.021	5.71	0.012
22	0.096	25.92	0.021	5.63	0.012
23	0.097	26.05	0.021	5.69	0.012

Average	0.096	0.027	0.012
Total	619.76	176.8	
30-Day Rlng	0.089	0.028	
365-Day Rlng		61174	

8/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	25.34	0.014	3.78	0.012
1	0.097	26.17	0.031	8.48	0.012
2	0.1	26.8	0.031	8.39	0.012
3	0.096	25.89	0.026	7.1	0.012
4	0.093	25.32	0.034	9.24	0.012
5	0.096	27.02	0.039	10.89	0.012
6	0.083	25.21	0.016	4.8	0.012
7	0.088	24.82	0.026	7.39	0.012
8	0.095	26.56	0.038	10.57	0.012
9	0.094	26.19	0.023	6.24	0.012
10	0.092	25.27	0.035	9.58	0.012
11	0.091	25.66	0.03	8.35	0.012
12	0.092	26.02	0.028	7.93	0.012
13	0.088	25.46	0.026	7.31	0.012
14	0.094	26.33	0.031	8.71	0.012
15	0.092	25.25	0.023	6.39	0.012
16	0.092	25.56	0.031	8.59	0.012
17	0.094	26.78	0.028	7.9	0.012
18	0.087	24.41	0.027	7.6	0.012
19	0.09	26.92	0.027	7.95	0.012
20	0.088	25.8	0.031	9.07	0.012
21	0.089	25.31	0.027	7.53	0.012
22	0.091	26.44	0.037	10.84	0.012
23	0.089	25.66	0.028	8.11	0.012
Average	0.092		0.029		0.012
Total		620.19		192.74	
30-Day Rlng	0.09		0.028		
365-Day Rlng				61173	

8/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.07	0.034	9.58	0.012
1	0.091	26.07	0.032	9.22	0.012
2	0.093	26.59	0.038	10.71	0.012
3	0.09	24.9	0.03	8.25	0.012
4	0.095	26.98	0.023	6.62	0.012
5	0.089	25.87	0.023	6.63	0.012
6	0.075	22.69	0.023	7.35	0.012
7	0.096	26.36	0.02	5.64	0.012
8	0.091	25.14	0.031	8.53	0.012
9	0.096	26.76	0.022	6.04	0.012
10	0.09	25.69	0.03	8.54	0.012

11	0.091	25.61	0.024	6.75	0.012
12	0.09	25.15	0.025	6.87	0.012
13	0.095	26.7	0.022	6.25	0.012
14	0.093	26.15	0.038	10.6	0.012
15	0.094	25.67	0.03	8.16	0.012
16	0.094	25.99	0.037	10.23	0.012
17	0.092	25.67	0.032	8.87	0.012
18	0.096	26.99	0.029	7.98	0.012
19	0.089	25.3	0.032	9.08	0.012
20	0.093	26.67	0.037	10.59	0.012
21	0.093	24.14	0.024	6.25	0.013
22	0.094	25.82	0.029	8	0.012
23	0.094	26.08	0.034	9.52	0.012
Average			0.029		0.012
Total		618.06		196.26	
30-Day Rlng	0.09		0.028		
365-Day Rlng				61169	

8/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	25.56	0.036	9.84	0.012
1	0.095	26.28	0.03	8.42	0.012
2	0.094	25.93	0.025	6.94	0.012
3	0.095	26.43	0.037	10.2	0.012
4	0.091	25.51	0.035	9.79	0.012
5	0.093	26.95	0.03	8.67	0.012
6	0.081	26.34	0.018	5.62	0.012
7	0.087	22.07	0.02	5.17	0.012
8	0.096	26.22	0.027	7.28	0.012
9	0.092	26.19	0.03	8.59	0.012
10	0.087	25.41	0.033	9.79	0.012
11	0.089	26.78	0.036	10.73	0.012
12	0.086	25.28	0.035	10.33	0.012
13	0.088	26.25	0.032	9.47	0.012
14	0.088	25.99	0.028	8.24	0.012
15	0.09	26.48	0.02	5.78	0.012
16	0.085	25.27	0.026	7.82	0.012
17	0.087	26	0.035	10.46	0.012
18	0.091	26.95	0.026	7.73	0.012
19	0.088	26.13	0.027	7.93	0.012
20	0.089	25.91	0.035	10.15	0.012
21	0.088	24.81	0.031	8.65	0.012
22	0.093	26.87	0.037	10.53	0.012
23	0.088	26.05	0.02	5.87	0.012
Average	0.09		0.03		0.012
Total		621.66		204	
30-Day Rlng	0.09		0.028		
365-Day Rlng				61166	

8/12/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.9	0.029	8.22	0.012
1	0.087	26.07	0.03	9.04	0.012
2	0.086	26.24	0.029	8.75	0.012
3	0.088	26.02	0.024	7.19	0.012
4	0.085	25.57	0.027	8.12	0.012
5	0.09	26.12	0.028	8.04	0.012
6	0.091	28.36	0.015	4.24	0.012
7	0.094	25.93	0.024	6.58	0.012
8	0.094	26.12	0.037	10.32	0.012
9	0.095	27.48	0.038	11.05	0.012
10	0.085	24.9	0.021	5.94	0.012
11	0.086	25.8	0.032	9.62	0.012
12	0.089	26.12	0.037	10.93	0.012
13	0.086	26.06	0.022	6.67	0.012
14	0.088	26.36	0.025	7.6	0.012
15	0.086	25.51	0.025	7.42	0.012
16	0.087	25.85	0.03	9.06	0.012
17	0.085	26.18	0.029	8.8	0.012
18	0.082	23.73	0.035	9.96	0.012
19	0.107	28.56	0.02	5.3	0.012
20	0.124	34.32	0.015	4.1	0.012
21	0.087	24.47	0.026	7.25	0.012
22	0.059	17.03	0.029	8.3	0.012
23	0.086	24.77	0.031	9.08	0.012
Average	0.089		0.027		0.012
Total		623.47		191.58	
30-Day Rlng	0.09		0.028		
365-Day Rlng				61163	

8/13/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.4	0.031	8.87	0.012
1	0.091	26.17	0.025	7.15	0.012
2	0.091	26.83	0.027	7.97	0.012
3	0.085	24.9	0.032	9.39	0.012
4	0.092	26.33	0.035	10.15	0.012
5	0.087	24.33	0.033	9.27	0.012
6	0.083	25.14	0.019	5.69	0.012
7	0.08	23.8	0.024	7.11	0.012
8	0.09	26.1	0.028	8.09	0.012
9	0.09	25.98	0.031	8.93	0.012
10	0.091	26.53	0.028	8.32	0.012
11	0.088	26.4	0.025	7.48	0.012
12	0.088	25.16	0.024	6.98	0.012
13	0.086	25.11	0.026	7.58	0.012
14	0.089	25.49	0.021	6.06	0.012

15	0.091	25.3	0.029	7.92	0.012
16	0.092	26.66	0.026	7.63	0.012
17	0.088	25.59	0.028	8.12	0.012
18	0.09	26.49	0.025	7.33	0.012
19	0.087	25.53	0.018	5.18	0.012
20	0.089	26.03	0.027	8.02	0.012
21	0.091	25.33	0.026	7.29	0.012
22	0.093	26.31	0.03	8.57	0.012
23	0.092	26.12	0.033	9.22	0.012
Average	0.089		0.027		0.012
Total		617.03		188.32	
30-Day Rlng	0.09		0.028		
365-Day Rlng				61149	

8/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	26.52	0.04	11.38	0.012
1	0.089	25.88	0.029	8.5	0.012
2	0.088	26.27	0.034	10.02	0.012
3	0.089	25.82	0.028	8.08	0.012
4	0.088	25.4	0.022	6.41	0.012
5	0.088	26.04	0.031	9.26	0.012
6	0.088	26.04	0.024	7.18	0.012
7	0.087	26	0.03	8.79	0.012
8	0.092	26.64	0.033	9.6	0.012
9	0.088	25.49	0.033	9.58	0.012
10	0.087	26.47	0.026	7.94	0.012
11	0.085	25.39	0.031	9.22	0.012
12	0.089	25.64	0.031	8.87	0.012
13	0.089	26.34	0.029	8.71	0.012
14	0.089	26.13	0.036	10.79	0.012
15	0.089	25.33	0.027	7.83	0.012
16	0.09	26.13	0.019	5.52	0.012
17	0.083	21.61	0.015	3.87	0.013
18	0.101	25.89	0.014	3.71	0.013
19	0.1	25.73	0.014	3.74	0.013
20	0.096	26.37	0.019	5.27	0.012
21	0.095	26.4	0.024	6.8	0.012
22	0.091	25.85	0.026	7.4	0.012
23	0.091	25.7	0.025	7.14	0.012
Average	0.09		0.027		0.012
Total		619.08		185.61	
30-Day Rlng	0.09		0.028		
365-Day Rlng				61130	

8/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	26.05	0.02	5.6	0.012
1	0.093	25.61	0.03	8.33	0.012

2	0.091	26.93	0.035	10.42	0.012
3	0.089	26.86	0.032	9.49	0.012
4	0.084	25.34	0.014	4.26	0.012
5	0.087	26.11	0.028	8.52	0.012
6	0.081	25.04	0.025	7.84	0.012
7	0.085	26.77	0.025	7.76	0.012
8	0.081	25.06	0.032	9.82	0.012
9	0.084	25.63	0.024	7.42	0.012
10	0.084	25.84	0.028	8.53	0.012
11	0.087	24.42	0.031	8.56	0.012
12	0.099	25.72	0.028	7.15	0.012
13	0.093	25.61	0.027	7.53	0.012
14	0.094	25.89	0.031	8.59	0.012
15	0.095	26.31	0.028	7.67	0.012
16	0.085	25.69	0.029	8.87	0.012
17	0.088	26.86	0.033	9.96	0.012
18	0.087	26.39	0.022	6.69	0.011
19	0.082	24.78	0.018	5.47	0.012
20	0.09	26.3	0.015	4.51	0.012
21	0.09	25.96	0.013	3.88	0.012
22	0.088	25.73	0.019	5.62	0.012
23	0.091	26.26	0.024	6.86	0.012
Average	0.088		0.025		0.012
Total		621.16		179.35	
30-Day Rlng	0.09		0.027		
365-Day Rlng				61098	

8/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.69	0.024	6.8	0.012
1	0.093	26.85	0.028	8.25	0.012
2	0.089	25.63	0.026	7.58	0.012
3	0.091	25.62	0.03	8.47	0.012
4	0.09	25.91	0.031	8.78	0.012
5	0.091	26.39	0.035	10.21	0.012
6	0.086	25.6	0.027	7.9	0.012
7	0.086	25.52	0.028	8.22	0.012
8	0.088	25.73	0.033	9.63	0.012
9	0.09	25.93	0.029	8.43	0.012
10	0.09	26.08	0.033	9.44	0.012
11	0.089	25.76	0.025	7.13	0.012
12	0.092	26.36	0.032	9.12	0.012
13	0.09	26.16	0.032	9.27	0.012
14	0.09	25.99	0.026	7.59	0.012
15	0.092	25.82	0.031	8.55	0.012
16	0.087	26.36	0.021	6.32	0.012
17	0.084	25.78	0.025	7.71	0.012
18	0.087	26.37	0.032	9.61	0.012

19	0.085	26.27	0.019	5.96	0.012
20	0.087	25.92	0.026	7.91	0.012
21	0.092	25.99	0.023	6.53	0.012
22	0.087	24.86	0.037	10.5	0.012
23	0.095	27.31	0.032	9.07	0.012
Average	0.089		0.029		0.012
Total		623.9		198.98	
30-Day Rlng	0.09		0.028		
365-Day Rlng				61069	

8/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.45	0.03	8.51	0.012
1	0.087	24.65	0.014	3.95	0.012
2	0.091	26	0.028	7.92	0.012
3	0.093	25.34	0.038	10.34	0.012
4	0.093	26.22	0.014	3.87	0.012
5	0.092	26.4	0.018	5.12	0.012
6	0.073	17.62	0.023	5.63	0.013
7	0.022	4.84	0.015	3.36	0.013
8	0.072	19.64	0.027	7.2	0.012
9	0.092	26.49	0.036	10.44	0.012
10	0.081	22.73	0.02	5.57	0.012
11	0.097	26.57	0.031	8.65	0.012
12	0.082	21.89	0.025	6.79	0.012
13	0.066	17.35	0.021	5.41	0.014
14	0.09	25.56	0.028	7.82	0.012
15	0.096	26.93	0.03	8.37	0.012
16	0.085	24.61	0.026	7.4	0.012
17	0.088	25.38	0.031	8.9	0.012
18	0.087	20.39	0.022	5.21	0.014
19	0.083	9.34	0.024	2.96	0.021
20	0.045	5.89	0.019	2.51	0.017
21	0.083	10.76	0.024	3.11	0.021
22	0.027	5.24	0.016	3.18	0.014
23	0.022	4.56	0.015	3.17	0.013
Average	0.077		0.024		0.013
Total		469.85		145.39	
30-Day Rlng	0.09		0.027		
365-Day Rlng				60999	

8/18/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.07	14.48	0.015	3.09	0.013
1	0.036	7.61	0.021	4.48	0.013
2	0.082	19.93	0.028	6.89	0.012
3	0.106	27.14	0.038	9.72	0.012
4	0.092	21.18	0.016	3.72 OOC	
5	0.082	22.55	0.03	8.1	0.012

6	0.094	26.17	0.033	9.16	0.012
7	0.091	25.93	0.031	8.87	0.012
8	0.082	22.48	0.018	4.84	0.012
9	0.069	18.76	0.025	6.86	0.012
10	0.092	25.84	0.031	8.71	0.012
11	0.093	26.31	0.031	8.9	0.012
12	0.092	25.89	0.032	8.93	0.012
13	0.068	19.09	0.017	4.86	0.014
14	0.092	26.45	0.025	6.99	0.012
15	0.097	25.43	0.03	7.8	0.012
16	0.09	23.96	0.028	7.53	0.012
17	0.057	13.44	0.031	7.55	0.014
18	0.093	25.53	0.03	8.22	0.012
19	0.094	26.57	0.036	10.23	0.012
20	0.092	26.24	0.027	7.66	0.012
21	0.09	25.54	0.03	8.56	0.012
22	0.092	25.94	0.025	7.02	0.012
23	0.089	25.78	0.029	8.3	0.012
Average	0.085		0.027		0.012
Total		548.24		176.99	
30-Day Rlng	0.089		0.027		
365-Day Rlng				60960	

8/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.62	0.037	10.34	0.012
1	0.092	27.06	0.035	10.31	0.012
2	0.09	26.27	0.03	8.74	0.012
3	0.09	25.82	0.019	5.59	0.012
4	0.101	24.6	0.021	5.18	0.013
5	0.109	26.8	0.037	9.16	0.013
6	0.106	24.55	0.049	11.35	0.013
7	0.107	25.97	0.032	7.8	0.013
8	0.109	26.17	0.033	7.97	0.013
9	0.099	24.39	0.034	8.27	0.013
10	0.101	25.63	0.025	6.32	0.013
11	0.109	26.4	0.031	7.55	0.013
12	0.104	24.74	0.036	8.48	0.013
13	0.107	26.19	0.048	11.61	0.013
14	0.106	25.61	0.03	7.32	0.013
15	0.107	25.25	0.029	6.98	0.013
16	0.108	26.41	0.041	10.03	0.013
17	0.106	25.32	0.03	7.07	0.013
18	0.112	26.53	0.039	9.15	0.013
19	0.105	25.21	0.031	7.48	0.013
20	0.107	25.71	0.032	7.77	0.013
21	0.109	25.82	0.03	7.18	0.013
22	0.107	25.38	0.039	9.34	0.013

	23	0.111	26.01	0.028	6.58	0.013
Average		0.104		0.033		0.013
Total			617.46		197.57	
30-Day Rlng		0.09		0.028		
365-Day Rlng					60958	

8/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.11	25.8	0.042	9.74	0.013
1	0.111	26.61	0.032	7.74	0.013
2	0.109	26.02	0.037	8.68	0.013
3	0.107	26.02	0.037	8.94	0.013
4 OOC		28.23 OOC		7.53 OOC	
5	0.067	21.66	0.019	5.95	0.012
6	0.091	27.01	0.039	11.43	0.012
7	0.082	25.19	0.026	7.89	0.012
8	0.084	25.61	0.032	9.85	0.012
9	0.087	25.35	0.025	7.23	0.012
10	0.093	26.85	0.034	9.72	0.012
11	0.089	26.04	0.029	8.48	0.012
12	0.088	25.22	0.026	7.36	0.012
13	0.091	27.32	0.03	9.19	0.012
14	0.094	28.41	0.034	10.19	0.012
15	0.092	26.28	0.031	8.81	0.012
16	0.087	25.06	0.027	7.8	0.012
17	0.091	25.66	0.026	7.42	0.012
18	0.091	25.85	0.035	9.87	0.012
19	0.092	26.22	0.025	7.17	0.012
20	0.09	26.44	0.03	9.02	0.012
21	0.089	26.26	0.029	8.56	0.012
22	0.086	25.42	0.029	8.36	0.012
23	0.088	25.57	0.026	7.64	0.014
Average	0.092		0.03		0.012
Total		624.1		204.57	
30-Day Rlng		0.09	0.028		
365-Day Rlng				60959	

8/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.18	0.032	9.03	0.017
1	0.093	27.42	0.03	8.89	0.017
2	0.088	25.4	0.029	8.47	0.016
3	0.091	26.27	0.032	9.02	0.014
4 OOC	OOC	OOC	OOC	OOC	
5 OOC	OOC	OOC	OOC	OOC	
6	0.081	23.15	0.022	6.14	0.012
7	0.09	27.12	0.029	8.58	0.012
8	0.09	26.22	0.029	8.57	0.012
9	0.087	24.45	0.029	8.23	0.012

10	0.088	25.67	0.028	8.25	0.012
11	0.09	26.02	0.031	8.82	0.012
12	0.089	25.51	0.04	11.57	0.012
13	0.091	26.7	0.034	9.96	0.012
14	0.074	23.71	0.024	7.84	0.012
15	0.079	24.75	0.018	5.63	0.012
16 Maint	Maint	Maint	Maint	Maint	Maint
17	0.085	25.16	0.018	5.43	0.012
18	0.09	26.25	0.031	9.19	0.012
19	0.086	25.74	0.031	9.37	0.012
20	0.089	26.34	0.032	9.5	0.012
21	0.088	25.45	0.029	8.47	0.012
22	0.092	26.96	0.03	8.83	0.012
23	0.086	25.38	0.033	9.52	0.012
Average	0.087		0.029		0.013
Total		538.85		179.31	
30-Day Rlng	0.09		0.028		
365-Day Rlng				60923	

8/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	25.19	0.031	8.89	0.012
1	0.086	25.72	0.031	9.14	0.014
2	0.084	25.85	0.026	7.91	0.017
3	0.086	25.86	0.029	8.68	0.019
4	0.078	24.34	0.021	6.62 OOC	
5	0.079	25.23	0.029	9.24 OOC	
6	0.086	24.63	0.023	6.5	0.012
7	0.092	26.36	0.034	9.65	0.012
8	0.091	26.81	0.028	8.14	0.012
9	0.086	25.3	0.027	7.78	0.012
10	0.087	26.04	0.031	9.13	0.012
11	0.093	28.36	0.027	8.24	0.012
12	0.082	24.34	0.025	7.44	0.012
13	0.082	23.62	0.031	8.79	0.012
14	0.089	26.57	0.034	10.22	0.012
15	0.091	26.29	0.023	6.65	0.012
16	0.089	26.17	0.024	7	0.012
17	0.091	26.55	0.032	9.5	0.012
18	0.086	24.95	0.027	7.78	0.012
19	0.088	25.87	0.028	8.21	0.012
20	0.085	25.32	0.028	8.34	0.012
21	0.089	25.9	0.032	9.4	0.012
22	0.09	26.09	0.033	9.65	0.012
23	0.088	25.79	0.032	9.48	0.012
Average	0.087		0.029		0.013
Total		617.15		202.38	
30-Day Rlng	0.09		0.028		

365-Day Rlng 60914

8/23/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.68	0.026	7.48	0.012
1	0.087	25.59	0.032	9.48	0.012
2	0.088	25.69	0.031	9.18	0.012
3	0.092	26.95	0.028	8.18	0.012
4	0.083	25.49	0.019	5.94	0.012
5	0.085	25.99	0.025	7.52	0.012
6	0.088	25.71	0.034	9.81	0.012
7	0.087	25.93	0.029	8.68	0.012
8	0.087	25.71	0.032	9.53	0.012
9	0.088	25.07	0.033	9.31	0.012
10	0.089	26.65	0.032	9.45	0.012
11	0.086	25.34	0.028	8.2	0.012
12	0.092	26.11	0.018	5.17	0.012
13	0.088	25.57	0.032	9.44	0.012
14	0.09	25.87	0.033	9.63	0.012
15	0.09	25.2	0.028	7.84	0.012
16	0.092	26.66	0.014	3.98	0.012
17	0.089	25.5	0.014	4.01	0.012
18	0.089	26	0.03	8.58	0.012
19	0.087	25.98	0.027	8.2	0.012
20	0.088	26.23	0.035	10.27	0.012
21	0.089	25.55	0.029	8.29	0.012
22	0.087	25.45	0.033	9.71	0.012
23	0.088	25.83	0.028	8.21	0.012
Average	0.088		0.028		0.012
Total		619.75		196.09	
30-Day Rlng	0.09		0.028		
365-Day Rlng				60900	

8/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.87	0.033	9.51	0.012
1	0.088	25.72	0.032	9.32	0.012
2	0.09	26.07	0.024	7.09	0.012
3	0.088	26.01	0.03	8.79	0.012
4	0.083	25.45	0.022	6.61	0.012
5	0.085	25.23	0.03	8.84	0.012
6	0.088	25.51	0.026	7.63	0.012
7	0.089	26.24	0.029	8.45	0.012
8	0.088	26.16	0.029	8.55	0.012
9	0.09	26.25	0.031	9.26	0.012
10	0.087	25.75	0.033	9.68	0.012
11	0.084	25.28	0.019	5.7	0.012
12	0.091	26.25	0.038	10.9	0.012
13	0.087	25.81	0.028	8.27	0.012

14	0.088	25.94	0.033	9.66	0.012
15	0.092	25.52	0.034	9.37	0.012
16	0.091	25.61	0.033	9.43	0.012
17	0.091	26.9	0.035	10.31	0.012
18	0.089	25.82	0.033	9.58	0.012
19	0.087	25.54	0.03	8.82	0.012
20	0.088	25.59	0.031	9.15	0.012
21	0.091	26.13	0.032	9.22	0.012
22	0.09	26.23	0.036	10.39	0.012
23	0.088	25.78	0.031	9	0.012
Average	0.089		0.031		0.012
Total		620.66		213.53	
30-Day Rlng	0.09		0.028		
365-Day Rlng				60904	

8/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	22.33	0.025	6.27	0.013
1	0.092	25.92	0.024	6.68	0.012
2	0.088	25.36	0.03	8.65	0.012
3	0.086	24.91	0.027	7.66	0.012
4	0.09	26.67	0.032	9.43	0.012
5	0.087	23.94	0.022	6.26	0.012
6	0.099	26.14	0.023	6.05	0.012
7	0.093	25.35	0.018	5	0.012
8	0.098	25.99	0.024	6.44	0.012
9	0.098	25.75	0.026	6.81	0.013
10	0.099	26.09	0.036	9.36	0.012
11	0.098	25.82	0.036	9.63	0.012
12	0.097	25.12	0.031	7.97	0.012
13	0.1	26.21	0.014	3.71	0.012
14	0.093	26.82	0.018	5.29	0.012
15	0.09	26.09	0.027	7.97	0.012
16	0.09	25.8	0.033	9.54	0.012
17	0.089	25.58	0.033	9.4	0.012
18	0.093	26.19	0.031	8.81	0.012
19	0.09	26.07	0.034	9.98	0.012
20	0.089	25.85	0.033	9.61	0.012
21	0.092	25.94	0.036	10.29	0.012
22	0.092	26.57	0.032	9.18	0.012
23	0.09	26.34	0.032	9.39	0.012
Average	0.093		0.028		0.012
Total		616.85		189.38	
30-Day Rlng	0.09		0.028		
365-Day Rlng				60876	

8/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	24.63	0.036	10.14	0.012

1	0.091	26.14	0.031	8.88	0.012
2	0.091	26.44	0.032	9.4	0.012
3	0.089	25.25	0.029	8.13	0.012
4	0.092	26.78	0.034	9.79	0.012
5	0.091	25.3	0.035	9.66	0.012
6	0.098	26.46	0.024	6.52	0.012
7	0.061	18.39	0.027	8.07	0.012
8	0.067	19.66	0.031	9.04	0.012
9	0.088	25.53	0.025	7.35	0.012
10	0.086	25.95	0.018	5.52	0.012
11	0.084	25.44	0.022	6.56	0.012
12	0.093	26.12	0.03	8.6	0.012
13	0.093	26.15	0.018	4.9	0.012
14	0.094	26.03	0.014	3.98	0.012
15	0.092	25.27	0.019	5.07	0.012
16	0.091	25.27	0.029	8.12	0.012
17	0.094	26.28	0.034	9.39	0.012
18	0.09	25.51	0.031	8.89	0.012
19	0.09	26.1	0.031	8.99	0.012
20	0.089	25.58	0.031	9.05	0.012
21	0.091	25.72	0.034	9.61	0.012
22	0.095	26.96	0.036	10.27	0.012
23	0.089	25.17	0.031	8.9	0.012
Average	0.089		0.028		0.012
Total		606.13		194.83	
30-Day Rlng	0.09		0.028		
365-Day Rlng				60871	

8/27/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	26.28	0.037	10.39	0.012
1	0.09	26.13	0.028	8.22	0.012
2	0.089	25.7	0.034	9.84	0.012
3	0.092	25.5	0.035	9.6	0.012
4	0.094	26.54	0.032	8.93	0.012
5	0.089	24.92	0.037	10.23	0.012
6	0.092	26.33	0.033	9.6	0.012
7	0.084	26.57	0.029	8.93	0.012
8	0.084	25.91	0.029	8.99	0.012
9	0.088	25.83	0.03	8.89	0.012
10	0.089	25.68	0.024	6.99	0.012
11	0.094	25.83	0.023	6.21	0.012
12	0.089	25.66	0.03	8.7	0.012
13	0.092	26.84	0.029	8.46	0.012
14	0.087	25.14	0.03	8.6	0.012
15	0.089	25.4	0.033	9.37	0.012
16	0.09	26.6	0.028	8.21	0.012
17	0.089	25.69	0.03	8.55	0.012

18	0.093	25.91	0.027	7.62	0.012
19	0.094	26.22	0.032	8.96	0.012
20	0.092	25.69	0.036	10.04	0.012
21	0.094	25.97	0.033	9.21	0.012
22	0.093	25.91	0.033	9.11	0.012
23	0.092	25.55	0.032	8.98	0.012
Average	0.09		0.031		0.012
Total		621.8		212.63	
30-Day Rlng	0.09		0.028		
365-Day Rlng				60886	

8/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	25.51	0.031	8.62	0.012
1	0.092	26.52	0.032	9.26	0.012
2	0.09	25.55	0.029	8.25	0.012
3	0.094	26.04	0.035	9.6	0.012
4	0.094	26.44	0.035	9.92	0.012
5	0.091	26.02	0.032	9.14	0.012
6	0.09	27.01	0.02	6.08	0.012
7	0.09	25.74	0.03	8.44	0.012
8	0.09	26.08	0.035	10.03	0.012
9	0.092	25.81	0.029	8.26	0.012
10	0.09	26.33	0.028	8.09	0.012
11	0.087	25.46	0.035	10.21	0.012
12	0.09	25.67	0.032	9.04	0.012
13	0.093	26.75	0.025	7.15	0.012
14	0.089	25.52	0.032	9.09	0.012
15	0.089	25.49	0.025	7.02	0.012
16	0.091	26.42	0.032	9.29	0.012
17	0.09	25.73	0.03	8.66	0.012
18	0.09	25.96	0.033	9.41	0.012
19	0.089	25.54	0.028	8.13	0.012
20	0.092	26.12	0.027	7.56	0.012
21	0.093	26.16	0.032	9.1	0.012
22	0.093	26.43	0.035	9.97	0.012
23	0.091	25.45	0.028	7.92	0.012
Average	0.091		0.03		0.012
Total		623.75		208.24	
30-Day Rlng	0.09		0.028		
365-Day Rlng				60912	

8/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	26	0.022	6.08	0.012
1	0.091	25.86	0.038	10.67	0.012
2	0.088	26.14	0.035	10.38	0.012
3	0.09	26.23	0.034	9.86	0.012
4	0.086	25.67	0.03	8.9	0.012

5	0.091	26.88	0.027	7.93	0.012
6	0.082	24.56	0.022	6.49	0.012
7	0.086	25.87	0.025	7.34	0.012
8	0.088	26.19	0.038	11.32	0.012
9	0.087	25.57	0.029	8.65	0.012
10	0.09	27.07	0.033	9.97	0.012
11	0.084	24.94	0.018	5.48	0.012
12	0.089	26.02	0.037	10.72	0.012
13	0.089	26.57	0.032	9.65	0.012
14	0.086	25.34	0.031	9.14	0.012
15	0.09	26.09	0.032	9.14	0.012
16	0.09	26.04	0.03	8.72	0.012
17	0.09	25.93	0.028	8.19	0.012
18	0.09	26.17	0.037	10.61	0.012
19	0.088	26.23	0.03	8.85	0.012
20	0.088	25.86	0.028	8.09	0.012
21	0.094	25.56	0.032	8.7	0.012
22	0.093	26.25	0.037	10.5	0.012
23	0.091	26.38	0.028	8.26	0.012
Average	0.089		0.031		0.012
Total		623.42		213.64	
30-Day Rlng	0.09		0.028		
365-Day Rlng				60946	

8/30/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	24.81	0.032	9.07	0.012
1	0.092	26.35	0.036	10.11	0.012
2	0.091	27.11	0.027	8.04	0.012
3	0.085	24.93	0.03	8.7	0.012
4	0.088	25.6	0.034	9.79	0.012
5	0.091	26.87	0.033	9.64	0.012
6	0.086	25.52	0.03	8.79	0.012
7	0.09	26.47	0.028	8.38	0.012
8	0.089	25.57	0.03	8.66	0.012
9	0.089	25.46	0.031	8.87	0.012
10	0.089	26.09	0.033	9.68	0.012
11	0.09	26.38	0.031	9.01	0.012
12	0.086	25.09	0.033	9.8	0.012
13	0.088	25.65	0.035	10.3	0.012
14	0.091	26.93	0.033	9.83	0.012
15	0.085	24.48	0.024	6.82	0.012
16	0.092	26.83	0.029	8.39	0.012
17	0.089	25.85	0.03	8.81	0.012
18	0.088	25.65	0.035	10.06	0.012
19	0.087	25.87	0.027	8.03	0.012
20	0.09	26.12	0.03	8.61	0.012
21	0.09	24.85	0.021	5.94	0.012

	22	0.094	26.6	0.034	9.7	0.012
	23	0.092	26.34	0.033	9.58	0.012
Average		0.089		0.031		0.012
Total			621.42		214.61	
30-Day Rlng		0.089		0.028		
365-Day Rlng					60965	

8/31/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.15	0.03	8.86	0.012
1	0.086	25.53	0.029	8.71	0.012
2	0.088	26.27	0.033	9.69	0.012
3	0.09	26.56	0.031	9.3	0.012
4	0.088	26.21	0.026	7.67	0.012
5	0.089	25.86	0.026	7.65	0.012
6	0.084	25.72	0.028	8.37	0.012
7	0.083	25.78	0.023	7.14	0.012
8	0.087	26.95	0.032	9.9	0.012
9	0.085	25.01	0.031	9.29	0.012
10	0.088	26.17	0.034	10.13	0.012
11	0.09	26.75	0.024	7.04	0.012
12	0.085	24.79	0.03	8.65	0.012
13	0.091	26.82	0.029	8.61	0.012
14	0.086	24.4	0.026	7.28	0.012
15	0.09	26.71	0.021	6.27	0.012
16	0.087	26.23	0.021	6.24	0.012
17	0.085	26.05	0.026	7.95	0.012
18	0.087	25.87	0.032	9.62	0.012
19	0.09	26.77	0.024	7.01	0.012
20	0.087	25.33	0.017	4.92	0.012
21	0.093	26.36	0.026	7.25	0.012
22	0.09	25.58	0.03	8.64	0.012
23	0.095	27.01	0.043	12.12	0.012
Average	0.088		0.028		0.012
Total		624.88		198.31	
30-Day Rlng	0.089		0.028		
365-Day Rlng				60962	

9/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.81	0.023	6.66	0.012
1	0.086	25.49	0.027	8	0.012
2	0.089	26.49	0.025	7.4	0.012
3	0.084	24.65	0.022	6.4	0.012
4	0.091	26.81	0.021	6.34	0.012
5	0.086	25.85	0.016	4.93	0.012
6	0.085	25.64	0.024	7.31	0.012
7	0.09	27.27	0.022	6.72	0.012
8	0.085	25.8	0.031	9.53	0.012

9	0.09	26.31	0.031	8.98	0.012
10	0.088	26.3	0.035	10.49	0.012
11	0.084	25.12	0.029	8.6	0.012
12	0.088	25.85	0.024	6.85	0.012
13	0.09	26.83	0.029	8.7	0.012
14	0.086	25.25	0.032	9.45	0.012
15	0.088	25.74	0.022	6.56	0.012
16	0.088	26.26	0.031	9.15	0.012
17	0.084	24.9	0.031	9.16	0.012
18	0.09	25.21	0.023	6.6	0.012
19	0.095	26.37	0.031	8.51	0.012
20	0.094	25.45	0.027	7.38	0.012
21	0.098	24.15	0.014	3.55	0.012
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average		0.089		0.026	0.012
Total			567.55		167.27
30-Day Rlng		0.089		0.028	
365-Day Rlng					60948

9/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Down	Down	Down	Down	Down
3	Down	Down	Down	Down	Down
4	Down	Down	Down	Down	Down
5	DCal	DCal	DCal	DCal	DCal
6	DCal	DCal	DCal	DCal	DCal
7	Down	Down	Down	Down	Down
8	Down	Down	Down	Down	Down
9	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	

30-Day Rlng 0.089 0.028
 365-Day Rlng 60748

9/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 DCAL	DCAL	DCAL	DCAL	DCAL	DCAL
6 DCAL	DCAL	DCAL	DCAL	DCAL	DCAL
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Maint	Maint	Maint	Maint	Maint	Maint
22 Maint	Maint	Maint	Maint	Maint	Maint
23 Maint	Maint	Maint	Maint	Maint	Maint
Average	Maint		Maint		Maint
Total		Maint		Maint	
30-Day Rlng	0.09		0.028		
365-Day Rlng				60544	

9/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Maint	Maint	Maint	Maint	Maint	Maint
1 Maint	Maint	Maint	Maint	Maint	Maint
2 Maint	Maint	Maint	Maint	Maint	Maint
3 Maint	Maint	Maint	Maint	Maint	Maint
4 Maint	Maint	Maint	Maint	Maint	Maint
5 Maint	Maint	Maint	Maint	Maint	Maint
6	0.072	21.93	0.018	5.43	0.012
7	0.087	26.13	0.031	9.48	0.012
8	0.087	26.46	0.035	10.65	0.012
9	0.086	25.35	0.03	8.77	0.012
10	0.089	26.08	0.03	8.9	0.012
11	0.09	26.53	0.034	10	0.012
12	0.087	25.08	0.032	9.24	0.012

13	0.091	25.79	0.033	9.52	0.012
14	0.094	26.96	0.036	10.41	0.012
15	0.091	25.37	0.033	9.13	0.012
16	0.092	25.63	0.024	6.68	0.012
17	0.092	26.06	0.031	8.92	0.012
18	0.091	25.34	0.02	5.64	0.012
19	0.092	25.45	0.025	6.84	0.012
20	0.093	26.45	0.03	8.52	0.012
21	0.097	26.6	0.027	7.49	0.012
22	0.092	25.9	0.029	8.13	0.012
23	0.091	25.64	0.023	6.42	0.012
Average	0.09		0.029		0.012
Total		462.75		150.17	
30-Day Rlng	0.09		0.028		
365-Day Rlng				60489	

9/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	25.3	0.035	9.6	0.012
1	0.093	26.33	0.025	7.13	0.012
2	0.091	26.11	0.027	7.81	0.012
3	0.094	26.27	0.031	8.54	0.012
4	0.094	26.25	0.027	7.54	0.012
5	0.092	25.79	0.032	9.12	0.012
6	0.092	26.77	0.034	9.91	0.012
7	0.09	25.71	0.028	7.98	0.012
8	0.093	26.15	0.036	10.08	0.012
9	0.093	25.14	0.032	8.71	0.012
10	0.093	26.25	0.034	9.69	0.012
11	0.09	25.74	0.034	9.67	0.012
12	0.093	25.94	0.037	10.29	0.012
13	0.091	26.09	0.032	9.23	0.012
14	0.093	26.1	0.034	9.42	0.012
15	0.094	25.23	0.032	8.65	0.012
16	0.094	25.91	0.036	9.9	0.012
17	0.094	26.07	0.034	9.54	0.012
18	0.094	25.66	0.026	7.16	0.012
19	0.094	25.7	0.027	7.36	0.012
20	0.092	25.58	0.023	6.36	0.012
21	0.095	26.15	0.025	6.81	0.012
22	0.094	26.38	0.034	9.7	0.012
23	0.091	25.61	0.032	8.96	0.012
Average	0.093		0.031		0.012
Total		622.23		209.16	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60489	

9/6/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
------	--------------	---------	--------------	---------	-------------

0	0.093	25.69	0.029	8.08	0.012
1	0.092	25.92	0.033	9.44	0.012
2	0.092	25.68	0.026	7.26	0.012
3	0.094	26.09	0.02	5.63	0.012
4	0.093	25.79	0.03	8.21	0.012
5	0.097	27.75	0.027	7.92	0.012
6	0.083	24.26	0.028	8.17	0.012
7	0.089	25.34	0.032	9.13	0.012
8	0.091	26.38	0.034	9.97	0.012
9	0.09	25.19	0.033	9.29	0.012
10	0.09	25.42	0.032	9.04	0.012
11	0.094	26.12	0.034	9.37	0.012
12	0.089	25.03	0.028	7.95	0.012
13	0.09	25.86	0.033	9.55	0.012
14	0.093	26.55	0.029	8.42	0.012
15	0.093	25.33	0.034	9.12	0.012
16	0.092	26.03	0.038	10.67	0.012
17	0.094	26.14	0.029	8.05	0.012
18	0.091	25.15	0.03	8.32	0.012
19	0.091	25.65	0.033	9.48	0.012
20	0.093	26.86	0.029	8.47	0.012
21	0.091	25.74	0.03	8.61	0.015
22	0.091	25.89	0.027	7.82	0.018
23	0.09	26.23	0.029	8.28	0.021
Average	0.092		0.03		0.013
Total		620.09		206.25	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60481	

9/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.94	0.032	9.34	0.023
1	0.089	26.11	0.031	9.15	0.026
2	0.092	26.25	0.035	9.98	0.028
3	0.092	25.91	0.029	8.1	0.028
4	0.092	26.16	0.03	8.52	0.029
5	0.091	26.04	0.034	9.59	0.028
6	0.087	26.57	0.022	6.88 OOC	
7	0.086	25.42	0.033	9.84 OOC	
8	0.084	25.48	0.031	9.45 OOC	
9	0.087	26.67	0.026	8.11 OOC	
10	0.085	24.89	0.028	8.06 OOC	
11	0.091	26.78	0.035	10.38 OOC	
12	0.084	24.87	0.03	8.98 Maint	
13	0.08	26.18	0.032	10.36	0.012
14	0.087	28.6	0.025	8.25	0.012
15	0.083	24.39	0.025	7.43	0.012
16	0.089	25.6	0.033	9.59	0.012

17	0.087	25.6	0.022	6.48	0.012
18	0.092	25.73	0.032	9.04	0.012
19	0.091	26.12	0.028	8.09	0.015
20	0.089	24.98	0.034	9.57	0.019
21	0.094	26.8	0.031	8.87	0.02
22	0.09	25.53	0.038	10.66	0.021
23	0.094	26.29	0.034	9.47	0.02
Average	0.089		0.03		0.019
Total		622.91		214.19	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60484	

9/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.4	0.034	9.48	0.022
1	0.094	26.18	0.034	9.38	0.023
2	0.093	25.49	0.024	6.64	0.025
3	0.095	25.55	0.038	10.37	0.028
4	0.095	26.96	0.037	10.46	0.03
5	0.097	31.1	0.025	7.97	0.012
6	0.087	25.12	0.037	10.77	0.012
7	0.085	25.73	0.027	8.21	0.012
8	0.09	26.05	0.032	9.18	0.012
9	0.092	26.4	0.031	8.78	0.012
10	0.089	25.82	0.031	8.91	0.012
11	0.092	26.34	0.033	9.53	0.012
12	0.087	25.01	0.035	10.11	0.012
13	0.095	27.41	0.036	10.32	0.012
14	0.093	26.11	0.032	9.01	0.012
15	0.094	25.93	0.037	10.13	0.012
16	0.093	25.86	0.036	9.96	0.012
17	0.091	25.29	0.027	7.6	0.012
18	0.094	25.2	0.036	9.61	0.012
19	0.099	26.33	0.034	8.97	0.012
20	0.098	26.03	0.028	7.48	0.012
21	0.097	25.16	0.034	8.77	0.012
22	0.1	26.8	0.026	7	0.012
23	0.096	25.41	0.031	8.26	0.012
Average	0.093		0.032		0.015
Total		626.68		216.9	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60502	

9/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.102	26.34	0.038	9.82	0.012
1	0.098	26.11	0.024	6.42	0.012
2	0.095	25.18	0.029	7.68	0.012
3	0.099	26.16	0.035	9.18	0.012

4	0.096	25.6	0.032	8.58	0.012
5	0.101	26.52	0.038	9.97	0.012
6	0.093	26.16	0.023	6.49	0.012
7	0.088	24.12	0.022	5.96	0.012
8 Maint	Maint	Maint	Maint	Maint	Maint
9 Maint	Maint	Maint	Maint	Maint	Maint
10	0.092	25.12	0.023	6.45	0.012
11	0.099	25.28	0.021	5.41	0.013
12	0.096	26.1	0.033	8.97	0.012
13	0.094	26.04	0.034	9.38	0.012
14	0.095	25.89	0.027	7.29	0.012
15	0.098	26.81	0.028	7.78	0.012
16	0.096	26.17	0.028	7.53	0.012
17	0.093	25.83	0.026	7.35	0.012
18	0.094	25.29	0.026	7.1	0.012
19	0.096	26.03	0.028	7.73	0.012
20	0.097	26.03	0.033	8.99	0.012
21	0.096	25.65	0.031	8.35	0.013
22	0.095	26.42	0.023	6.28	0.012
23	0.097	26.03	0.022	5.83	0.012
Average	0.096		0.028		0.012
Total		568.88		168.54	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60454	

9/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.096	25.9	0.023	6.21	0.012
1	0.095	25.75	0.03	8.16	0.013
2	0.095	25.98	0.03	8.07	0.013
3	0.103	28.09	0.027	7.46	0.013
4	0.089	25.45	0.031	8.76	0.012
5	0.096	27.39	0.026	7.46	0.012
6	0.091	25.7	0.024	6.61	0.012
7	0.09	25.72	0.025	7.12	0.012
8	0.091	26.49	0.02	5.97	0.012
9	0.088	24.38	0.03	8.26	0.012
10	0.096	26.08	0.03	8.17	0.012
11	0.095	25.51	0.032	8.57	0.012
12	0.099	26.97	0.022	6.05	0.012
13	0.093	25.93	0.014	3.95	0.012
14	0.094	26.42	0.016	4.37	0.012
15	0.093	26.51	0.021	6	0.012
16	0.081	24.03	0.017	5.01	0.012
17	0.086	27.06	0.017	5.36	0.012
18	0.088	26.48	0.023	6.76	0.012
19	0.088	25.32	0.029	8.32	0.012
20	0.087	24.75	0.03	8.42	0.015

21	0.091	25.89	0.029	8.16	0.015
22	0.09	25.75	0.027	7.55	0.015
23	0.088	25.36	0.034	9.84	0.015
Average	0.092		0.025		0.013
Total		622.91		170.61	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60444	

9/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.78	0.032	9.15	0.015
1	0.091	25.24	0.023	6.3	0.015
2	0.093	26.46	0.031	8.72	0.014
3	0.091	25.8	0.038	10.59	0.014
4	0.093	26.51	0.031	8.82	0.014
5	0.087	25.06	0.021	6.09	0.014
6	0.094	27.64	0.02	5.97 Cal	
7	0.094	25.92	0.025	6.76	0.012
8	0.095	26.38	0.03	8.41	0.012
9	0.094	26.38	0.031	8.68	0.012
10	0.094	25.33	0.021	5.64	0.012
11	0.093	25.73	0.031	8.64	0.012
12	0.094	26.06	0.029	8.05	0.012
13	0.09	25.94	0.031	9.05	0.012
14	0.089	25.12	0.028	7.93	0.012
15	0.095	26.56	0.028	7.94	0.012
16	0.093	26.14	0.032	8.94	0.012
17	0.09	25.51	0.029	8.12	0.012
18	0.093	26.44	0.032	9.11	0.012
19	0.09	25.15	0.031	8.71	0.012
20	0.092	26.56	0.029	8.44	0.012
21	0.092	26.19	0.031	8.9	0.012
22	0.091	26.01	0.026	7.49	0.012
23	0.091	25.88	0.032	9.04	0.012
Average	0.092		0.029		0.013
Total		623.79		195.49	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60494	

9/12/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.29	0.021	5.82	0.012
1	0.091	25.63	0.032	8.96	0.012
2	0.091	26.16	0.031	8.82	0.012
3	0.091	25.87	0.03	8.6	0.012
4	0.093	25.85	0.03	8.22	0.012
5	0.091	26.39	0.032	9.23	0.012
6	0.092	27.65	0.019	5.78	0.012
7	0.087	25.03	0.028	8.01	0.012

8	0.093	26.57	0.033	9.55	0.012
9	0.092	25.95	0.028	7.85	0.012
10	0.089	24.55	0.029	7.86	0.012
11	0.091	25.58	0.027	7.52	0.012
12	0.095	26.97	0.035	9.91	0.012
13	0.09	25.75	0.024	6.96	0.012
14	0.087	24.45	0.024	6.75	0.012
15	0.095	26.66	0.033	9.33	0.012
16	0.096	24.4	0.024	5.99	0.013
17	0.109	25.64	0.016	3.79	0.014
18	0.113	26.45	0.017	3.99	0.015
19	0.109	26.17	0.017	4.02	0.014
20	0.104	24.4	0.018	4.18	0.015
21	0.091	25.68	0.022	6.33	0.013
22	0.089	24.48	0.024	6.68	0.012
23	0.088	24.78	0.027	7.68	0.012
Average	0.094		0.026		0.013
Total		616.35		171.83	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60487	

9/13/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.81	0.033	9.41	0.012
1	0.093	26.01	0.032	8.95	0.012
2	0.09	25.59	0.025	7.14	0.012
3	0.09	26.2	0.026	7.66	0.012
4	0.086	24.66	0.028	7.93	0.012
5	0.091	27.19	0.029	8.63	0.012
6	0.087	26.34	0.018	5.49	0.012
7	0.087	24.84	0.014	4.03	0.012
8	0.093	26.62	0.029	8.3	0.012
9	0.091	25.48	0.031	8.63	0.012
10	0.094	26.06	0.03	8.43	0.012
11	0.093	25.93	0.029	7.98	0.012
12	0.093	25.52	0.03	8.32	0.012
13	0.095	26.01	0.034	9.42	0.012
14	0.094	26.72	0.032	9.02	0.012
15	0.093	26.48	0.033	9.33	0.012
16	0.091	25.11	0.029	7.93	0.012
17	0.092	26.4	0.031	9.01	0.012
18	0.089	25.81	0.028	8.26	0.012
19	0.089	25.18	0.029	8.34	0.012
20	0.089	25.9	0.027	7.86	0.012
21	0.089	25.88	0.031	8.95	0.012
22	0.091	26.43	0.029	8.46	0.012
23	0.087	25.33	0.026	7.44	0.012
Average	0.091		0.028		0.012

Total		621.5		194.92	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60505	
9/14/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.65	0.033	9.59	0.012
1	0.09	25.04	0.03	8.39	0.012
2	0.095	26.81	0.028	7.92	0.012
3	0.088	24.62	0.031	8.68	0.012
4	0.095	26.5	0.028	7.76	0.012
5	0.092	26.95	0.031	8.98	0.012
6	0.087	26.22	0.027	7.97	0.012
7	0.085	24.11	0.028	7.76	0.012
8	0.09	25.77	0.032	9.14	0.012
9	0.094	27	0.027	7.7	0.012
10	0.09	25.19	0.03	8.39	0.012
11	0.089	25.82	0.023	6.59	0.012
12	0.094	26.49	0.028	7.86	0.012
13	0.092	25.66	0.03	8.28	0.012
14	0.094	26.38	0.027	7.63	0.012
15	0.092	25.62	0.032	8.89	0.012
16	0.094	26.5	0.031	8.72	0.012
17	0.089	25.12	0.024	6.78	0.012
18	0.061	11.32	0.032	6.02	0.016
19	0.074	17.51	0.022	4.93	0.013
20	0.097	28.38	0.03	8.9	0.012
21	0.084	24.23	0.029	8.39	0.012
22	0.094	26.58	0.03	8.54	0.012
23	0.087	24.08	0.028	7.61	0.012
Average	0.089		0.029		0.012
Total		597.55		191.42	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60509	
9/15/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.098	27.73	0.037	10.54	0.012
1	0.09	25.23	0.032	9.07	0.012
2	0.093	26.41	0.028	8.04	0.012
3	0.093	26.46	0.03	8.52	0.012
4	0.091	25.21	0.033	9.01	0.012
5	0.092	26.55	0.028	8.02	0.012
6	0.091	27.09	0.02	5.93	0.012
7	0.093	25.57	0.035	9.67	0.012
8	0.091	26.52	0.025	7.26	0.012
9	0.089	25.93	0.029	8.45	0.012
10	0.091	26.05	0.025	7.05	0.012
11	0.09	26.02	0.032	9.31	0.012

12	0.089	25.82	0.028	8.12	0.012
13	0.09	25.71	0.016	4.65	0.012
14	0.091	25.88	0.025	6.98	0.012
15	0.091	26.43	0.033	9.63	0.012
16	0.091	25.11	0.032	8.73	0.012
17	0.092	26.06	0.028	8.01	0.012
18	0.093	26.76	0.034	9.75	0.012
19	0.09	25.29	0.032	8.93	0.012
20	0.09	25.6	0.028	7.99	0.012
21	0.093	26.16	0.03	8.49	0.012
22	0.093	25.85	0.015	4.17	0.012
23	0.094	26.32	0.032	8.89	0.012
Average			0.029		0.012
Total		625.76		195.21	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60497	

9/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	25.64	0.029	8.17	0.012
1	0.094	26.16	0.026	7.1	0.012
2	0.093	26.41	0.038	10.87	0.012
3	0.094	26.17	0.029	8.01	0.012
4	0.093	25.83	0.034	9.29	0.012
5	0.092	26.02	0.023	6.64	0.012
6	0.092	26.98	0.031	9.27	0.012
7	0.09	25.4	0.025	7	0.012
8	0.09	25.26	0.023	6.28	0.012
9	0.094	26.3	0.033	9.19	0.012
10	0.092	25.56	0.031	8.6	0.012
11	0.09	25.46	0.029	8.08	0.012
12	0.093	26.27	0.031	8.9	0.012
13	0.093	26.07	0.024	6.78	0.012
14	0.093	26.37	0.031	8.86	0.012
15	0.092	25.92	0.028	8.04	0.012
16	0.093	26.4	0.028	7.99	0.012
17	0.09	25.52	0.026	7.4	0.012
18	0.094	27.07	0.034	9.77	0.012
19	0.095	26.56	0.031	8.62	0.012
20	0.087	24.79	0.029	8.12	0.012
21	0.092	26.2	0.031	8.71	0.012
22	0.092	26	0.028	7.75	0.012
23	0.093	26.19	0.033	9.26	0.012
Average			0.029		0.012
Total		624.55		198.7	
30-Day Rlng	0.09		0.029		
365-Day Rlng				60460	

9/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	24.76	0.032	8.81	0.012
1	0.096	26.63	0.031	8.5	0.012
2	0.094	26.14	0.031	8.73	0.012
3	0.093	25.63	0.027	7.46	0.012
4	0.094	25.65	0.035	9.55	0.012
5	0.096	27.54	0.033	9.33	0.012
6	0.087	25.75	0.018	5.24	0.012
7	0.091	25.51	0.024	6.89	0.012
8	0.094	26.19	0.032	8.95	0.012
9	0.092	25.54	0.034	9.38	0.012
10	0.095	26.03	0.026	6.98	0.012
11	0.094	26.09	0.029	8.06	0.012
12	0.094	26.33	0.033	9.15	0.012
13	0.094	26.09	0.025	6.8	0.012
14	0.092	25.91	0.034	9.5	0.012
15	0.093	26.42	0.028	8.04	0.012
16	0.095	26.56	0.024	6.87	0.012
17	0.091	26.26	0.03	8.68	0.012
18	0.09	25.94	0.03	8.64	0.012
19	0.091	25.47	0.028	7.83	0.012
20	0.092	26.21	0.029	8.13	0.012
21	0.09	25.44	0.039	10.84	0.012
22	0.098	27.01	0.028	7.76	0.012
23	0.091	24.98	0.031	8.64	0.012
Average	0.093		0.03		0.012
Total		624.08		198.76	
30-Day Rng	0.091		0.029		
365-Day Rng				60449	

9/18/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	26.06	0.029	8.01	0.012
1	0.096	26.89	0.032	9.01	0.012
2	0.091	25.5	0.03	8.49	0.012
3	0.092	25.71	0.031	8.71	0.012
4	0.097	25.8	0.032	8.56	0.012
5	0.097	27.28	0.037	10.37	0.012
6	0.085	25.34	0.026	7.82	0.012
7	0.087	23.03	0.024	6.37	0.012
8	0.099	25.96	0.039	10.2	0.012
9	0.096	25.23	0.032	8.38	0.012
10	0.098	26.36	0.032	8.5	0.012
11	0.088	24.24	0.029	7.97	0.012
12	0.099	26.21	0.029	7.74	0.012
13	0.092	25.51	0.034	9.46	0.012
14	0.088	25.62	0.033	9.48	0.012
15	0.09	25.76	0.026	7.5	0.012

16	0.09	25.39	0.029	8.2	0.012
17	0.091	26	0.03	8.55	0.012
18	0.092	25.93	0.03	8.59	0.012
19	0.091	25.69	0.029	8.09	0.012
20	0.092	26.09	0.027	7.54	0.012
21	0.09	24.48	0.019	5.15	0.012
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	0.093		0.03		0.012
Total		564.08		182.69	
30-Day Rlng	0.091		0.029		
365-Day Rlng				60440	

9/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Down	Down	Down	Down	Down
3	Down	Down	Down	Down	Down
4	Down	Down	Down	Down	Down
5	DCal	DCal	DCal	DCal	DCal
6	DCal	DCal	DCal	DCal	DCal
7	Down	Down	Down	Down	Down
8	Down	Down	Down	Down	Down
9	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng	0.091		0.029		
365-Day Rlng				60261	

9/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Down	Down	Down	Down	Down

3 Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down
Average	Down	Down	Down	Down
Total		Down	Down	
30-Day Rlng	0.091		0.029	
365-Day Rlng				60072

9/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down

	20	Down	Down	Down	Down
	21	Down	Down	Down	Down
	22	Down	Down	Down	Down
	23	Down	Down	Down	Down
Average		Down		Down	Down
Total			Down		Down
30-Day Rlng		0.091		0.029	
365-Day Rlng					59865

9/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu	
0	Down	Down	Down	Down	Down	
1	Down	Down	Down	Down	Down	
2	Down	Down	Down	Down	Down	
3	Down	Down	Down	Down	Down	
4	Down	Down	Down	Down	Down	
5	Down	Down	Down	Down	Down	
6	Maint	Maint	Maint	Maint	Maint	
7	Maint	Maint	Maint	Maint	Maint	
8	Maint	Maint	Maint	Maint	Maint	
9	Maint	Maint	Maint	Maint	Maint	
10	Maint	Maint	Maint	Maint	Maint	
11	Maint	Maint	Maint	Maint	Maint	
12	Maint	Maint	Maint	Maint	Maint	
13	Maint	Maint	Maint	Maint	Maint	
14	0.219	Maint		0.036	Maint	
15	0.186		29.52	0.023	3.73	Cal
16	0.084	OOC		0.02	OOC	
17	0.084		25.03	0.023	6.96	0.012
18	0.084		25.88	0.018	5.68	0.012
19	0.089		26.14	0.029	8.45	0.012
20	0.086		25.57	0.019	5.49	0.012
21	0.089		25.81	0.019	5.62	0.014
22	0.091		26.31	0.023	6.56	0.017
23	0.089		25.96	0.026	7.66	0.018
Average		0.11		0.024		0.014
Total			210.22		50.15	
30-Day Rlng		0.091		0.029		
365-Day Rlng					59816	

9/23/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.68	0.026	7.61	0.02
1	0.089	25.36	0.029	8.26	0.022
2	0.092	25.87	0.019	5.36	0.02
3	0.094	26.3	0.035	9.76	0.02
4	0.094	26.31	0.031	8.55	0.02
5	0.093	26.72	0.015	4.25	0.02
6	0.077	23.41	0.021	6.65	0.013

7	0.095	25.32	0.025	6.76	0.013
8	0.096	25.97	0.034	9.13	0.012
9	0.094	25.61	0.034	9.27	0.012
10	0.096	26.12	0.028	7.69	0.012
11	0.092	25.85	0.03	8.48	0.012
12	0.093	26.08	0.028	7.9	0.012
13	0.094	25.54	0.033	9.04	0.012
14	0.093	26.15	0.024	6.83	0.012
15	0.093	26.31	0.034	9.49	0.012
16	0.092	25.91	0.033	9.17	0.012
17	0.09	25.62	0.027	7.65	0.012
18	0.09	26.45	0.029	8.64	0.012
19	0.09	25.47	0.03	8.43	0.012
20	0.092	26.58	0.033	9.57	0.012
21	0.088	25.81	0.025	7.34	0.012
22	0.092	25.78	0.027	7.53	0.012
23	0.09	26.43	0.023	6.72	0.012
Average	0.092		0.028		0.014
Total		621.65		190.08	
30-Day Rlng	0.091		0.029		
365-Day Rlng				59807	

9/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	25.54	0.022	6.21	0.012
1	0.092	25.59	0.033	9.11	0.012
2	0.091	26.23	0.025	7.12	0.012
3	0.095	25.35	0.026	7.04	0.012
4	0.102	25.72	0.021	5.31	0.012
5	0.098	27.59	0.031	8.68	0.012
6	0.083	23.69	0.024	7.02	0.012
7	0.093	25.35	0.029	7.92	0.013
8	0.092	26.18	0.029	8.27	0.013
9	0.09	25.72	0.031	8.71	0.012
10	0.089	25.29	0.028	7.93	0.012
11	0.095	26.59	0.028	7.94	0.012
12	0.092	26.23	0.031	8.73	0.012
13	0.089	24.82	0.028	7.82	0.012
14	0.094	26.44	0.027	7.48	0.013
15	0.095	26.12	0.032	8.7	0.013
16	0.095	25.71	0.034	9.09	0.013
17	0.095	26.33	0.032	8.92	0.013
18	0.092	25.32	0.029	8.04	0.013
19	0.088	21.1	0.018	4.28	0.013
20	0.09	22.57	0.021	5.21	0.013
21	0.091	20.07	0.026	5.68	0.014
22	0.07	12.96	0.018	3.33	0.015
23	0.046	8.51	0.017	3.15	0.015

Average	0.089	0.027	0.013
Total	575.02	171.69	
30-Day Rlng	0.091	0.029	
365-Day Rlng		59780	

9/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.058	10.21	0.018	3.14	0.016
1	0.088	16.11	0.017	3.07	0.015
2	0.085	16.75	0.02	3.91	0.014
3	0.069	12.83	0.017	3.1	0.014
4	0.077	13.28	0.018	3.06	0.016
5	0.08	16.72	0.025	5.18	0.013
6	0.082	17.21	0.023	4.93	0.014
7	0.089	17.46	0.028	5.48	0.014
8	0.091	16.68	0.017	3.13	0.015
9	0.087	15.84	0.022	3.9	0.016
10	0.074	15.09	0.031	6.76	0.014
11	0.071	18.2	0.03	7.72	0.012
12	0.065	18.79	0.023	6.67	0.012
13	0.065	18.07	0.029	8.1	0.012
14	0.065	18.7	0.031	8.77	0.012
15	0.064	18.04	0.028	7.93	0.012
16	0.08	22.3	0.03	8.39	0.012
17	0.094	26.4	0.029	8.2	0.012
18	0.093	26	0.031	8.74	0.012
19	0.094	25.33	0.034	9.13	0.012
20	0.095	26.29	0.026	7.04	0.012
21	0.094	25.87	0.029	7.97	0.012
22	0.098	24.19	0.03	7.42	0.012
23	Inval	2.48	Inval	1.72	Inval
Average	0.081		0.025		0.013
Total		438.84		143.46	
30-Day Rlng	0.091		0.029		
365-Day Rlng				59723	

9/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu	
0	Inval		1.87	Inval	1.3	Inval
1	Down	Down	Down	Down	Down	
2	Inval		2.19	Inval	1.52	Inval
3	0.282	14.46	0.06	3.23	OOR	
4	0.116	24.07	0.023	4.94		0.02
5	0.09	24.27	0.035	9.46		0.012
6	0.097	27.98	0.027	7.79		0.012
7	0.09	25.8	0.024	6.9		0.012
8	0.09	26.18	0.033	9.5		0.012
9	0.092	26.15	0.027	7.62		0.012
10	0.091	25.4	0.033	9.17		0.012

11	0.092	26.2	0.03	8.45	0.012
12	0.091	25.22	0.024	6.7	0.012
13	0.097	26.86	0.03	8.36	0.013
14	0.093	26.31	0.032	8.95	0.012
15	0.093	25.96	0.029	8.16	0.012
16	0.091	25.51	0.032	8.94	0.012
17	0.092	26.1	0.028	7.88	0.012
18	0.092	26.01	0.029	8.17	0.012
19	0.092	25.55	0.026	7.43	0.012
20	0.095	26.64	0.032	8.9	0.012
21	0.092	25.47	0.029	7.92	0.012
22	0.097	26.44	0.026	7.13	0.012
23	0.094	25.82	0.026	7.17	0.012
Average	0.103		0.03		0.012
Total		536.46		165.59	
30-Day Rlng	0.091		0.029		
365-Day Rlng				59689	
9/27/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	25.93	0.034	9.13	0.012
1	0.093	26.41	0.037	10.62	0.012
2	0.088	25.22	0.026	7.52	0.012
3	0.09	26.37	0.028	8.2	0.012
4	0.087	25.48	0.027	7.9	0.012
5	0.087	26.99	0.03	9.19	0.012
6	0.081	25.89	0.021	6.67	0.012
7	0.086	24.74	0.024	6.96	0.012
8	0.09	25.76	0.027	7.85	0.012
9	0.089	26.89	0.031	9.43	0.012
10	0.087	24.7	0.026	7.51	0.012
11	0.092	25.77	0.028	7.66	0.012
12	0.093	26.16	0.023	6.38	0.012
13	0.092	26.12	0.033	9.29	0.012
14	0.092	26.44	0.03	8.61	0.012
15	0.093	26.51	0.028	8.09	0.012
16	0.092	24.95	0.021	5.74	0.012
17	0.092	26.48	0.033	9.39	0.012
18	0.089	24.92	0.022	6.26	0.012
19	0.094	26.46	0.025	7.07	0.012
20	0.092	25.98	0.033	9.31	0.012
21	0.094	26.44	0.03	8.48	0.012
22	0.093	25.52	0.027	7.59	0.012
23	0.093	26.07	0.033	9.17	0.012
Average	0.091		0.028		0.012
Total		622.2		194.02	
30-Day Rlng	0.091		0.029		
365-Day Rlng				59671	

9/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	25.64	0.027	7.31	0.012
1	0.099	27.13	0.034	9.23	0.012
2	0.093	25.67	0.031	8.53	0.012
3	0.094	26.57	0.033	9.26	0.012
4	0.094	26.22	0.03	8.42	0.012
5	0.089	26.41	0.029	8.76	0.012
6	0.083	24.82	0.021	6.39	0.013
7	0.091	25.84	0.023	6.57	0.012
8	0.091	26.17	0.027	7.76	0.012
9	0.095	26.56	0.032	8.89	0.012
10	0.093	25.75	0.016	4.53	0.012
11	0.09	26.11	0.027	7.69	0.012
12	0.091	25.87	0.016	4.57	0.012
13	0.093	25.27	0.014	3.88	0.012
14	0.098	26.41	0.031	8.48	0.013
15	0.09	26.35	0.033	9.57	0.012
16	0.098	25.04	0.029	7.44	0.013
17	0.099	26.29	0.019	4.93	0.012
18	0.096	26.27	0.023	6.31	0.012
19	0.094	26.08	0.032	8.82	0.012
20	0.093	25.24	0.031	8.29	0.012
21	0.097	26.13	0.034	9.05	0.012
22	0.092	25.02	0.035	9.44	0.012
23	0.095	25.59	0.022	5.95	0.012
Average	0.093		0.027		0.012
Total		622.45		180.07	
30-Day Rlng	0.091		0.029		
365-Day Rlng				59664	

9/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	26.11	0.034	9.19	0.012
1	0.091	25.31	0.031	8.63	0.012
2	0.09	26.32	0.032	9.48	0.012
3	0.088	25.69	0.029	8.51	0.012
4	0.091	25.78	0.028	7.84	0.012
5	0.094	26.73	0.032	9.05	0.013
6	0.09	27.07	0.03	8.94	0.013
7	0.09	25.18	0.019	5.21	0.013
8	0.094	25.8	0.028	7.51	0.013
9	0.091	24.86	0.028	7.69	0.012
10	0.096	25.73	0.028	7.52	0.013
11	0.098	26.01	0.033	8.7	0.013
12	0.096	25.93	0.032	8.62	0.013
13	0.097	25.87	0.032	8.53	0.013
14	0.096	25.52	0.033	8.87	0.013

15	0.097	25.92	0.032	8.51	0.013
16	0.098	25.91	0.017	4.42	0.013
17	0.096	26.18	0.029	7.81	0.012
18	0.091	25.28	0.025	6.87	0.012
19	0.091	25.06	0.033	9.16	0.012
20	0.091	25.39	0.028	7.9	0.012
21	0.091	25.45	0.031	8.63	0.012
22	0.094	25.58	0.031	8.55	0.012
23	0.097	26.61	0.031	8.45	0.012
Average	0.093		0.029		0.012
Total		619.29		194.59	
30-Day Rlng	0.092		0.029		
365-Day Rlng				59652	

9/30/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	25.37	0.031	8.58	0.012
1	0.094	25.25	0.029	7.91	0.012
2	0.096	25.76	0.03	8.15	0.012
3	0.097	26.18	0.033	8.98	0.012
4	0.096	25.65	0.031	8.21	0.012
5	0.097	26.94	0.035	9.67	0.012
6	0.094	29.57	0.02	6.4 OOC	
7	0.098	25.81	0.027	7.02	0.012
8	0.096	26.11	0.024	6.59	0.012
9	0.095	25.61	0.021	5.74	0.012
10	0.096	25.43	0.029	7.64	0.012
11	0.094	26.2	0.035	9.78	0.012
12	0.092	25.42	0.022	6.05	0.012
13	0.095	25.56	0.034	8.98	0.012
14	0.098	26.41	0.032	8.75	0.012
15	0.098	27.08	0.032	8.82	0.012
16	0.09	24.85	0.03	8.18	0.012
17	0.095	25.96	0.031	8.55	0.012
18	0.091	24.98	0.031	8.48	0.012
19	0.092	25.31	0.023	6.33	0.012
20	0.093	26.01	0.034	9.64	0.012
21	0.095	26.37	0.028	7.86	0.012
22	0.089	24.51	0.025	6.73	0.012
23	0.096	26.71	0.031	8.62	0.012
Average	0.095		0.029		0.012
Total		623.05		191.66	
30-Day Rlng	0.092		0.029		
365-Day Rlng				59667	

10/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	25.37	0.035	9.64	0.012
1	0.094	25.57	0.028	7.7	0.012

2	0.093	25.34	0.032	8.56	0.012
3	0.095	26.07	0.028	7.73	0.012
4	0.094	25.8	0.029	8.01	0.012
5	0.089	25.02	0.031	8.71	0.012
6	0.088	26.25	0.024	7.34	0.012
7	0.093	26.42	0.025	7	0.012
8	0.093	26.25	0.028	7.98	0.012
9	0.091	25.1	0.029	7.93	0.012
10	0.096	26.62	0.034	9.54	0.012
11	0.092	26.2	0.031	8.71	0.013
12	0.091	25.59	0.029	8.04	0.012
13	0.092	25.23	0.027	7.41	0.012
14	0.096	26.3	0.026	7.13	0.012
15	0.096	26.47	0.033	9.04	0.012
16	0.094	25.11	0.032	8.66	0.012
17	0.095	26.3	0.032	8.84	0.012
18	0.094	26.32	0.029	8.17	0.012
19	0.094	26.14	0.032	8.94	0.012
20	0.095	25.99	0.03	8.22	0.012
21	0.094	26.05	0.032	8.78	0.012
22	0.093	25.55	0.031	8.41	0.012
23	0.093	25.13	0.026	6.96	0.012
Average	0.093		0.03		0.012
Total		620.19		197.45	
30-Day Rlng	0.092		0.029		
365-Day Rlng				59683	

10/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	25.35	0.03	8.17	0.012
1	0.1	26.98	0.033	8.83	0.012
2	0.091	25.18	0.034	9.3	0.012
3	0.095	26.18	0.033	9.16	0.012
4	0.091	25.87	0.028	7.93	0.012
5	0.088	26.46	0.026	7.7	0.012
6	0.084	26.39	0.029	9.04	0.012
7	0.086	25.43	0.027	7.87	0.012
8	0.091	26.46	0.031	9.02	0.012
9	0.093	26.37	0.027	7.62	0.012
10	0.092	25.04	0.03	8.07	0.012
11	0.094	25.84	0.028	7.61	0.012
12	0.095	26.45	0.036	10.08	0.012
13	0.093	26.14	0.034	9.56	0.012
14	0.094	26.27	0.028	7.8	0.012
15	0.091	25.85	0.03	8.55	0.012
16	0.095	26.04	0.033	8.99	0.012
17	0.092	25.87	0.031	8.62	0.012
18	0.09	25.74	0.03	8.59	0.012

19	0.092	26.04	0.029	8.21	0.012
20	0.09	25.66	0.029	8.26	0.012
21	0.092	26	0.032	8.99	0.012
22	0.096	26.31	0.026	7.21	0.012
23	0.092	25.63	0.03	8.36	0.012
Average	0.092		0.03		0.012
Total		623.55		203.54	
30-Day Rlng	0.092		0.029		
365-Day Rlng				59690	

10/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	25.87	0.033	8.99	0.012
1	0.093	25.14	0.034	9.11	0.012
2	0.093	26.15	0.034	9.55	0.012
3	0.092	25.37	0.025	6.92	0.012
4	0.097	26.62	0.037	10.14	0.012
5	0.095	26.93	0.027	7.67	0.012
6	0.093	29.61	0.031	9.92	0.012
7	0.09	25.5	0.027	7.62	0.012
8	0.093	26.4	0.029	8.33	0.012
9	0.095	26.67	0.033	9.21	0.012
10	0.092	25.86	0.03	8.35	0.012
11	0.093	26.02	0.03	8.37	0.012
12	0.091	26.34	0.03	8.57	0.012
13	0.092	25.87	0.031	8.7	0.012
14	0.092	25.54	0.033	9.11	0.012
15	0.095	26.69	0.031	8.62	0.012
16	0.093	25.19	0.024	6.44	0.012
17	0.092	25.87	0.026	7.28	0.012
18	0.092	26.26	0.03	8.57	0.012
19	0.09	25.57	0.032	9.09	0.012
20	0.094	26.29	0.03	8.4	0.012
21	0.093	26.73	0.032	9.21	0.012
22	0.088	24.78	0.03	8.29	0.012
23	0.091	25.71	0.028	7.79	0.012
Average	0.093		0.03		0.012
Total		626.98		204.25	
30-Day Rlng	0.092		0.029		
365-Day Rlng				59699	

10/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	26.04	0.033	9.26	0.012
1	0.094	25.36	0.03	8.13	0.012
2	0.092	25.25	0.029	8.02	0.012
3	0.094	25.85	0.031	8.37	0.012
4	0.095	25.98	0.034	9.2	0.012
5	0.094	26.04	0.036	9.93	0.012

6	0.098	29.52	0.027	8.08	0.012
7	0.092	27.97	0.031	9.77	0.012
8	0.088	25.64	0.031	9.12	0.012
9	0.09	26.24	0.03	8.77	0.012
10	0.093	26.02	0.03	8.53	0.012
11	0.092	25.97	0.028	7.92	0.012
12	0.092	26.36	0.033	9.47	0.012
13	0.089	25.22	0.03	8.43	0.012
14	0.094	26.28	0.031	8.58	0.012
15	0.094	26.85	0.031	8.94	0.012
16	0.093	24.83	0.032	8.65	0.012
17	0.092	25.07	0.03	8.17	0.012
18	0.093	26.13	0.029	7.97	0.012
19	0.094	26.26	0.034	9.33	0.012
20	0.093	25.48	0.03	8.12	0.012
21	0.094	25.98	0.031	8.69	0.012
22	0.094	26.38	0.033	9.2	0.012
23	0.09	26.12	0.027	7.79	0.012
Average	0.093		0.031		0.012
Total		626.84		208.44	
30-Day Rlng	0.092		0.029		
365-Day Rlng				59716	

10/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.06	0.031	8.81	0.012
1	0.09	25.41	0.032	8.95	0.012
2	0.092	25.79	0.029	8.17	0.013
3	0.094	26.66	0.031	8.76	0.012
4	0.088	23.96	0.03	8.3	0.012
5	0.095	26.54	0.026	7.27	0.014
6	0.095	28.33	0.028	8.21	0.013
7	0.091	25.72	0.035	9.98	0.012
8	0.092	26.04	0.026	7.3	0.012
9	0.094	25.77	0.025	6.99	0.012
10	0.095	25.86	0.033	9.02	0.012
11	0.094	25.7	0.029	8.08	0.013
12	0.093	25.29	0.031	8.4	0.013
13	0.098	26.62	0.027	7.25	0.013
14	0.096	25.86	0.033	8.84	0.013
15	0.096	26.89	0.03	8.49	0.012
16	0.102	26.43	0.034	8.82	0.012
17	0.099	25.47	0.03	7.75	0.012
18	0.098	26.38	0.034	9.25	0.012
19	0.098	25.93	0.031	8.14	0.012
20	0.097	26.24	0.033	8.93	0.014
21	0.095	26.05	0.032	8.85	0.016
22	0.096	26.33	0.027	7.46	0.017

	23	0.097	25.59	0.032	8.38	0.017
Average		0.095		0.03		0.013
Total			624.92		200.4	
30-Day Rlng		0.092		0.029		
365-Day Rlng					59916	

10/6/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.101	26.53	0.038	10.17	0.017
1	0.096	25.16	0.03	7.98	0.018
2	0.102	26.68	0.033	8.7	0.017
3	0.097	25.59	0.032	8.48	0.017
4	0.102	26.35	0.033	8.5	0.017
5	0.098	25.98	0.033	8.71	0.018
6	0.087	23.88	0.037	10.16	0.013
7	0.097	25.12	0.031	7.95	0.012
8	0.099	26	0.032	8.36	0.012
9	0.1	25.81	0.033	8.5	0.012
10	0.102	25.72	0.033	8.49	0.012
11	0.094	25.77	0.033	9.03	0.012
12	0.097	26.47	0.035	9.5	0.012
13	0.093	25.46	0.033	8.82	0.012
14	0.097	25.49	0.031	8.04	0.012
15	0.099	26.62	0.029	7.74	0.012
16	0.097	25.81	0.028	7.42	0.012
17	0.094	25.93	0.031	8.54	0.012
18	0.094	25.55	0.031	8.6	0.012
19	0.094	25.14	0.026	7.05	0.012
20	0.1	26.96	0.034	9.08	0.012
21	0.092	25.46	0.031	8.64	0.012
22	0.091	25.78	0.032	9.05	0.012
23	0.092	25.84	0.029	8.12	0.012
Average	0.096		0.032		0.013
Total		619.1		205.63	
30-Day Rlng	0.093		0.029		
365-Day Rlng				60122	

10/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.096	26.05	0.033	8.92	0.012
1	0.098	25.72	0.035	9.15	0.012
2	0.097	26.23	0.032	8.78	0.012
3	0.099	25.93	0.03	7.86	0.012
4	0.097	26.42	0.033	9.02	0.012
5	0.087	26.49	0.027	8.18	0.012
6	0.059	19.01	0.023	7.5	0.013
7	0.091	25.85	0.021	6.33	0.012
8	0.103	25.73	0.027	6.85	0.012
9	0.105	27.23	0.032	8.37	0.013

10	0.091	25.42	0.022	6.09	0.012
11	0.092	26.93	0.035	10.1	0.012
12	0.092	23.58	0.018	4.62	0.013
13	0.107	25.36	0.032	7.64	0.012
14	0.103	27.12	0.034	8.84	0.012
15	0.094	26.35	0.027	7.46	0.012
16	0.093	25.51	0.03	8.26	0.012
17	0.094	26.45	0.028	7.82	0.012
18	0.091	25.69	0.034	9.44	0.012
19	0.095	25.39	0.031	8.41	0.012
20	0.096	26.39	0.034	9.33	0.012
21	0.093	25.55	0.032	8.72	0.012
22	0.095	25.96	0.028	7.67	0.012
23	0.093	25.91	0.032	8.89	0.012
Average	0.094		0.03		0.012
Total		616.27		194.25	
30-Day Rlng	0.093		0.029		
365-Day Rlng				60301	

10/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	26.33	0.026	7.29	0.012
1	0.091	25.51	0.029	8.32	0.012
2	0.088	25.46	0.029	8.18	0.012
3	0.087	26.64	0.029	8.94	0.012
4	0.089	25	0.028	7.75	0.012
5	0.094	26.95	0.029	8.22	0.012
6	0.089	26.33	0.035	10.55	0.012
7	0.092	25	0.026	7.09	0.012
8	0.097	26.31	0.033	9.08	0.012
9	0.094	25.48	0.026	7.04	0.012
10	0.096	26.56	0.032	8.68	0.012
11	0.091	25.58	0.029	8.08	0.012
12	0.094	26.56	0.025	7.15	0.012
13	0.089	25.04	0.029	8.28	0.012
14	0.094	26.48	0.029	8.05	0.012
15	0.091	25.56	0.034	9.68	0.012
16	0.093	25.63	0.029	7.95	0.012
17	0.094	25.99	0.029	8.08	0.012
18	0.093	25.15	0.031	8.32	0.012
19	0.098	26.37	0.037	9.97	0.012
20	0.094	25.55	0.032	8.81	0.012
21	0.098	26.84	0.03	8.29	0.012
22	0.108	21.77	0.035	7.15	0.012
23	0.114	22.54	0.046	8.96	0.012
Average	0.094		0.031		0.012
Total		614.63		199.91	
30-Day Rlng	0.093		0.029		

365-Day Rlng 60327

10/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.112	22.34	0.04	7.86	0.012
1	0.105	20.71	0.028	5.46	0.012
2	0.099	19.86	0.031	6.19	0.012
3	0.101	20.13	0.031	6.3	0.012
4	0.098	19.49	0.029	5.84	0.012
5	0.106	21.91	0.035	7.28	0.012
6	0.105	21.53	0.036	7.29	0.012
7	0.098	23.1	0.031	7.49	0.012
8	0.085	24.57	0.034	9.82	0.012
9	0.089	25.78	0.031	9.09	0.012
10	0.092	25.76	0.035	9.84	0.013
11	0.092	26.18	0.031	8.87	0.012
12	0.089	25.83	0.038	10.94	0.012
13	0.093	26.48	0.029	8.23	0.012
14	0.09	26.19	0.03	8.79	0.012
15	0.089	25.86	0.036	10.59	0.012
16	0.094	26.31	0.031	8.57	0.013
17	0.091	26.14	0.034	9.62	0.013
18	0.088	24.85	0.029	8.15	0.013
19	0.093	26.42	0.029	8.18	0.012
20	0.09	26.46	0.031	9.12	0.012
21	0.09	25.75	0.026	7.32	0.012
22	0.091	25.73	0.033	9.27	0.012
23	0.09	26.02	0.028	8.04	0.012
Average	0.095		0.032		0.012
Total		583.4		198.15	
30-Day Rlng	0.093		0.029		
365-Day Rlng				60312	

10/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	24.99	0.031	8.96	0.012
1	0.093	26.53	0.028	8.03	0.012
2	0.091	25.99	0.033	9.58	0.012
3	0.09	26	0.033	9.54	0.012
4	0.086	23.77	0.026	7.27	0.013
5	0.092	26.43	0.031	8.92	0.012
6	0.087	25.73	0.035	10.33	0.012
7	0.09	25.83	0.047	13.37	0.012
8	0.095	25.82	0.033	8.85	0.013
9	0.089	25.98	0.042	12.42	0.013
10	0.096	27.11	0.026	7.45	0.013
11	0.094	25.65	0.031	8.39	0.013
12	0.092	27.4	0.026	7.67	0.013
13	0.086	25.61	0.036	10.75	0.012

14	0.092	24.79	0.036	9.59	0.014
15	0.099	26.78	0.023	6.23	0.013
16	0.097	26.38	0.021	5.81	0.013
17	0.093	26.02	0.029	8.12	0.013
18	0.092	24.96	0.041	11.33	0.013
19	0.095	25.55	0.028	7.49	0.013
20	0.096	26.06	0.018	5.01	0.013
21	0.095	25.64	0.027	7.41	0.013
22	0.096	25.88	0.026	6.97	0.013
23	0.094	25.54	0.026	7.2	0.013
Average	0.092		0.031		0.013
Total		620.44		206.69	
30-Day Rlng	0.093		0.029		
365-Day Rlng				60305	

10/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	25.7	0.029	7.84	0.013
1	0.093	25.33	0.031	8.51	0.013
2	0.091	24.99	0.034	9.32	0.013
3	0.098	26.84	0.032	8.81	0.013
4	0.087	24.99	0.032	9.22	0.013
5	0.093	27.11	0.025	7.19	0.013
6	0.088	27.58	0.026	8.18	0.013
7	0.087	25.13	0.021	6.24	0.013
8	0.089	25.32	0.02	5.59	0.013
9	0.094	26.9	0.025	7.1	0.013
10	0.091	25.35	0.024	6.61	0.013
11	0.097	25.87	0.029	7.63	0.013
12	0.097	25.79	0.024	6.33	0.013
13	0.095	26.28	0.034	9.49	0.013
14	0.092	25.74	0.028	7.86	0.013
15	0.092	24.55	0.023	6.19	0.013
16	0.106	26.63	0.021	5.32	0.012
17	0.103	25.54	0.033	8.2	0.013
18	0.108	26.05	0.031	7.54	0.013
19	0.099	24.12	0.028	6.9	0.013
20	0.098	25.78	0.028	7.33	0.013
21	0.092	25.78	0.037	10.27	0.013
22	0.102	28.07	0.022	5.99	0.013
23	0.095	26.27	0.024	6.69	0.013
Average	0.095		0.028		0.013
Total		621.71		180.35	
30-Day Rlng	0.093		0.029		
365-Day Rlng				60272	

10/12/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.1	26.62	0.027	7.13	0.013

1	0.097	25.5	0.026	6.81	0.013
2	0.098	26.26	0.029	7.66	0.013
3	0.094	24.25	0.03	7.78	0.013
4	0.092	24.36	0.031	8.2	0.013
5	0.096	26.41	0.028	7.6	0.013
6	0.094	26.03	0.03	8.46	0.013
7	0.105	26.7	0.025	6.41	0.013
8	0.101	25.07	0.026	6.54	0.013
9	0.107	26.58	0.036	8.81	0.013
10	0.104	26.49	0.035	8.93	0.012
11	0.1	25.66	0.031	7.86	0.012
12	0.099	24.87	0.023	5.87	0.013
13	0.098	25.42	0.031	8.16	0.013
14	0.099	27.07	0.032	8.82	0.013
15	0.094	25.35	0.042	11.28	0.013
16	0.098	26.67	0.04	10.82	0.013
17	0.093	25.64	0.038	10.47	0.013
18	0.092	25.02	0.037	10.05	0.013
19	0.093	25.39	0.028	7.53	0.013
20	0.096	26.4	0.025	6.86	0.013
21	0.093	25.1	0.034	9.09	0.013
22	0.092	25.37	0.033	9.2	0.013
23	0.095	26.03	0.027	7.38	0.013
Average	0.097		0.031		0.013
Total		618.26		197.72	
30-Day Rlng	0.093		0.029		
365-Day Rlng				60261	

10/13/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	25.69	0.039	10.8	0.013
1	0.091	25.35	0.019	5.24	0.013
2	0.095	25.69	0.028	7.67	0.013
3	0.095	25.72	0.027	7.33	0.013
4	0.095	25.71	0.032	8.59	0.013
5	0.094	26.85	0.039	11.23	0.013
6	0.085	24.85	0.027	7.83	0.013
7	0.089	26.15	0.025	7.27	0.013
8	0.09	25.75	0.03	8.51	0.013
9	0.093	26.12	0.027	7.63	0.013
10	0.094	25.39	0.026	6.92	0.013
11	0.1	25.99	0.026	6.77	0.013
12	0.099	26.46	0.028	7.54	0.013
13	0.093	26.27	0.029	8.29	0.013
14	0.096	25.39	0.027	7.18	0.013
15	0.1	25.59	0.027	6.98	0.013
16	0.096	25.59	0.025	6.67	0.012
17	0.097	26.68	0.026	7.14	0.012

18	0.095	25.91	0.026	7.22	0.013
19	0.093	25.79	0.027	7.55	0.013
20	0.093	25.87	0.029	8.1	0.013
21	0.094	26.57	0.026	7.39	0.013
22	0.09	24.98	0.024	6.62	0.013
23	0.103	10.85	0.023	2.3	0.021
Average	0.094		0.028		0.013
Total		605.21		178.77	
30-Day Rlng	0.093		0.029		
365-Day Rlng				60212	

10/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng	0.093		0.029		
365-Day Rlng				60002	

10/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down

5	Down	Down	Down	Down	Down
6	Down	Down	Down	Down	Down
7	Down	Down	Down	Down	Down
8	Down	Down	Down	Down	Down
9	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.093		0.029	
365-Day Rlng					59791

10/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Down	Down	Down	Down	Down
3	Maint	Maint	Maint	Maint	Maint
4	Maint	Maint	Maint	Maint	Maint
5	Maint	Maint	Maint	Maint	Maint
6	Maint	Maint	Maint	Maint	Maint
7	Maint	Maint	Maint	Maint	Maint
8	Maint	Maint	Maint	Maint	Maint
9	Maint	Maint	Maint	Maint	Maint
10	Maint	Maint	Maint	Maint	Maint
11	0.199	46.06	0.019	4.32	0.02
12	0.051	12.39	0.037	8.9	0.014
13	0.075	20.6	0.023	6.36	0.012
14	0.093	26.45	0.024	6.96	0.012
15	0.093	26.55	0.022	6.35	0.012
16	0.092	25.29	0.026	7.31	0.012
17	0.095	26.32	0.028	7.66	0.012
18	0.085	23.5	0.03	8.33	0.012
19	0.097	26.21	0.045	12.1	0.013
20	0.096	25.86	0.025	6.73	0.013
21	0.095	26.2	0.017	4.75	0.013

	22	0.093	25.28	0.026	7.2	0.013
	23	0.098	26.25	0.023	6.07	0.013
Average		0.097		0.027		0.013
Total			336.96		93.04	
30-Day Rlng		0.093		0.029		
365-Day Rlng					59663	

10/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	26.36	0.03	8.28	0.013
1	0.091	25.48	0.026	7.41	0.013
2	0.094	25.92	0.024	6.57	0.013
3	0.092	25.93	0.027	7.66	0.013
4	0.09	25.31	0.025	7.1	0.013
5	0.092	26.45	0.028	8.17	0.013
6	0.088	26.73	0.026	7.73	0.013
7	0.091	26.38	0.023	6.58	0.013
8	0.092	26.12	0.027	7.57	0.013
9	0.084	26.01	0.024	7.53	0.013
10	0.087	24.13	0.022	6.3	0.013
11	0.114	24.92	0.018	3.85	0.015
12	0.117	25.35	0.019	4.1	0.015
13	0.115	24.68	0.018	3.84	0.016
14	0.115	24.66	0.018	3.85	0.016
15	0.111	24.92	0.023	5.14	0.015
16	0.096	23.96	0.021	5.36	0.014
17	0.099	26.61	0.026	6.89	0.013
18	0.096	26.28	0.027	7.47	0.013
19	0.092	25.18	0.022	6.01	0.013
20	0.095	25.93	0.026	7.02	0.013
21	0.087	23.97	0.026	7.12	0.013
22	0.091	26.16	0.027	7.83	0.013
23	0.094	25.71	0.024	6.61	0.013
Average	0.097		0.024		0.014
Total		613.15		155.99	
30-Day Rlng	0.093		0.029		
365-Day Rlng				59609	

10/18/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	26.09	0.028	7.83	0.013
1	0.09	25.07	0.029	8.07	0.013
2	0.091	25.87	0.031	8.86	0.013
3	0.093	26.17	0.028	7.91	0.013
4	0.094	25.84	0.02	5.65	0.013
5	0.095	26.61	0.025	7.13	0.013
6	0.085	25.19	0.016	4.62	0.013
7	0.089	26.34	0.024	7.16	0.013
8	0.091	25.93	0.026	7.39	0.013

9	0.091	25.87	0.023	6.49	0.013
10	0.093	26.13	0.031	8.56	0.013
11	0.093	26.08	0.023	6.56	0.013
12	0.093	26.31	0.024	6.88	0.013
13	0.09	25.77	0.024	6.78	0.013
14	0.094	26.08	0.021	5.76	0.013
15	0.092	26.06	0.028	8	0.013
16	0.094	26.56	0.024	6.9	0.013
17	0.09	26.06	0.024	6.98	0.012
18	0.09	25.94	0.033	9.38	0.013
19	0.089	25.5	0.026	7.4	0.013
20	0.092	26.24	0.022	6.41	0.013
21	0.085	25	0.029	8.51	0.012
22	0.09	25.73	0.025	7.01	0.013
23	0.088	25.65	0.025	7.35	0.013
Average	0.091		0.025		0.013
Total		622.09		173.59	
30-Day Rlng	0.093		0.029		
365-Day Rlng				59569	

10/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.65	0.041	11.89	0.013
1	0.088	25.53	0.021	6.03	0.013
2	0.089	25.29	0.022	6.13	0.013
3	0.09	25.38	0.026	7.45	0.013
4	0.091	26.14	0.024	7	0.013
5	0.093	27.56	0.034	10.02	0.012
6	0.086	25.26	0.034	10.18	0.013
7	0.091	25.9	0.033	9.21	0.013
8	0.09	24.54	0.021	5.77	0.014
9	0.086	27.04	0.028	8.65	0.013
10	0.085	25.77	0.025	7.69	0.013
11	0.094	25.85	0.023	6.42	0.013
12	0.089	25.74	0.028	8.3	0.013
13	0.089	26.32	0.032	9.45	0.013
14	0.092	26.32	0.017	4.74	0.013
15	0.091	26.23	0.015	4.22	0.013
16	0.092	26.11	0.016	4.64	0.013
17	0.091	26.35	0.023	6.75	0.013
18	0.087	25.28	0.033	9.67	0.013
19	0.088	25.28	0.041	11.61	0.013
20	0.065	17.93	0.019	5.3	0.013
21	0.09	25.44	0.02	5.65	0.013
22	0.092	25.92	0.024	6.64	0.013
23	0.088	24.73	0.024	6.69	0.013
Average	0.089		0.026		0.013
Total		611.56		180.1	

30-Day Rlng	0.093	0.029	
365-Day Rlng			59542
10/20/2020			
Hour			
	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu
0	0.093	25.83	0.031
1	0.085	24.3	0.036
2	0.093	25.81	0.039
3	0.095	26.5	0.029
4	0.091	25.91	0.036
5	0.092	27.22	0.034
6	0.078	24.22	0.024
7	0.085	26.44	0.027
8	0.087	25.77	0.031
9	0.087	26.69	0.03
10	0.085	26.38	0.026
11	0.088	25.22	0.026
12	0.09	26.79	0.023
13	0.09	25.87	0.036
14	0.091	26.86	0.025
15	0.088	25.34	0.024
16	0.094	26.81	0.021
17	0.09	25.56	0.022
18	0.091	26.22	0.033
19	0.089	26.08	0.022
20	0.09	26.18	0.025
21	0.09	25.49	0.04
22	0.092	25.76	0.023
23	0.094	26.62	0.026
Average	0.09		0.029
Total		623.87	199.45
30-Day Rlng	0.093	0.029	
365-Day Rlng			59555
10/21/2020			
Hour			
	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu
0	0.09	24.6	0.037
1	0.092	25.46	0.029
2	0.091	25.76	0.029
3	0.09	25.62	0.022
4	0.089	25.77	0.025
5	0.087	25.37	0.023
6	0.087	26.87	0.028
7	0.088	25.97	0.023
8	0.09	25.7	0.021
9	0.088	26.77	0.024
10	0.086	25.5	0.017
11	0.095	26.43	0.021
12	0.093	26.12	0.027

13	0.091	25.96	0.024	6.83	0.013
14	0.092	25.6	0.025	7.01	0.013
15	0.094	26.48	0.029	8.04	0.013
16	0.092	25.85	0.026	7.17	0.013
17	0.092	26.22	0.026	7.27	0.013
18	0.089	25.7	0.024	6.91	0.013
19	0.088	25.42	0.032	9.42	0.012
20	0.087	25.01	0.04	11.52	0.013
21	0.092	25.87	0.032	8.89	0.013
22	0.092	25.89	0.019	5.34	0.012
23	0.089	25.09	0.022	6.23	0.013
Average	0.09		0.026		0.013
Total		619.03		178.88	
30-Day Rlng	0.093		0.029		
365-Day Rlng				59533	

10/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.106	21.57	0.027	5.57	0.012
1	0.11	21.46	0.037	7.11	0.012
2	0.107	20	0.036	6.78	0.013
3	0.114	21.83	0.033	6.35	0.012
4	0.113	21.33	0.038	7.22	0.012
5	0.113	21.41	0.036	6.83	0.012
6	0.11	21.23	0.034	6.46	0.012
7	0.097	30.01	0.026	7.83	0.013
8	0.09	26.72	0.029	8.5	0.012
9	0.082	27.28	0.021	7.02	0.012
10	0.076	24.08	0.023	7.39	0.012
11	0.088	25.52	0.028	8.14	0.012
12	0.086	27.19	0.02	6.46	0.012
13	0.084	25.71	0.02	6.32	0.012
14	0.089	25.71	0.023	6.58	0.012
15	0.092	27.21	0.034	10.08	0.012
16	0.088	25.11	0.031	9.01	0.012
17	0.09	26.1	0.025	7.21	0.012
18	0.09	26.41	0.026	7.46	0.012
19	0.089	26.39	0.021	6.06	0.012
20	0.088	25.35	0.022	6.26	0.012
21	0.086	25.12	0.025	7.34	0.012
22	0.09	25.93	0.034	9.94	0.012
23	0.089	26.31	0.035	10.31	0.012
Average	0.094		0.029		0.012
Total		594.98		178.23	
30-Day Rlng	0.093		0.029		
365-Day Rlng				59501	

10/23/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
------	--------------	---------	--------------	---------	-------------

0	0.088	24.9	0.037	10.57	0.013
1	0.089	26.41	0.028	8.22	0.012
2	0.089	26.17	0.021	6.3	0.012
3	0.085	25.97	0.023	7.03	0.012
4	0.092	26.96	0.026	7.47	0.012
5	0.087	26.32	0.023	6.84	0.012
6	0.084	25.36	0.021	6.42	0.012
7	0.087	25.75	0.024	7.12	0.012
8	0.09	25.97	0.023	6.67	0.012
9	0.089	25.83	0.026	7.56	0.012
10	0.089	26.29	0.023	6.79	0.012
11	0.087	25.43	0.02	5.77	0.012
12	0.083	26.59	0.024	7.84	0.012
13	0.08	25.72	0.027	8.78	0.012
14	0.088	25.61	0.026	7.43	0.012
15	0.089	26.25	0.029	8.53	0.012
16	0.089	26.3	0.029	8.56	0.012
17	0.087	25.66	0.022	6.44	0.012
18	0.089	25.52	0.024	6.79	0.012
19	0.09	25.9	0.034	9.83	0.012
20	0.093	27.38	0.025	7.33	0.012
21	0.088	25.39	0.024	6.99	0.012
22	0.09	25.64	0.023	6.4	0.012
23	0.092	26.69	0.03	8.73	0.012
Average	0.088		0.026		0.012
Total		624.01		180.41	
30-Day Rlng	0.093		0.028		
365-Day Rlng				59480	

10/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	25.2	0.025	7.12	0.013
1	0.088	25.9	0.027	7.93	0.012
2	0.092	26	0.023	6.59	0.013
3	0.094	26.28	0.031	8.79	0.013
4	0.092	25.97	0.035	10.01	0.013
5	0.094	26.61	0.022	6.17	0.013
6	0.084	27.03	0.023	7.47	0.013
7	0.085	26.18	0.021	6.51	0.013
8	0.089	26.75	0.026	7.69	0.013
9	0.083	25.94	0.018	5.68	0.013
10	0.081	25.35	0.021	6.55	0.013
11	0.092	26.42	0.021	5.95	0.012
12	0.091	25.83	0.027	7.65	0.013
13	0.085	26.3	0.023	7.24	0.012
14	0.091	25.97	0.024	6.99	0.013
15	0.089	25.41	0.028	8.06	0.012
16	0.095	26.37	0.024	6.7	0.013

17	0.092	26.11	0.024	6.74	0.012
18	0.091	26.19	0.023	6.62	0.013
19	0.092	26.24	0.026	7.43	0.012
20	0.093	26.12	0.027	7.69	0.012
21	0.091	26.07	0.023	6.52	0.013
22	0.09	26.16	0.025	7.18	0.012
23	0.09	26.26	0.026	7.54	0.012
Average	0.09		0.025		0.013
Total		626.66		172.82	
30-Day Rlng	0.093		0.028		
365-Day Rlng				59438	

10/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.7	0.02	5.7	0.012
1	0.087	25	0.023	6.47	0.012
2	0.092	26.07	0.026	7.44	0.013
3	0.093	26.78	0.029	8.41	0.013
4	0.098	25.25	0.034	8.66	0.012
5	0.103	26.23	0.022	5.61	0.012
6	0.097	26.5	0.025	6.82	0.012
7	0.102	25.79	0.017	4.18	0.012
8	0.102	25.7	0.024	6.02	0.012
9	0.105	26.41	0.03	7.55	0.012
10	0.101	25.62	0.028	7.03	0.012
11	0.1	25.29	0.025	6.24	0.012
12	0.105	26.04	0.032	7.86	0.012
13	0.106	25.7	0.029	7.03	0.013
14	0.106	25.92	0.03	7.2	0.013
15	0.107	26.48	0.03	7.34	0.012
16	0.107	25.72	0.03	7.11	0.012
17	0.105	25.75	0.029	7.13	0.012
18	0.107	26.34	0.031	7.58	0.012
19	0.103	24.98	0.024	5.95	0.012
20	0.105	26.44	0.032	8.11	0.012
21	0.103	25.73	0.025	6.28	0.013
22	0.105	26.1	0.027	6.78	0.013
23	0.104	26.62	0.032	8.17	0.012
Average	0.101		0.027		0.012
Total		622.16		166.67	
30-Day Rlng	0.093		0.028		
365-Day Rlng				59500	

10/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.101	25.71	0.026	6.69	0.013
1	0.103	25.95	0.033	8.37	0.012
2	0.103	26.23	0.027	6.86	0.012
3	0.106	25.79	0.028	6.81	0.013

4	0.105	25.83	0.028	6.78	0.013
5	0.107	26.27	0.028	6.97	0.013
6	0.102	27.75	0.033	9.08	0.012
7	0.096	25.05	0.024	6.3	0.013
8	0.103	26.42	0.028	7.27	0.012
9	0.103	26.16	0.032	8.18	0.012
10	0.103	25.43	0.023	5.66	0.013
11	0.102	25.62	0.026	6.6	0.012
12	0.107	25.86	0.032	7.62	0.013
13	0.105	26.16	0.03	7.43	0.013
14	0.103	26.21	0.03	7.57	0.012
15	0.103	25.47	0.026	6.45	0.013
16	0.102	25.5	0.027	6.84	0.012
17	0.104	26.04	0.031	7.85	0.012
18	0.102	25.91	0.028	7.17	0.013
19	0.104	26.48	0.028	7.09	0.012
20	0.103	25.8	0.033	8.25	0.013
21	0.103	25.89	0.026	6.55	0.013
22	0.101	25.28	0.026	6.55	0.013
23	0.102	26.16	0.031	7.91	0.012
Average	0.103		0.029		0.013
Total		622.97		172.85	
30-Day Rlng	0.094		0.028		
365-Day Rlng				59592	

10/27/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.102	25.82	0.028	6.97	0.013
1	0.102	25.29	0.027	6.73	0.013
2	0.103	25.99	0.028	7.08	0.013
3	0.104	26.02	0.03	7.38	0.013
4	0.108	26.7	0.028	6.92	0.013
5	0.109	25.07	0.028	6.5	0.012
6	0.111	20.48	0.027	4.93	0.013
7	0.114	19.7	0.045	7.7	0.013
8	0.116	21.35	0.043	7.83	0.013
9	0.113	20.21	0.035	6.32	0.013
10	0.114	19.51	0.046	7.85	0.013
11	0.113	19.29	0.034	5.87	0.013
12	0.115	19.17	0.053	8.87	0.012
13	0.112	17.89	0.037	5.98	0.012
14	0.113	19.18	0.042	7.31	0.012
15	0.114	20.09	0.038	6.78	0.012
16	0.115	20.09	0.051	8.86	0.012
17	0.113	20.18	0.035	6.28	0.012
18	0.107	19.07	0.038	6.66	0.013
19	0.085	22.49	0.017	4.52	0.013
20	0.091	25.24	0.028	7.88	0.012

21	0.095	25.53	0.029	7.73	0.013
22	0.088	25.82	0.031	9.09	0.013
23	0.096	26.77	0.03	8.39	0.013
Average	0.106		0.035		0.013
Total		536.95		170.43	
30-Day Rlng	0.094		0.029		
365-Day Rlng				59587	

10/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	25.19	0.028	7.95	0.013
1	0.088	25.17	0.027	7.76	0.013
2	0.092	25.56	0.034	9.38	0.013
3	0.091	25.24	0.032	8.82	0.013
4	0.094	25.86	0.03	8.29	0.013
5	0.095	27.04	0.03	8.49	0.013
6	0.09	26.41	0.029	8.64	0.013
7	0.09	26.64	0.034	10.08	0.012
8	0.089	24.99	0.028	7.99	0.013
9	0.088	27.18	0.029	9.05	0.013
10	0.087	25.56	0.026	7.68	0.013
11	0.094	25.86	0.033	9.16	0.012
12	0.093	25.58	0.028	7.71	0.012
13	0.094	25.57	0.027	7.4	0.013
14	0.096	25.83	0.029	7.79	0.013
15	0.098	26.64	0.029	7.85	0.013
16	0.096	26.46	0.036	9.97	0.013
17	0.094	25.88	0.028	7.56	0.013
18	0.091	25.7	0.035	9.99	0.012
19	0.094	26.39	0.035	9.93	0.013
20	0.088	24.78	0.029	8.08	0.013
21	0.093	26.28	0.03	8.44	0.013
22	0.091	25.66	0.027	7.58	0.013
23	0.091	25.22	0.031	8.51	0.013
Average	0.092		0.03		0.013
Total		620.69		204.1	
30-Day Rlng	0.094		0.029		
365-Day Rlng				59590	

10/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	25.06	0.047	12.76	0.013
1	0.092	26.09	0.033	9.53	0.013
2	0.095	26.36	0.041	11.22	0.013
3	0.092	25.89	0.027	7.64	0.013
4	0.091	25.37	0.029	8.13	0.013
5	0.093	26.77	0.027	7.75	0.013
6	0.09	26.85	0.03	9.09	0.013
7	0.093	26.37	0.021	5.95	0.013

8	0.093	25.86	0.027	7.47	0.013
9	0.096	26.25	0.029	7.9	0.013
10	0.095	26.07	0.024	6.45	0.013
11	0.093	25.22	0.025	6.81	0.013
12	0.098	26.65	0.03	8.1	0.013
13	0.092	25.91	0.024	6.82	0.013
14	0.097	26.42	0.03	8.18	0.013
15	0.094	25.66	0.031	8.39	0.013
16	0.097	25.92	0.028	7.4	0.013
17	0.096	26.14	0.023	6.38	0.013
18	0.095	26.54	0.036	10.12	0.013
19	0.091	25.26	0.033	9.14	0.013
20	0.092	25.55	0.038	10.66	0.013
21	0.092	25.83	0.018	4.93	0.013
22	0.098	26.73	0.031	8.55	0.013
23	0.09	24.96	0.036	9.95	0.013
Average	0.094		0.03		0.013
Total		623.73		199.32	
30-Day Rlng	0.094		0.029		
365-Day Rlng				59617	

10/30/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.079	26.55	0.03	9.91	0.013
1	0.084	25.56	0.033	10.09	0.013
2	0.095	26.63	0.025	6.87	0.013
3	0.091	25.27	0.025	6.8	0.013
4	0.094	26.21	0.028	7.9	0.013
5	0.093	26.53	0.025	7	0.013
6	0.087	26.34	0.031	9.33	0.013
7	0.089	24.95	0.029	8.12	0.013
8	0.095	26.46	0.028	7.76	0.013
9	0.088	26.35	0.026	7.9	0.013
10	0.086	25.96	0.024	7.2	0.012
11	0.092	25.45	0.026	7.08	0.012
12	0.091	27.42	0.029	8.64	0.012
13	0.085	25.88	0.024	7.41	0.012
14	0.091	25.76	0.026	7.27	0.012
15	0.09	24.97	0.024	6.73	0.012
16	0.099	27.03	0.032	8.68	0.012
17	0.093	25.99	0.023	6.41	0.012
18	0.095	26.75	0.027	7.73	0.012
19	0.093	25.49	0.028	7.71	0.012
20	0.094	26.5	0.035	9.74	0.012
21	0.092	26.79	0.023	6.58	0.012
22	0.087	25.92	0.028	8.44	0.012
23	0.092	26.34	0.03	8.62	0.012
Average	0.091		0.027		0.012

Total		627.1		189.92	
30-Day Rlng	0.094		0.029		
365-Day Rlng				59617	
10/31/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.23	0.029	8.17	0.012
1	0.092	26.44	0.026	7.36	0.012
2	0.094	26.16	0.028	7.72	0.012
3	0.092	25.46	0.024	6.54	0.012
4	0.094	26.61	0.028	7.98	0.012
5	0.095	27.61	0.026	7.5	0.012
6	0.087	27.56	0.025	8.08	0.012
7	0.086	25.38	0.025	7.41	0.012
8	0.088	25.56	0.026	7.47	0.012
9	0.093	26.57	0.025	7.27	0.012
10	0.086	24.93	0.024	6.81	0.012
11	0.093	25.83	0.027	7.36	0.012
12	0.092	26.92	0.031	8.97	0.012
13	0.087	25.1	0.023	6.79	0.012
14	0.092	26.2	0.027	7.75	0.012
15	0.095	27.23	0.03	8.56	0.012
16	0.091	26.25	0.03	8.52	0.012
17	0.086	24.96	0.025	7.32	0.012
18	0.095	27.1	0.027	7.68	0.012
19	0.09	26.39	0.026	7.43	0.012
20	0.088	25.47	0.029	8.4	0.012
21	0.09	26.2	0.023	6.7	0.012
22	0.088	24.45	0.024	6.8	0.013
23	0.114	20.71	0.023	4.19	0.021
Average	0.092		0.026		0.012
Total		620.32		178.78	
30-Day Rlng	0.094		0.029		
365-Day Rlng				59598	
11/1/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 DCAL	DCAL	DCAL	DCAL	DCAL	DCAL
6 DCAL	DCAL	DCAL	DCAL	DCAL	DCAL
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down

	12 Down	Down	Down	Down	Down
	13 Down	Down	Down	Down	Down
	14 Down	Down	Down	Down	Down
	15 Down	Down	Down	Down	Down
	16 Down	Down	Down	Down	Down
	17 Down	Down	Down	Down	Down
	18 Down	Down	Down	Down	Down
	19 Down	Down	Down	Down	Down
	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.094		0.029	
365-Day Rlng					59369

11/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0 Down	Down	Down	Down	Down
	1 Down	Down	Down	Down	Down
	2 Down	Down	Down	Down	Down
	3 Down	Down	Down	Down	Down
	4 Down	Down	Down	Down	Down
	5 DCal	DCal	DCal	DCal	DCal
	6 DCal	DCal	DCal	DCal	DCal
	7 Down	Down	Down	Down	Down
	8 Down	Down	Down	Down	Down
	9 Down	Down	Down	Down	Down
	10 Down	Down	Down	Down	Down
	11 Down	Down	Down	Down	Down
	12 Down	Down	Down	Down	Down
	13 Down	Down	Down	Down	Down
	14 Down	Down	Down	Down	Down
	15 Down	Down	Down	Down	Down
	16 Down	Down	Down	Down	Down
	17 Down	Down	Down	Down	Down
	18 Down	Down	Down	Down	Down
	19 Down	Down	Down	Down	Down
	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.094		0.029	
365-Day Rlng					59139

11/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Down	Down	Down	Down	Down
3	Down	Down	Down	Down	Down
4	Down	Down	Down	Down	Down
5	Down	Down	Down	Down	Down
6	Down	Down	Down	Down	Down
7	Down	Down	Down	Down	Down
8	Down	Down	Down	Down	Down
9	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rng		0.094		0.029	
365-Day Rng					58942

11/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Down	Down	Down	Down	Down
2	Down	Down	Down	Down	Down
3	Down	Down	Down	Down	Down
4	Down	Down	Down	Down	Down
5	Down	Down	Down	Down	Down
6	Down	Down	Down	Down	Down
7	Down	Down	Down	Down	Down
8	Down	Down	Down	Down	Down
9	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down

	16 Down	Down	Down	Down	Down
	17 Down	Down	Down	Down	Down
	18 Down	Down	Down	Down	Down
	19 Down	Down	Down	Down	Down
	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.094		0.029	
365-Day Rlng					58738

11/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0 Down	Down	Down	Down	Down
	1 Down	Down	Down	Down	Down
	2 Down	Down	Down	Down	Down
	3 Down	Down	Down	Down	Down
	4 Down	Down	Down	Down	Down
	5 Down	Down	Down	Down	Down
	6 Down	Down	Down	Down	Down
	7 Down	Down	Down	Down	Down
	8 Down	Down	Down	Down	Down
	9 Down	Down	Down	Down	Down
	10 Down	Down	Down	Down	Down
	11 Down	Down	Down	Down	Down
	12 Down	Down	Down	Down	Down
	13 Down	Down	Down	Down	Down
	14 Down	Down	Down	Down	Down
	15 Down	Down	Down	Down	Down
	16 Down	Down	Down	Down	Down
	17 Down	Down	Down	Down	Down
	18 Down	Down	Down	Down	Down
	19 Down	Down	Down	Down	Down
	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.094		0.029	
365-Day Rlng					58527

11/6/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0 Down	Down	Down	Down	Down
	1 Down	Down	Down	Down	Down
	2 Down	Down	Down	Down	Down

3 Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down
Average	Down	Down	Down	Down
Total		Down	Down	
30-Day Rlng	0.094		0.029	
365-Day Rlng				58318

11/7/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 Down	Down	Down	Down	Down	Down
7 Down	Down	Down	Down	Down	Down
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down

	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.094		0.029	
365-Day Rlng					58146

11/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0 Down	Down	Down	Down	Down
	1 Down	Down	Down	Down	Down
	2 Down	Down	Down	Down	Down
	3 Down	Down	Down	Down	Down
	4 Down	Down	Down	Down	Down
	5 Down	Down	Down	Down	Down
	6 Down	Down	Down	Down	Down
	7 Down	Down	Down	Down	Down
	8 Down	Down	Down	Down	Down
	9 Down	Down	Down	Down	Down
	10 Down	Down	Down	Down	Down
	11 Down	Down	Down	Down	Down
	12 Down	Down	Down	Down	Down
	13 Down	Down	Down	Down	Down
	14 Down	Down	Down	Down	Down
	15 Down	Down	Down	Down	Down
	16 Down	Down	Down	Down	Down
	17 Down	Down	Down	Down	Down
	18 Down	Down	Down	Down	Down
	19 Down	Down	Down	Down	Down
	20 Down	Down	Down	Down	Down
	21 Down	Down	Down	Down	Down
	22 Down	Down	Down	Down	Down
	23 Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.094		0.029	
365-Day Rlng					57976

11/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
	0 Down	Down	Down	Down	Down
	1 Down	Down	Down	Down	Down
	2 Down	Down	Down	Down	Down
	3 Down	Down	Down	Down	Down
	4 Down	Down	Down	Down	Down
	5 Down	Down	Down	Down	Down
	6 Down	Down	Down	Down	Down

7	Down	Down	Down	Down	Down
8	Down	Down	Down	Down	Down
9	Down	Down	Down	Down	Down
10	Down	Down	Down	Down	Down
11	Down	Down	Down	Down	Down
12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.094		0.029	
365-Day Rlng					57794

11/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Maint	Maint	Maint	Maint	Maint
1	Maint	Maint	Maint	Maint	Maint
2	Maint	Maint	Maint	Maint	Maint
3	Maint	Maint	Maint	Maint	Maint
4	Maint	Maint	Maint	Maint	Maint
5	Maint	Maint	Maint	Maint	Maint
6	Down	Down	Down	Down	Down
7	Down	Down	Down	Down	Down
8	Maint	Maint	Maint	Maint	Maint
9	Maint	Maint	Maint	Maint	Maint
10	Maint	Maint	Maint	Maint	Maint
11	Maint	Maint	Maint	Maint	Maint
12	Maint	Maint	Maint	Maint	Maint
13	Maint	Maint	Maint	Maint	Maint
14	Maint	Maint	Maint	Maint	Maint
15	Maint	Maint	Maint	Maint	Maint
16	Maint	Maint	Maint	Maint	Maint
17	Maint	Maint	Maint	Maint	Maint
18	Maint	Maint	Maint	Maint	Maint
19	Maint	Maint	Maint	Maint	Maint
20	Maint	Maint	Maint	Maint	Maint
21	Maint	Maint	Maint	Maint	Maint
22	Maint	Maint	Maint	Maint	Maint
23	0.356 OOC		0.028 OOC		0.112

Average	0.356	0.028	0.112
Total	Maint	Maint	
30-Day Rlng	0.094	0.029	
365-Day Rlng			57607

11/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.153	OOC	0.021	OOC	0.033
1	0.108	OOC	0.018	OOC	0.019
2	0.094	OOC	0.016	OOC	0.014
3	0.096	OOC	0.017	OOC	0.013
4	0.093	OOC	0.031	OOC	0.013
5	0.082	OOC	0.028	OOC	0.013
6	0.086	22.53	0.016	4.2	0.014
7	0.083	24.9	0.031	9.25	0.012
8	0.087	26.29	0.027	8.2	0.012
9	0.087	26.23	0.026	7.84	0.012
10	0.087	25.94	0.026	7.62	0.012
11	0.087	25.87	0.023	6.95	0.012
12	0.088	26.31	0.026	7.67	0.012
13	0.089	26.17	0.03	8.66	0.012
14	0.088	25.92	0.026	7.58	0.013
15	0.088	26.22	0.026	7.88	0.012
16	0.088	25.82	0.025	7.25	0.013
17	0.088	26.62	0.025	7.54	0.012
18	0.088	26.32	0.025	7.46	0.013
19	0.089	26.3	0.025	7.35	0.013
20	0.086	25.88	0.026	7.89	0.012
21	0.087	25.84	0.025	7.39	0.012
22	0.091	26.93	0.027	7.89	0.012
23	0.087	25.85	0.025	7.56	0.012
Average	0.092		0.025		0.014
Total		465.94		136.18	
30-Day Rlng	0.094		0.029		
365-Day Rlng				57540	

11/12/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	26.27	0.025	7.32	0.012
1	0.088	26.22	0.026	7.68	0.012
2	0.088	26.2	0.029	8.64	0.012
3	0.092	27.07	0.025	7.43	0.012
4	0.084	24.89	0.026	7.64	0.012
5	0.087	26.04	0.026	7.64	0.012
6	0.083	25.91	0.024	7.57	0.012
7	0.088	26.24	0.025	7.54	0.013
8	0.087	26.04	0.028	8.31	0.012
9	0.087	25.99	0.023	6.9	0.012
10	0.088	26.2	0.026	7.75	0.012

11	0.089	26.48	0.023	6.65	0.012
12	0.088	26.19	0.023	6.93	0.012
13	0.085	26.26	0.027	8.26	0.012
14	0.087	26	0.023	6.85	0.012
15	0.088	26.28	0.026	7.74	0.012
16	0.088	25.87	0.025	7.38	0.012
17	0.088	26.09	0.025	7.38	0.012
18	0.088	26.23	0.026	7.62	0.012
19	0.087	25.42	0.025	7.28	0.012
20	0.088	26.04	0.025	7.38	0.012
21	0.089	26.2	0.026	7.66	0.012
22	0.091	26.55	0.028	8.25	0.012
23	0.087	25.56	0.025	7.31	0.012
Average	0.088		0.025		0.012
Total		626.24		181.11	
30-Day Rlng	0.094		0.028		
365-Day Rlng				57520	
11/13/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.62	0.028	8.44	0.012
1	0.087	25.35	0.027	7.73	0.013
2	0.089	26.3	0.026	7.8	0.012
3	0.087	26.43	0.028	8.48	0.012
4	0.085	25.78	0.024	7.15	0.012
5	0.088	27.41	0.026	7.93	0.012
6	0.083	25.85	0.023	7.21	0.013
7	0.087	26.08	0.026	7.73	0.012
8	0.088	26.19	0.027	8.05	0.012
9	0.088	26.07	0.028	8.41	0.012
10	0.09	26.43	0.029	8.42	0.012
11	0.088	26.24	0.031	9.15	0.012
12	0.088	25.81	0.025	7.35	0.012
13	0.091	26.24	0.032	9.12	0.012
14	0.087	25.96	0.027	8.17	0.012
15	0.086	25.92	0.026	7.65	0.012
16	0.087	26.18	0.031	9.34	0.012
17	0.088	26.85	0.029	8.9	0.012
18	0.084	25.64	0.028	8.38	0.012
19	0.087	26.15	0.029	8.84	0.012
20	0.088	25.95	0.03	8.84	0.012
21	0.089	26.35	0.03	8.96	0.012
22	0.089	25.62	0.028	7.97	0.012
23	0.089	25.24	0.028	7.94	0.013
Average	0.088		0.028		0.012
Total		626.66		197.96	
30-Day Rlng	0.094		0.028		
365-Day Rlng				57516	

11/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.095	20.55	0.019	4.14	0.014
1	0.083	15.77	0.018	3.38	0.016
2	0.087	17.1	0.018	3.49	0.016
3	0.092	17.55	0.018	3.44	0.016
4	0.093	17.62	0.018	3.4	0.016
5	0.091	17.99	0.018	3.5	0.016
6	0.086	16.9	0.018	3.5	0.016
7	0.089	17.13	0.018	3.39	0.016
8	0.09	17.1	0.018	3.37	0.016
9	0.09	17.21	0.018	3.38	0.016
10	0.087	16.34	0.018	3.32	0.015
11	0.088	16.86	0.018	3.37	0.015
12	0.097	18.38	0.018	3.33	0.015
13	0.095	18.24	0.018	3.37	0.015
14	0.096	19.21	0.017	3.45	0.015
15	0.084	15.69	0.018	3.33	0.016
16	0.087	16.55	0.017	3.29	0.015
17	0.092	17.38	0.018	3.32	0.015
18	0.1	19.21	0.017	3.33	0.015
19	0.096	18.31	0.017	3.32	0.015
20	0.087	16.46	0.018	3.37	0.016
21	0.089	17	0.018	3.39	0.016
22	0.093	17.9	0.018	3.37	0.015
23	0.087	16.52	0.018	3.37	0.016
Average	0.091		0.018		0.016
Total		418.97		81.92	
30-Day Rlng	0.094		0.028		
365-Day Rlng				57403	

11/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.083	16.49	0.017	3.4	0.015
1	0.093	18.06	0.017	3.38	0.015
2	0.095	17.6	0.018	3.29	0.016
3	0.111	20.55	0.018	3.35	0.016
4	0.09	16.7	0.018	3.36	0.016
5	0.085	15.91	0.018	3.41	0.016
6	0.085	16.14	0.018	3.48	0.016
7	0.095	18.66	0.018	3.51	0.016
8	0.098	18.37	0.018	3.44	0.016
9	0.077	14.57	0.018	3.37	0.016
10	0.084	15.61	0.018	3.34	0.016
11	0.084	15.57	0.018	3.34	0.016
12	0.106	20.25	0.018	3.39	0.016
13	0.103	19.42	0.018	3.34	0.016
14	0.096	17.86	0.018	3.32	0.016

15	0.11	20.55	0.018	3.31	0.016
16	0.114	20.84	0.018	3.25	0.016
17	0.096	17.79	0.018	3.3	0.016
18	0.096	17.94	0.018	3.3	0.016
19	0.086	16.03	0.018	3.31	0.016
20	0.1	18.88	0.018	3.36	0.016
21	0.112	21.15	0.018	3.39	0.016
22	0.108	20.85	0.018	3.39	0.015
23	0.11	21.4	0.018	3.41	0.015
Average	0.097		0.018		0.016
Total		437.19		80.74	
30-Day Rlng	0.094		0.027		
365-Day Rlng				57311	

11/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.069	18.91	0.023	6.5	0.013
1	0.074	22.32	0.032	9.7	0.012
2	0.083	24.38	0.031	9	0.012
3	0.089	26.36	0.026	7.68	0.012
4	0.087	26.03	0.029	8.71	0.012
5	0.086	25.99	0.026	7.72	0.012
6	0.088	26.81	0.026	8.01	0.012
7	0.083	25.96	0.022	6.88	0.012
8	0.086	26.39	0.024	7.53	0.012
9	0.088	26.14	0.027	8.03	0.012
10	0.087	25.78	0.029	8.58	0.012
11	0.089	25.89	0.029	8.24	0.012
12	0.09	26.03	0.032	9.28	0.012
13	0.092	26.54	0.031	8.97	0.012
14	0.088	25.89	0.029	8.37	0.012
15	0.089	26.34	0.029	8.61	0.012
16	0.088	26	0.027	7.98	0.012
17	0.088	26.23	0.024	7.28	0.012
18	0.087	26.23	0.031	9.24	0.012
19	0.087	26.06	0.029	8.57	0.012
20	0.087	26.36	0.03	9.1	0.012
21	0.086	25.93	0.027	8.28	0.012
22	0.088	26.66	0.03	9.23	0.012
23	0.086	25.88	0.029	8.69	0.012
Average	0.086		0.028		0.012
Total		615.11		200.18	
30-Day Rlng	0.094		0.027		
365-Day Rlng				57324	

11/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	26.38	0.029	8.99	0.012
1	0.088	25.93	0.026	7.65	0.012

2	0.086	25.83	0.027	8.12	0.012
3	0.086	25.51	0.024	7.28	0.012
4	0.088	26.36	0.03	8.96	0.012
5	0.088	26.06	0.03	8.99	0.012
6	0.087	25.99	0.029	8.53	0.012
7	0.086	26.77	0.033	10.18	0.012
8	0.086	26.26	0.024	7.44	0.012
9	0.086	26.37	0.028	8.59	0.012
10	0.087	26.11	0.029	8.72	0.012
11	0.085	26.03	0.027	8.28	0.012
12	0.087	26.49	0.029	8.86	0.012
13	0.085	25.64	0.027	8.22	0.012
14	0.085	25.87	0.028	8.58	0.012
15	0.088	26.17	0.029	8.74	0.012
16	0.089	26.68	0.031	9.16	0.012
17	0.086	26	0.029	8.8	0.012
18	0.086	26.07	0.027	8.29	0.012
19	0.087	26.26	0.029	8.7	0.012
20	0.087	26.42	0.029	8.69	0.012
21	0.086	25.98	0.029	8.63	0.012
22	0.086	26.08	0.029	8.63	0.012
23	0.087	26.27	0.028	8.36	0.012
Average		0.087		0.028	0.012
Total			627.53		205.39
30-Day Rlng		0.093		0.027	
365-Day Rlng					57349

11/18/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	26.24	0.028	8.33	0.012
1	0.087	26.3	0.029	8.75	0.012
2	0.085	25.76	0.029	8.94	0.012
3	0.086	26.11	0.028	8.59	0.012
4	0.088	26.53	0.03	9.14	0.012
5	0.085	25.68	0.028	8.42	0.012
6	0.087	27.34	0.03	9.49	0.012
7	0.081	25.4	0.029	9.01	0.012
8	0.085	26.08	0.027	8.45	0.012
9	0.085	25.99	0.028	8.48	0.012
10	0.087	25.91	0.028	8.15	0.012
11	0.087	26.45	0.025	7.62	0.012
12	0.086	25.64	0.028	8.52	0.012
13	0.086	25.75	0.033	9.81	0.012
14	0.089	26.45	0.031	9.1	0.012
15	0.088	25.93	0.024	7.07	0.012
16	0.09	25.83	0.028	8.06	0.012
17	0.09	26.44	0.033	9.61	0.012
18	0.088	26.19	0.029	8.75	0.012

19	0.089	26.26	0.03	8.76	0.012
20	0.087	25.97	0.03	8.78	0.012
21	0.088	26.12	0.029	8.53	0.012
22	0.088	25.91	0.03	8.98	0.012
23	0.09	26.27	0.03	8.84	0.012
Average	0.087		0.029		0.012
Total		626.55		208.18	
30-Day Rlng	0.093		0.027		
365-Day Rlng				57399	

11/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	26.1	0.033	9.89	0.012
1	0.09	26.17	0.032	9.48	0.012
2	0.088	26.17	0.027	7.98	0.012
3	0.088	26.26	0.028	8.23	0.012
4	0.089	25.91	0.028	7.99	0.012
5	0.088	26.4	0.03	8.98	0.012
6	0.088	26.89	0.029	8.74	0.012
7	0.086	26.63	0.028	8.79	0.012
8	0.086	25.9	0.027	8.14	0.012
9	0.087	26.25	0.03	9.1	0.012
10	0.088	25.48	0.029	8.41	0.012
11	0.09	26.33	0.031	8.95	0.012
12	0.089	26.51	0.029	8.54	0.012
13	0.089	25.73	0.028	8.18	0.012
14	0.09	26.64	0.029	8.54	0.012
15	0.088	25.9	0.029	8.63	0.012
16	0.088	25.81	0.029	8.62	0.012
17	0.088	26.23	0.028	8.41	0.012
18	0.092	27.17	0.03	8.79	0.012
19	0.087	25.48	0.029	8.4	0.012
20	0.088	26.2	0.032	9.65	0.012
21	0.088	26.01	0.03	8.76	0.012
22	0.089	26.29	0.031	8.97	0.012
23	0.089	26.37	0.028	8.41	0.012
Average	0.088		0.029		0.012
Total		628.83		208.58	
30-Day Rlng	0.093		0.027		
365-Day Rlng				57483	

11/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.98	0.029	8.48	0.012
1	0.088	25.64	0.031	9.2	0.012
2	0.09	26.23	0.029	8.51	0.012
3	0.089	26.19	0.03	8.68	0.012
4	0.09	26.33	0.029	8.46	0.012
5	0.088	25.97	0.029	8.47	0.012

6	0.085	25.25	0.028	8.32	0.012
7	0.088	27.02	0.026	8.07	0.012
8	0.085	25.55	0.028	8.46	0.012
9	0.089	26.56	0.029	8.79	0.012
10	0.088	25.88	0.027	7.88	0.012
11	0.088	24.87	0.03	8.46	0.012
12	0.092	26.89	0.031	8.93	0.012
13	0.088	25.44	0.029	8.46	0.012
14	0.09	26.53	0.03	8.87	0.012
15	0.088	26.12	0.029	8.52	0.012
16	0.089	25.81	0.028	7.97	0.012
17	0.088	26.18	0.028	8.37	0.012
18	0.087	25.76	0.028	8.26	0.012
19	0.088	25.96	0.03	8.88	0.012
20	0.087	25.98	0.026	7.6	0.012
21	0.087	25.81	0.028	8.29	0.012
22	0.09	26.13	0.031	9.06	0.012
23	0.088	26.22	0.029	8.53	0.012
Average	0.088		0.029		0.012
Total		624.3		203.52	
30-Day Rlng	0.093		0.027		
365-Day Rlng				57686	

11/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.79	0.03	8.87	0.012
1	0.087	25.31	0.031	9.11	0.012
2	0.09	26.44	0.03	8.68	0.012
3	0.09	26.4	0.03	8.71	0.012
4	0.087	24.94	0.029	8.37	0.012
5	0.091	26.69	0.029	8.45	0.012
6	0.089	26.02	0.029	8.49	0.012
7	0.091	25.93	0.03	8.42	0.013
8	0.09	25.99	0.03	8.57	0.012
9	0.094	26.83	0.03	8.58	0.012
10	0.091	25.34	0.028	7.78	0.012
11	0.09	25.52	0.028	8.11	0.012
12	0.095	26.38	0.031	8.7	0.012
13	0.094	25.99	0.032	8.9	0.012
14	0.092	26.38	0.032	9.02	0.012
15	0.093	26.09	0.03	8.34	0.012
16	0.09	25.32	0.029	8.15	0.012
17	0.094	26.37	0.031	8.76	0.012
18	0.092	26.33	0.031	8.82	0.012
19	0.093	26.38	0.03	8.41	0.012
20	0.091	25.65	0.03	8.36	0.012
21	0.092	26.52	0.031	8.88	0.012
22	0.092	26.28	0.031	8.72	0.012

	23	0.091	26.03	0.031	8.77	0.012
Average		0.091		0.03		0.012
Total			624.92		205.97	
30-Day Rlng		0.093		0.027		
365-Day Rlng					57892	

11/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.04	0.03	8.78	0.012
1	0.09	25.97	0.029	8.46	0.012
2	0.089	25.47	0.032	9.18	0.012
3	0.092	26	0.029	8.18	0.013
4	0.091	26.19	0.032	9.27	0.012
5	0.09	25.58	0.029	8.29	0.012
6	0.091	26.85	0.029	8.45	0.012
7	0.088	26.16	0.036	10.83	0.013
8	0.089	26.15	0.028	8.4	0.013
9	0.091	26.23	0.027	7.87	0.013
10	0.091	25.76	0.027	7.48	0.012
11	0.091	25.81	0.027	7.79	0.012
12	0.092	25.92	0.032	8.94	0.012
13	0.094	25.77	0.031	8.49	0.012
14	0.093	25.64	0.03	8.31	0.012
15	0.093	26.04	0.031	8.7	0.012
16	0.092	25.93	0.03	8.36	0.012
17	0.092	26.37	0.03	8.67	0.012
18	0.09	26.35	0.03	8.69	0.012
19	0.09	25.51	0.029	8.16	0.012
20	0.09	26.57	0.031	9.15	0.012
21	0.09	26.26	0.029	8.65	0.012
22	0.089	25.78	0.029	8.23	0.012
23	0.089	26.48	0.031	9.16	0.012
Average	0.091		0.03		0.012
Total		624.83		206.49	
30-Day Rlng		0.092		0.027	
365-Day Rlng				57982	

11/23/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	25.34	0.028	7.97	0.012
1	0.088	24.57	0.026	7.19	0.013
2	0.094	27.07	0.037	10.67	0.013
3	0.089	26.03	0.025	7.37	0.012
4	0.089	26.62	0.029	8.76	0.012
5	0.086	26	0.028	8.37	0.012
6	0.091	27.63	0.03	9.06	0.012
7	0.077	23.74	0.023	7.24	0.012
8	0.089	27.26	0.027	8.27	0.012
9	0.084	25.24	0.031	9.26	0.012

10	0.089	25.76	0.026	7.47	0.012
11	0.091	26.3	0.03	8.68	0.012
12	0.087	25.74	0.03	8.79	0.012
13	0.087	23.99	0.027	7.56	0.013
14	0.09	26.29	0.027	7.82	0.012
15	0.091	26.62	0.026	7.52	0.012
16	0.091	26.02	0.024	6.97	0.012
17	0.09	26.2	0.031	8.91	0.012
18	0.089	26.03	0.031	9.16	0.012
19	0.092	26.28	0.029	8.46	0.012
20	0.089	25.64	0.028	8.17	0.012
21	0.091	26.18	0.03	8.69	0.012
22	0.103	26.16	0.029	7.4	0.012
23	0.101	25.38	0.034	8.65	0.012
Average	0.09		0.029		0.012
Total		622.09		198.41	
30-Day Rlng	0.092		0.027		
365-Day Rlng				57993	

11/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.104	26.75	0.03	7.65	0.012
1	0.102	25.05	0.032	7.82	0.013
2	0.105	25.91	0.038	9.49	0.013
3	0.104	26.09	0.038	9.36	0.012
4	0.107	26.53	0.036	9.03	0.012
5	0.101	25.65	0.032	8.25	0.012
6	0.103	26.6	0.035	9.1	0.012
7	0.101	26.76	0.025	6.59	0.012
8	0.098	25.92	0.034	9.06	0.012
9	0.101	26.06	0.015	3.77	0.012
10	0.1	25.26	0.031	7.9	0.012
11	0.104	26.35	0.037	9.43	0.012
12	0.101	25.53	0.031	7.88	0.012
13	0.103	25.68	0.033	8.32	0.012
14	0.104	26.14	0.041	10.33	0.012
15	0.103	25.67	0.033	8.23	0.013
16	0.102	26.03	0.036	9.17	0.012
17	0.102	25.91	0.033	8.46	0.012
18	0.104	26.44	0.034	8.76	0.012
19	0.103	25.99	0.035	8.89	0.012
20	0.102	25.46	0.031	7.76	0.012
21	0.103	25.96	0.036	9.02	0.012
22	0.101	25.34	0.038	9.51	0.012
23	0.102	25.66	0.03	7.62	0.013
Average	0.103		0.033		0.012
Total		622.74		201.4	
30-Day Rlng	0.092		0.027		

365-Day Rlng 57999

11/25/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.102	25.86	0.034	8.67	0.013
1	0.099	24.73	0.034	8.49	0.013
2	0.105	26.56	0.031	7.79	0.013
3	0.105	25.95	0.037	9.06	0.013
4	0.103	25.47	0.037	9.12	0.013
5	0.103	25.94	0.035	8.84	0.013
6	0.102	26.47	0.032	8.27	0.013
7	0.097	25.57	0.023	6.13	0.013
8	0.102	26.25	0.032	8.19	0.013
9	0.103	26.42	0.034	8.76	0.012
10	0.101	25.67	0.036	9.07	0.012
11	0.103	25.98	0.033	8.2	0.013
12	0.104	26.76	0.03	7.81	0.012
13	0.102	25.94	0.035	8.8	0.013
14	0.101	25.31	0.035	8.89	0.013
15	0.103	25.91	0.034	8.44	0.013
16	0.104	25.71	0.035	8.69	0.013
17	0.106	26.62	0.036	8.94	0.012
18	0.103	25.77	0.034	8.42	0.013
19	0.105	25.78	0.03	7.32	0.013
20	0.102	26.28	0.035	9.03	0.012
21	0.102	25.59	0.033	8.16	0.013
22	0.11	23.41	0.035	7.32	0.013
23	0.114	20.35	0.048	8.48	0.012
Average	0.103		0.034		0.013
Total		614.3		200.89	
30-Day Rlng	0.093		0.028		
365-Day Rlng				58009	

11/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.112	19.76	0.047	8.37	0.012
1	0.107	18.38	0.038	6.6	0.013
2	0.111	18.98	0.039	6.63	0.013
3	0.108	18.32	0.041	7.01	0.013
4	0.108	18.44	0.042	7.09	0.012
5	0.111	19.53	0.039	6.94	0.012
6	0.103	25.31	0.032	7.69	0.012
7	0.092	24.64	0.024	6.46	0.012
8	0.095	24.39	0.022	5.62	0.012
9	0.101	25.36	0.028	7.1	0.012
10	0.099	24.83	0.025	6.19	0.012
11	0.104	22.75	0.026	5.61	0.012
12	0.11	19.92	0.044	7.84	0.012
13	0.111	19.62	0.038	6.81	0.012

14	0.108	18.62	0.033	5.69	0.012
15	0.107	18.66	0.04	7	0.012
16	0.11	26.71	0.038	9.12	0.013
17	0.092	24.97	0.014	3.86	0.012
18	0.093	24.22	0.014	3.68	0.012
19	0.106	22.95	0.014	3.09	0.012
20	0.095	25.03	0.019	5.04	0.012
21	0.105	21.87	0.042	8.46	0.013
22	0.108	19.24	0.039	6.89	0.013
23	0.111	22.33	0.033	6.69	0.013
Average	0.104		0.032		0.012
Total		524.83		155.48	
30-Day Rlng	0.093		0.028		
365-Day Rlng				57978	

11/27/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.107	20.86	0.031	6.06	0.013
1	0.109	21.67	0.036	7.22	0.013
2	0.11	22.18	0.035	6.97	0.013
3	0.109	21.45	0.033	6.43	0.013
4	0.112	22.53	0.036	7.21	0.013
5	0.096	23.53	0.028	6.97	0.013
6	0.093	25.57	0.023	6.45	0.013
7	0.094	26.92	0.028	8.15	0.013
8	0.09	24.65	0.025	6.73	0.013
9	0.096	24.33	0.024	6.07	0.013
10	0.101	25.31	0.026	6.45	0.012
11	0.093	24.85	0.017	4.47	0.013
12	0.093	26.07	0.03	8.32	0.012
13	0.087	24.36	0.028	7.83	0.013
14	0.093	24.81	0.026	6.85	0.013
15	0.094	25.1	0.028	7.36	0.013
16	0.096	24.94	0.027	7.03	0.013
17	0.096	25.09	0.025	6.42	0.013
18	0.095	24.89	0.025	6.43	0.013
19	0.09	25.18	0.027	7.63	0.012
20	0.094	25.46	0.029	7.96	0.012
21	0.093	24.73	0.025	6.56	0.012
22	0.095	24.43	0.019	4.83	0.013
23	0.098	25.53	0.036	9.26	0.012
Average	0.097		0.028		0.013
Total		584.44		165.66	
30-Day Rlng	0.093		0.028		
365-Day Rlng				57955	

11/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	24.86	0.026	6.75	0.012

1	0.095	24.28	0.02	5.07	0.013
2	0.096	24.47	0.031	7.84	0.013
3	0.095	25.38	0.026	7.02	0.013
4	0.093	25.68	0.024	6.65	0.013
5	0.082	25.14	0.022	6.74	0.013
6	0.082	26.44	0.022	7.04	0.012
7	0.079	23.95	0.021	6.4	0.013
8	0.084	24.88	0.022	6.42	0.013
9	0.082	25.48	0.021	6.5	0.013
10	0.085	24.63	0.02	5.83	0.013
11	0.083	24.93	0.024	7.14	0.013
12	0.083	25.92	0.021	6.41	0.012
13	0.081	24.01	0.022	6.53	0.013
14	0.085	25.2	0.025	7.38	0.012
15	0.087	25.39	0.023	6.63	0.013
16	0.093	25.95	0.025	7	0.012
17	0.087	25.03	0.023	6.55	0.013
18	0.091	25.21	0.024	6.68	0.013
19	0.09	24.87	0.026	7.31	0.013
20	0.09	25.78	0.023	6.6	0.012
21	0.086	25.03	0.022	6.44	0.012
22	0.087	23.96	0.028	7.63	0.012
23	0.094	25.82	0.028	7.85	0.013
Average	0.088		0.024		0.013
Total		602.29		162.41	
30-Day Rlng	0.093		0.028		
365-Day Rlng				57950	

11/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	25.31	0.022	6.04	0.013
1	0.092	24.9	0.029	7.9	0.013
2	0.091	25.23	0.029	7.93	0.013
3	0.093	25.17	0.021	5.55	0.013
4	0.093	24.26	0.023	6.12	0.013
5	0.094	25.73	0.026	6.99	0.012
6	0.094	25.85	0.027	7.33	0.013
7	0.088	26.17	0.03	8.88	0.013
8	0.089	25.35	0.02	5.57	0.013
9	0.09	25.45	0.024	6.77	0.012
10	0.091	25.44	0.023	6.52	0.012
11	0.091	25.07	0.024	6.61	0.012
12	0.088	24.49	0.022	6.14	0.012
13	0.093	25.14	0.025	6.8	0.012
14	0.093	25.72	0.025	6.8	0.012
15	0.088	23.67	0.024	6.63	0.013
16	0.091	24.62	0.026	6.91	0.013
17	0.094	26.24	0.024	6.84	0.012

18	0.088	25.08	0.024	6.81	0.012
19	0.087	24.16	0.023	6.41	0.013
20	0.09	25.73	0.024	6.87	0.012
21	0.088	25.07	0.024	6.88	0.012
22	0.09	24.48	0.023	6.38	0.012
23	0.09	25.39	0.023	6.32	0.012
Average	0.091		0.024		0.012
Total		603.72		162	
30-Day Rlng	0.093		0.028		
365-Day Rlng				57918	

11/30/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.03	0.026	7.55	0.012
1	0.087	23.7	0.026	7.18	0.013
2	0.091	25.01	0.023	6.32	0.013
3	0.092	25.01	0.025	6.75	0.013
4	0.09	24.48	0.023	6.19	0.013
5	0.091	25.35	0.024	6.56	0.013
6	0.093	25.52	0.021	5.88	0.013
7	0.099	29.98	0.03	9.2	0.012
8	0.092	25.88	0.028	7.79	0.012
9	0.09	24.6	0.025	6.95	0.012
10	0.094	25.06	0.018	4.66	0.013
11	0.097	26.06	0.027	7.27	0.012
12	0.091	24.44	0.022	5.91	0.012
13	0.091	24.17	0.026	6.86	0.013
14	0.095	24.73	0.025	6.4	0.013
15	0.095	25.47	0.026	6.91	0.013
16	0.093	24.7	0.026	6.84	0.013
17	0.093	25.07	0.026	7.02	0.013
18	0.092	25.12	0.024	6.39	0.013
19	0.094	26.29	0.026	7.3	0.012
20	0.086	24.35	0.024	6.75	0.012
21	0.087	25.04	0.025	7.22	0.012
22	0.089	24.93	0.026	7.24	0.012
23	0.094	25.39	0.02	5.4	0.012
Average	0.092		0.025		0.013
Total		606.38		162.54	
30-Day Rlng	0.093		0.028		
365-Day Rlng				58031	

12/1/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	24.96	0.023	6.23	0.012
1	0.092	25.13	0.025	6.73	0.012
2	0.094	25.32	0.03	8.18	0.013
3	0.092	25	0.021	5.68	0.012
4	0.092	24.5	0.026	7.02	0.012

5	0.095	25.44	0.027	7.37	0.012
6	0.092	25.59	0.023	6.32	0.012
7	0.09	26.58	0.029	8.64	0.012
8	0.09	24.71	0.028	7.66	0.012
9	0.092	25.09	0.024	6.58	0.012
10	0.095	25.49	0.023	6.22	0.012
11	0.093	24.99	0.023	6.23	0.012
12	0.094	24.72	0.023	6.11	0.013
13	0.096	25.55	0.025	6.76	0.013
14	0.094	24.95	0.024	6.51	0.013
15	0.095	25.46	0.026	6.87	0.013
16	0.094	24.96	0.022	5.98	0.013
17	0.09	25.07	0.024	6.55	0.013
18	0.091	25.64	0.026	7.22	0.013
19	0.089	25.02	0.03	8.36	0.013
20	0.09	25.54	0.02	5.49	0.013
21	0.088	25.1	0.023	6.63	0.012
22	0.093	25.58	0.024	6.7	0.012
23	0.09	26.04	0.024	7.05	0.012
Average	0.092		0.025		0.012
Total		606.43		163.09	
30-Day Rlng	0.093		0.028		
365-Day Rlng				58194	

12/2/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	24.26	0.024	6.64	0.012
1	0.089	24.7	0.026	7.15	0.012
2	0.088	24.5	0.024	6.66	0.013
3	0.088	25.08	0.024	6.76	0.013
4	0.09	25.29	0.024	6.75	0.013
5	0.089	25.68	0.023	6.47	0.013
6	0.087	25.7	0.024	7.13	0.013
7	0.09	27.18	0.026	8.06	0.013
8	0.091	25.6	0.022	6.35	0.013
9	0.092	24.74	0.022	5.96	0.013
10	0.096	25.32	0.026	6.77	0.013
11	0.093	24.76	0.023	6.02	0.013
12	0.099	25.43	0.028	7.16	0.013
13	0.094	24.48	0.027	6.91	0.013
14	0.098	25.32	0.025	6.4	0.013
15	0.097	24.74	0.025	6.39	0.013
16	0.1	25.05	0.026	6.48	0.013
17	0.097	25.53	0.028	7.32	0.013
18	0.095	25.32	0.024	6.4	0.013
19	0.098	25.76	0.029	7.65	0.013
20	0.094	24.71	0.023	6.08	0.012
21	0.095	24.77	0.028	7.3	0.013

	22	0.096	25.07	0.026	6.68	0.012
	23	0.095	24.64	0.025	6.47	0.013
Average		0.093		0.025		0.013
Total			603.63		161.96	
30-Day Rlng		0.094		0.028		
365-Day Rlng					58356	

12/3/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.097	25.35	0.025	6.65	0.012
1	0.108	22.25	0.028	5.68	0.013
2	0.109	22.81	0.033	6.86	0.013
3	0.11	23.25	0.031	6.65	0.013
4	0.11	22.35	0.033	6.72	0.013
5	0.109	23.07	0.034	7.21	0.013
6	0.111	23.94	0.034	7.26	0.013
7	0.104	24.19	0.035	7.3	0.013
8	0.109	22	0.036	7.38	0.012
9	0.109	22.27	0.03	6.18	0.012
10	0.11	21.37	0.036	6.99	0.012
11	0.105	18.33	0.026	4.63	0.013
12	0.111	20.33	0.044	8.14	0.013
13	0.099	24.44	0.032	7.93	0.013
14	0.096	25.29	0.025	6.59	0.013
15	0.094	24.57	0.024	6.2	0.013
16	0.094	25.64	0.025	6.65	0.013
17	0.092	25.38	0.02	5.63	0.013
18	0.089	24.59	0.024	6.62	0.013
19	0.095	26.5	0.03	8.39	0.012
20	0.089	24.32	0.023	6.32	0.013
21	0.089	24.76	0.023	6.46	0.012
22	0.092	24.92	0.023	6.29	0.013
23	0.093	25.52	0.024	6.71	0.012
Average	0.101		0.029		0.013
Total		567.44		161.44	
30-Day Rlng	0.094		0.028		
365-Day Rlng				58518	

12/4/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	24.56	0.025	6.72	0.013
1	0.094	25.55	0.028	7.46	0.013
2	0.09	25.48	0.027	7.53	0.013
3	0.091	25.36	0.024	6.78	0.013
4	0.09	24.51	0.025	6.85	0.013
5	0.089	24.76	0.024	6.77	0.012
6	0.091	26.35	0.021	6.1	0.013
7	0.086	24.82	0.026	7.51	0.013
8	0.087	25.09	0.024	6.8	0.012

9	0.09	25.27	0.023	6.45	0.012
10	0.091	25.08	0.024	6.45	0.013
11	0.09	25.08	0.024	6.64	0.012
12	0.09	24.94	0.022	6.05	0.012
13	0.09	24.34	0.026	6.84	0.013
14	0.094	25.51	0.025	6.68	0.013
15	0.091	24.47	0.022	6.04	0.013
16	0.094	22.8	0.031	7.64	0.014
17	0.102	21.03	0.017	3.53	0.015
18	0.112	23.74	0.018	3.82	0.015
19	0.107	21.56	0.018	3.61	0.016
20	0.11	22.14	0.019	3.89	0.016
21	0.11	22.2	0.02	4.05	0.015
22	0.108	21.15	0.02	3.93	0.016
23	0.063	12.76	0.025	5.03	0.015
Average	0.094		0.023		0.014
Total		568.55		143.17	
30-Day Rlng	0.093		0.027		
365-Day Rlng				58661	

12/5/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	21.28	0.041	10.08	0.013
1	0.09	24.94	0.017	4.66	0.013
2	0.091	25.06	0.023	6.46	0.013
3	0.093	25.71	0.027	7.61	0.013
4	0.09	24.6	0.024	6.57	0.013
5	0.091	24.81	0.022	6.07	0.013
6	0.094	26.05	0.023	6.25	0.013
7	0.088	25.41	0.027	7.88	0.013
8	0.09	25.76	0.021	6.11	0.013
9	0.088	24.04	0.025	6.68	0.013
10	0.092	24.88	0.023	6.34	0.013
11	0.092	25.36	0.024	6.44	0.013
12	0.091	25.43	0.024	6.63	0.012
13	0.09	24.4	0.026	6.99	0.013
14	0.094	25.51	0.026	7.08	0.013
15	0.091	24.8	0.023	6.18	0.013
16	0.093	25.75	0.025	6.84	0.013
17	0.089	24.86	0.024	6.78	0.013
18	0.089	24.88	0.023	6.54	0.013
19	0.094	25.51	0.026	7.03	0.013
20	0.091	24.77	0.024	6.59	0.013
21	0.096	26.22	0.024	6.46	0.012
22	0.089	23.99	0.023	6.24	0.013
23	0.092	25.39	0.025	6.94	0.012
Average	0.091		0.025		0.013
Total		599.41		161.45	

30-Day Rlng	0.093	0.027	
365-Day Rlng			58822
12/6/2020			
Hour			
	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu
0	0.09	25.19	0.025
1	0.091	24.86	0.031
2	0.091	24.59	0.039
3	0.091	24.92	0.031
4	0.091	24.94	0.02
5	0.092	25.91	0.025
6	0.086	24.53	0.021
7	0.091	24.79	0.023
8	0.091	25.47	0.029
9	0.095	25.25	0.022
10	0.095	25.23	0.021
11	0.094	24.64	0.023
12	0.096	25.18	0.027
13	0.093	24.33	0.031
14	0.094	25.71	0.025
15	0.091	24.18	0.023
16	0.094	25.04	0.025
17	0.095	26.09	0.025
18	0.088	24.61	0.025
19	0.091	25.69	0.024
20	0.086	24.69	0.025
21	0.089	25.46	0.025
22	0.088	24.59	0.022
23	0.09	25.45	0.023
Average	0.091		0.025
Total		601.34	167.57
30-Day Rlng	0.093	0.027	
365-Day Rlng			58990
12/7/2020			
Hour			
	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu
0	0.092	25.59	0.023
1	0.091	24.53	0.026
2	0.092	25.06	0.025
3	0.088	23.86	0.025
4	0.095	25.52	0.023
5	0.091	25.02	0.025
6	0.094	26.73	0.022
7	0.088	24.28 OOC	OOC
8 Invalid	Invalid	OOC	OOC
9	0.089	25.53	0.029
10	0.086	24.37	0.023
11	0.083	23.58	0.018
12	0.088	24.76	0.026
			7.24
			0.013

13	0.09	25.54	0.025	7.04	0.013
14	0.09	25.7	0.023	6.46	0.012
15	0.088	24.38	0.023	6.28	0.013
16	0.092	23.76	0.023	6.09	0.013
17	0.095	25.76	0.025	6.9	0.013
18	0.104	23.28	0.028	6.24	0.013
19	0.11	21.45	0.033	6.36	0.013
20	0.115	23.16	0.035	7.15	0.012
21	0.094	25.63	0.03	8.35	0.012
22	0.087	24.47	0.025	6.93	0.013
23	0.086	24.72	0.021	6	0.013
Average	0.093		0.025		0.013
Total		566.68		147.42	
30-Day Rlng	0.093		0.027		
365-Day Rlng				59137	

12/8/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	24.36	0.023	6.44	0.013
1	0.091	24.44	0.025	6.78	0.013
2	0.092	25.93	0.028	7.82	0.013
3	0.09	25.03	0.023	6.49	0.013
4	0.09	25.16	0.024	6.77	0.013
5	0.089	25.12	0.024	6.68	0.013
6	0.091	25.57	0.021	5.76	0.013
7	0.087	25.95	0.026	7.69	0.012
8	0.085	25.58	0.025	7.36	0.012
9	0.084	24.85	0.021	6.24	0.012
10	0.087	25.01	0.025	7.14	0.012
11	0.088	25.1	0.022	6.2	0.012
12	0.091	25.03	0.021	5.9	0.012
13 Maint	Maint	Maint	Maint	Maint	Maint
14 Maint	Maint	Maint	Maint	Maint	Maint
15	0.09	28.13	0.03	9.8	0.012
16	0.083	25.06	0.027	8.27	0.012
17	0.085	23.75	0.029	8.18	0.012
18	0.093	26.76	0.015	4.4	0.012
19	0.091	25.85	0.029	8.38	0.012
20	0.095	27.18	0.021	6.12	0.012
21	0.089	25.82	0.022	6.36	0.012
22	0.09	25.57	0.025	7	0.012
23	0.087	25.14	0.022	6.29	0.012
Average	0.089		0.024		0.012
Total		560.39		152.07	
30-Day Rlng	0.093		0.027		
365-Day Rlng				59250	

12/9/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
------	--------------	---------	--------------	---------	-------------

0	0.092	27.07	0.024	7.01	0.012
1	0.085	25.18	0.023	6.75	0.012
2	0.088	25.33	0.021	5.9	0.012
3	0.089	26.8	0.024	7.26	0.012
4	0.088	26.04	0.022	6.59	0.012
5	0.089	25.79	0.024	6.85	0.012
6	0.09	27.04	0.023	6.83	0.012
7	0.083	25.84	0.023	7.16	0.012
8	0.087	26.06	0.021	6.25	0.012
9	0.085	26.25	0.024	7.49	0.012
10	0.083	24.92	0.022	6.71	0.013
11	0.092	26.55	0.028	8.18	0.012
12	0.092	25.93	0.021	6.01	0.012
13	0.093	25.64	0.023	6.28	0.012
14	0.092	26.96	0.028	8.13	0.012
15	0.09	24.66	0.017	4.63	0.013
16	0.094	26.44	0.029	8.25	0.012
17	0.092	26.52	0.023	6.76	0.012
18	0.089	25.71	0.018	5.34	0.012
19	0.085	25.94	0.023	7.06	0.012
20	0.089	25.68	0.024	6.84	0.012
21	0.091	26.15	0.026	7.6	0.012
22	0.093	26.22	0.023	6.6	0.012
23	0.089	25.87	0.017	5	0.012
Average	0.089		0.023		0.012
Total		624.59		161.48	
30-Day Rlng	0.093		0.027		
365-Day Rlng				59221	

12/10/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.089	26.63	0.028	8.2	0.012
1	0.083	24.68	0.017	5.21	0.012
2	0.094	27.23	0.023	6.72	0.012
3	0.087	25.79	0.022	6.58	0.012
4	0.096	26.61	0.022	6.24	0.012
5	0.087	24.89	0.021	5.96	0.012
6	0.092	27.38	0.018	5.46	0.012
7	0.083	26.74	0.037	11.87	0.012
8	0.088	25.47	0.028	8.07	0.013
9	0.081	26.32	0.024	7.81	0.012
10	0.081	25.63	0.024	7.61	0.012
11	0.092	26.22	0.019	5.47	0.013
12	0.091	25.56	0.023	6.55	0.013
13	0.095	26.03	0.027	7.36	0.013
14	0.094	26.3	0.024	6.76	0.013
15	0.092	26.32	0.029	8.14	0.012
16	0.091	25.64	0.019	5.44	0.012

17	0.091	26.09	0.025	7.17	0.012
18	0.089	26.06	0.021	6.04	0.013
19	0.089	25.82	0.022	6.26	0.013
20	0.09	26.01	0.026	7.49	0.013
21	0.096	27.15	0.023	6.63	0.012
22	0.09	25.38	0.02	5.63	0.013
23	0.092	26.91	0.021	6.01	0.012
Average	0.09		0.023		0.012
Total		626.86		164.68	
30-Day Rlng	0.092		0.026		
365-Day Rlng				59187	

12/11/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	25.58	0.024	7.05	0.013
1	0.087	25.28	0.023	6.65	0.013
2	0.094	26.46	0.021	5.88	0.013
3	0.092	26.48	0.022	6.35	0.013
4	0.087	25.57	0.023	6.73	0.013
5	0.092	26.32	0.025	7.25	0.012
6	0.091	26.69	0.021	6.03	0.013
7	0.067	22.06	0.027	8.57 Cal	
8	0.084	25.83	0.025	7.81	0.013
9	0.088	26.29	0.023	6.82	0.012
10	0.09	26.16	0.02	5.83	0.013
11	0.09	25.82	0.028	7.89	0.012
12	0.09	25.86	0.019	5.52	0.012
13	0.093	26.17	0.023	6.52	0.012
14	0.091	26.19	0.023	6.59	0.012
15	0.09	26.17	0.024	6.81	0.012
16	0.089	25.95	0.024	6.93	0.012
17	0.088	25.86	0.023	6.86	0.012
18	0.087	25.76	0.022	6.48	0.012
19	0.087	26.12	0.02	6.08	0.013
20	0.089	26.25	0.024	7.16	0.012
21	0.09	25.86	0.023	6.48	0.013
22	0.093	26.4	0.024	6.79	0.013
23	0.089	26.02	0.024	6.97	0.012
Average	0.088		0.023		0.012
Total		621.15		162.05	
30-Day Rlng	0.092		0.026		
365-Day Rlng				59166	

12/12/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.088	26.73	0.021	6.3	0.013
1	0.081	25.5	0.021	6.47	0.012
2	0.088	25.5	0.023	6.66	0.013
3	0.086	26.68	0.022	6.77	0.013

4	0.084	25.03	0.022	6.42	0.013
5	0.092	26.51	0.025	7.15	0.013
6	0.093	27.48	0.024	7.03	0.013
7	0.075	23.88	0.02	6.49	0.012
8	0.087	26.12	0.021	6.38	0.012
9	0.088	26.17	0.02	5.9	0.012
10	0.088	26.1	0.023	6.81	0.012
11	0.088	26.33	0.019	5.78	0.012
12	0.088	25.36	0.022	6.4	0.012
13	0.091	26.22	0.027	7.65	0.012
14	0.089	25.64	0.023	6.56	0.012
15	0.093	26.49	0.021	5.91	0.012
16	0.091	25.91	0.024	6.95	0.012
17	0.092	26.67	0.024	6.8	0.012
18	0.091	25.79	0.023	6.42	0.012
19	0.091	25.51	0.018	4.96	0.013
20	0.092	26.03	0.024	6.85	0.012
21	0.093	26.26	0.023	6.56	0.012
22	0.095	26.81	0.025	7.1	0.012
23	0.09	25.68	0.024	6.79	0.012
Average	0.089		0.022		0.012
Total		624.4		157.11	
30-Day Rlng	0.092		0.026		
365-Day Rlng				59322	

12/13/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.085	26.53	0.022	6.75	0.012
1	0.091	25.27	0.022	6.01	0.013
2	0.096	26.44	0.026	7.28	0.013
3	0.09	26.07	0.022	6.44	0.013
4	0.095	25.98	0.026	7.04	0.013
5	0.094	25.95	0.026	7.18	0.013
6	0.095	27.5	0.019	5.34	0.012
7	0.085	25.09	0.026	7.77	0.013
8	0.09	26	0.022	6.38	0.013
9	0.083	25.05	0.019	5.77	0.013
10	0.09	25.96	0.02	5.64	0.013
11	0.09	25.81	0.027	7.76	0.012
12	0.091	25.89	0.023	6.47	0.012
13	0.093	25.62	0.023	6.49	0.012
14	0.095	26.47	0.024	6.55	0.012
15	0.095	26.62	0.027	7.41	0.012
16	0.092	25.67	0.024	6.65	0.012
17	0.091	25.81	0.024	6.77	0.012
18	0.091	25.99	0.026	7.33	0.012
19	0.087	26.15	0.021	6.37	0.012
20	0.089	25.85	0.022	6.22	0.012

21	0.085	26.94	0.022	7.05	0.012
22	0.08	25.25	0.02	6.41	0.012
23	0.087	25.46	0.021	6.19	0.012
Average	0.09		0.023		0.012
Total		623.37		159.27	
30-Day Rlng	0.092		0.026		
365-Day Rlng				59295	

12/14/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.34	0.024	6.95	0.012
1	0.09	26.3	0.024	7.08	0.012
2	0.09	25.85	0.023	6.71	0.012
3	0.093	26.39	0.024	6.86	0.012
4	0.089	25.96	0.023	6.65	0.012
5	0.09	26.26	0.022	6.35	0.012
6	0.089	27.34	0.024	7.27	0.012
7	0.079	24.31	0.024	7.46	0.012
8	0.09	26.73	0.023	6.74	0.013
9 Maint	Maint	Maint	Maint	Maint	
10	0.088	30.62	0.023	7.97	0.012
11	0.09	26.91	0.022	6.61	0.012
12	0.081	25.95	0.02	6.28	0.012
13	0.079	24.59	0.021	6.26	0.012
14	0.092	25.84	0.022	6.11	0.012
15	0.091	26.16	0.027	7.78	0.012
16	0.089	25.19	0.024	6.91	0.012
17	0.093	26.64	0.024	6.9	0.012
18	0.091	27.21	0.026	7.79	0.012
19	0.082	24.64	0.023	6.77	0.012
20	0.088	25.89	0.021	6.28	0.012
21	0.096	27.72	0.025	7.13	0.012
22	0.102	29.23	0.023	6.49	0.012
23	0.084	23.72	0.02	5.7	0.012
Average	0.089		0.023		0.012
Total		605.79		157.05	
30-Day Rlng	0.092		0.026		
365-Day Rlng				59271	

12/15/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.086	24.66	0.021	6.05	0.012
1	0.088	25.21	0.022	6.35	0.012
2	0.096	26.71	0.028	7.81	0.012
3	0.087	26.35	0.029	8.86	0.012
4	0.081	25.48	0.022	7.05	0.012
5	0.092	26.79	0.022	6.38	0.012
6	0.091	26.9	0.023	6.86	0.012
7	0.087	25.61	0.018	5.36	0.013

8	0.092	26.18	0.025	6.95	0.013
9	0.084	26.05	0.019	6	0.013
10	0.082	25.24	0.025	7.44	0.013
11	0.094	26.7	0.024	6.98	0.013
12	0.09	25.68	0.018	4.98	0.013
13	0.091	26.05	0.021	5.97	0.013
14	0.092	26.43	0.029	8.46	0.012
15	0.092	26.05	0.023	6.7	0.012
16	0.091	25.55	0.019	5.19	0.012
17	0.094	26.61	0.026	7.5	0.012
18	0.091	25.9	0.024	6.8	0.012
19	0.094	26.29	0.023	6.46	0.012
20	0.089	25.65	0.026	7.59	0.012
21	0.086	26.53	0.023	7.07	0.012
22	0.088	25.84	0.019	5.66	0.012
23	0.09	26.35	0.024	7.01	0.012
Average	0.09		0.023		0.012
Total		624.81		161.48	
30-Day Rlng	0.092		0.026		
365-Day Rlng				59244	

12/16/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.097	26.24	0.024	6.44	0.012
1	0.094	25.37	0.027	7.19	0.013
2	0.095	25.73	0.02	5.48	0.013
3	0.094	26.17	0.023	6.52	0.013
4	0.091	26.16	0.024	6.82	0.013
5	0.091	25.82	0.024	6.72	0.013
6	0.096	27.52	0.024	6.95	0.013
7	0.088	16.39	0.021	3.88	0.018
8	0.114	20.6	0.019	3.4	0.017
9	0.058	10.01	0.019	3.29	0.017
10	0.081	12.21	0.019	2.92	0.017
11	0.08	9.66	0.021	2.5	0.018
12	0.083	10	0.02	2.46	0.018
13	0.09	10.81	0.02	2.44	0.018
14	0.09	10.95	0.02	2.49	0.018
15	0.089	10.82	0.021	2.5	0.018
16	0.089	10.61	0.021	2.45	0.018
17	0.09	10.88	0.021	2.52	0.018
18	0.09	10.98	0.021	2.51	0.018
19	0.089	10.82	0.02	2.48	0.018
20	0.09	11.01	0.021	2.53	0.018
21	0.09	11.09	0.021	2.55	0.018
22	0.09	10.87	0.021	2.51	0.018
23	0.094	9.9	0.024	2.5	0.038
Average	0.09		0.022		0.017

Total		380.62		92.05
30-Day Rlng	0.092		0.026	
365-Day Rlng				59158

12/17/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 DCal	DCal	DCal	DCal	DCal	DCal
7 DCal	DCal	DCal	DCal	DCal	DCal
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down
12 Down	Down	Down	Down	Down	Down
13 Down	Down	Down	Down	Down	Down
14 Down	Down	Down	Down	Down	Down
15 Down	Down	Down	Down	Down	Down
16 Down	Down	Down	Down	Down	Down
17 Down	Down	Down	Down	Down	Down
18 Down	Down	Down	Down	Down	Down
19 Down	Down	Down	Down	Down	Down
20 Down	Down	Down	Down	Down	Down
21 Down	Down	Down	Down	Down	Down
22 Down	Down	Down	Down	Down	Down
23 Down	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng	0.092		0.026		
365-Day Rlng				58980	

12/18/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0 Down	Down	Down	Down	Down	Down
1 Down	Down	Down	Down	Down	Down
2 Down	Down	Down	Down	Down	Down
3 Down	Down	Down	Down	Down	Down
4 Down	Down	Down	Down	Down	Down
5 Down	Down	Down	Down	Down	Down
6 DCal	DCal	DCal	DCal	DCal	DCal
7 DCal	DCal	DCal	DCal	DCal	DCal
8 Down	Down	Down	Down	Down	Down
9 Down	Down	Down	Down	Down	Down
10 Down	Down	Down	Down	Down	Down
11 Down	Down	Down	Down	Down	Down

12	Down	Down	Down	Down	Down
13	Down	Down	Down	Down	Down
14	Down	Down	Down	Down	Down
15	Down	Down	Down	Down	Down
16	Down	Down	Down	Down	Down
17	Down	Down	Down	Down	Down
18	Down	Down	Down	Down	Down
19	Down	Down	Down	Down	Down
20	Down	Down	Down	Down	Down
21	Down	Down	Down	Down	Down
22	Down	Down	Down	Down	Down
23	Down	Down	Down	Down	Down
Average	Down		Down		Down
Total		Down		Down	
30-Day Rlng		0.092		0.026	
365-Day Rlng					58799

12/19/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	Down	Down	Down	Down	Down
1	Inval	OOC	Inval	OOC	Inval
2	Inval	OOC	Inval	OOC	Inval
3	Inval	OOC	Inval	OOC	Inval
4	Inval	OOC	Inval	OOC	Inval
5	Inval	OOC	Inval	OOC	Inval
6	Inval	OOC	Inval	OOC	Inval
7	0.278	22.83	0.042	3.5	Cal
8	0.168	31.39	0.022	4.18	0.039
9	0.095	23.97	0.032	8.08	0.015
10	0.095	26.26	0.028	7.69	0.014
11	0.096	26.88	0.025	6.98	0.013
12	0.093	26.2	0.028	7.93	0.013
13	0.092	25.73	0.026	7.22	0.013
14	0.094	26.3	0.027	7.58	0.013
15	0.093	26.1	0.026	7.18	0.013
16	0.094	26.23	0.028	7.69	0.013
17	0.094	26.22	0.025	6.92	0.013
18	0.095	26.32	0.025	6.98	0.012
19	0.092	26.32	0.029	8.2	0.012
20	0.092	25.66	0.029	8.02	0.012
21	0.096	25.56	0.028	7.4	0.012
22	0.089	25.4	0.022	6.22	0.012
23	0.095	26.45	0.024	6.67	0.012
Average	0.109		0.027		0.014
Total		443.82		118.44	
30-Day Rlng	0.093		0.026		
365-Day Rlng				58740	

12/20/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	26.31	0.028	7.97	0.012
1	0.092	25.52	0.03	8.19	0.013
2	0.092	25.88	0.023	6.52	0.012
3	0.091	25.76	0.024	6.86	0.012
4	0.092	26.72	0.024	7.13	0.012
5	0.091	25.58	0.025	7.12	0.012
6	0.093	26.65	0.031	9.02	0.012
7	0.085	26.01	0.025	7.76	0.012
8	0.09	25.75	0.02	5.84	0.013
9	0.092	26.73	0.029	8.36	0.012
10	0.087	26	0.026	7.74	0.012
11	0.094	26.26	0.027	7.65	0.013
12	0.091	26.08	0.028	7.97	0.012
13	0.093	25.92	0.026	7.27	0.012
14	0.093	25.91	0.027	7.46	0.012
15	0.093	27.05	0.029	8.55	0.012
16	0.088	24.73	0.024	6.58	0.013
17	0.094	27.14	0.03	8.71	0.012
18	0.089	25.78	0.024	7.06	0.012
19	0.091	25.85	0.024	6.95	0.012
20	0.093	26.82	0.026	7.51	0.012
21	0.088	25.1	0.024	6.89	0.012
22	0.092	25.52	0.03	8.32	0.012
23	0.095	26.57	0.027	7.55	0.012
Average	0.091		0.026		0.012
Total		625.64		180.98	
30-Day Rng	0.093		0.026		
365-Day Rng				58752	

12/21/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.087	25.95	0.026	7.87	0.013
1	0.085	25.59	0.027	8.1	0.013
2	0.091	26.21	0.03	8.46	0.013
3	0.09	26.38	0.025	7.4	0.013
4	0.086	25.23	0.025	7.43	0.013
5	0.094	26.31	0.027	7.49	0.013
6	0.09	26.45	0.028	8.11	0.012
7	0.08	26.07	0.023	7.61	0.013
8	0.092	26.54	0.028	7.92	0.013
9	0.088	27.34	0.026	7.93	0.013
10	0.085	25.23	0.028	8.2	0.013
11	0.096	26.79	0.026	7.33	0.013
12	0.091	25.9	0.027	7.49	0.013
13	0.091	25.74	0.032	8.91	0.013
14	0.093	26.12	0.024	6.76	0.013
15	0.094	26.1	0.026	7.25	0.013

16	0.093	26	0.029	8.2	0.013
17	0.092	26.39	0.029	8.19	0.013
18	0.091	25.79	0.026	7.4	0.013
19	0.093	26.09	0.027	7.49	0.013
20	0.091	26.54	0.027	7.93	0.013
21	0.088	26.32	0.026	7.65	0.013
22	0.086	25.54	0.026	7.57	0.013
23	0.092	26.42	0.024	6.96	0.013
Average	0.09		0.027		0.013
Total		627.04		185.65	
30-Day Rlng	0.093		0.026		
365-Day Rlng				58755	

12/22/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.09	26.54	0.024	7.05	0.013
1	0.088	26.33	0.026	7.7	0.013
2	0.088	25.08	0.024	6.87	0.012
3	0.092	25.59	0.028	7.71	0.013
4	0.096	26.66	0.026	7.38	0.013
5	0.093	26.09	0.029	8.18	0.013
6	0.09	26.35	0.025	7.29	0.013
7	0.088	26.28	0.027	8.12	0.013
8	0.091	26	0.023	6.5	0.013
9	0.092	25.89	0.028	7.88	0.013
10	0.096	26.53	0.025	6.91	0.013
11	0.094	26	0.027	7.55	0.013
12	0.094	26.18	0.026	7.23	0.013
13	0.092	24.69	0.022	5.8	0.013
14	0.095	26.47	0.032	9.01	0.013
15	0.095	26.29	0.028	7.58	0.013
16	0.097	26.22	0.028	7.57	0.013
17	0.094	25.84	0.027	7.34	0.013
18	0.093	26.31	0.022	6.31	0.013
19	0.09	25.33	0.027	7.74	0.013
20	0.093	26.6	0.028	7.93	0.013
21	0.089	27.43	0.034	10.28	0.012
22	0.083	24.42	0.022	6.47	0.012
23	0.091	25.71	0.02	5.71	0.013
Average	0.092		0.026		0.013
Total		624.83		178.11	
30-Day Rlng	0.093		0.026		
365-Day Rlng				58760	

12/23/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.092	26.68	0.03	8.69	0.013
1	0.092	26.4	0.024	6.89	0.012
2	0.092	26.11	0.024	6.78	0.012

3	0.095	26.46	0.029	8.21	0.012
4	0.098	27.74	0.029	8.09	0.012
5	0.098	27.68	0.027	7.63	0.011
6	0.105	30.41	0.025	7.27	0.011
7	0.086	24	0.02	5.61	0.013
8	0.093	26.29	0.03	8.42	0.012
9	0.092	25.1	0.032	8.72	0.012
10	0.09	24.09	0.027	7.16	0.013
11	0.094	25.22	0.034	9.15	0.013
12	0.095	25.78	0.025	6.86	0.013
13	0.098	25.75	0.033	8.66	0.013
14	0.094	25.55	0.031	8.55	0.013
15	0.099	27.03	0.032	8.84	0.013
16	0.09	24.15	0.026	6.82	0.013
17	0.097	26.1	0.028	7.7	0.013
18	0.096	25.67	0.026	7.03	0.013
19	0.096	26.46	0.033	8.95	0.013
20	0.097	26.39	0.029	8.03	0.013
21	0.096	26.02	0.032	8.81	0.013
22	0.098	25.73	0.031	8.16	0.013
23	0.098	26.25	0.029	7.7	0.013
Average	0.095		0.029		0.013
Total		627.06		188.73	
30-Day Rlng	0.093		0.026		
365-Day Rlng				58773	

12/24/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.096	27.06	0.025	7.1	0.013
1	0.087	25.55	0.026	7.81	0.013
2	0.099	26.89	0.027	7.24	0.012
3	0.094	25.47	0.025	6.9	0.012
4	0.096	25.99	0.027	7.21	0.012
5	0.095	26.32	0.029	7.9	0.012
6	0.088	23.58	0.032	8.72	0.013
7	0.094	26.56	0.034	9.75	0.013
8	0.092	26.03	0.03	8.61	0.013
9	0.092	26.02	0.025	7.23	0.013
10	0.089	25.57	0.026	7.65	0.013
11	0.097	26.53	0.028	7.72	0.013
12	0.094	25.7	0.031	8.31	0.013
13	0.099	26.45	0.03	7.96	0.013
14	0.094	25.93	0.026	7.21	0.013
15	0.095	26.45	0.022	6.02	0.013
16	0.094	26.08	0.025	7.05	0.016
17	0.095	26.42	0.028	7.86	0.013
18	0.093	26.4	0.027	7.77	0.013
19	0.091	25.77	0.028	7.83	0.013

20	0.092	25.76	0.026	7.2	0.013
21	0.095	26.69	0.028	7.87	0.013
22	0.091	25.93	0.027	7.71	0.013
23	0.089	25.98	0.027	7.83	0.013
Average	0.093		0.027		0.013
Total		625.13		184.46	
30-Day Rlng	0.093		0.026		
365-Day Rlng				58800	
12/25/2020					
Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.5	0.028	8.12	0.013
1	0.09	25.31	0.023	6.49	0.013
2	0.094	25.41	0.023	6.2	0.013
3	0.098	26.19	0.023	6.01	0.013
4	0.097	26.46	0.032	8.73	0.013
5	0.092	25.97	0.024	6.75	0.013
6	0.091	26.91	0.024	7.01	0.013
7	0.086	26.07	0.023	7.04	0.013
8	0.087	25.55	0.027	7.8	0.013
9	0.084	26.92	0.023	7.49	0.013
10	0.074	23.07	0.018	5.76	0.013
11	0.091	26.15	0.026	7.39	0.013
12	0.086	25.51	0.027	7.84	0.013
13	0.094	26.05	0.033	9.05	0.013
14	0.09	25.49	0.027	7.59	0.013
15	0.09	25.46	0.026	7.26	0.013
16	0.092	25.47	0.026	7.27	0.013
17	0.092	25.78	0.026	7.36	0.013
18	0.091	25.98	0.025	7.07	0.013
19	0.092	25.87	0.026	7.32	0.013
20	0.094	26.76	0.029	8.13	0.013
21	0.091	25.76	0.028	7.94	0.013
22	0.092	25.93	0.027	7.8	0.013
23	0.093	26.06	0.026	7.18	0.013
Average	0.091		0.026		0.013
Total		620.63		176.6	
30-Day Rlng	0.093		0.026		
365-Day Rlng				58802	

12/26/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.093	26.55	0.028	7.85	0.013
1	0.096	27.04	0.031	8.64	0.013
2	0.09	25.62	0.026	7.38	0.013
3	0.089	25.83	0.025	7.19	0.013
4	0.093	26.27	0.028	7.77	0.013
5	0.091	26.39	0.028	8.08	0.013
6	0.089	26.89	0.028	8.44	0.013

7	0.08	28.07	0.019	6.77	0.013
8	0.081	24.69	0.018	5.42	0.013
9	0.082	26.85	0.024	7.66	0.013
10	0.079	23.39	0.023	6.8	0.013
11	0.094	26.5	0.033	9.39	0.013
12	0.091	25.91	0.023	6.49	0.013
13	0.093	26.21	0.028	7.8	0.013
14	0.091	25.32	0.025	6.93	0.013
15	0.094	26.25	0.026	7.32	0.013
16	0.094	26.3	0.031	8.83	0.013
17	0.093	26.04	0.03	8.31	0.013
18	0.093	26.33	0.025	7.09	0.013
19	0.092	25.68	0.02	5.6	0.013
20	0.09	26.59	0.028	8.38	0.013
21	0.095	26.32	0.029	8.01	0.013
22	0.077	25.36	0.022	7.21	0.013
23	0.091	26.23	0.025	7.31	0.013
Average	0.09		0.026		0.013
Total		626.63		180.67	
30-Day Rlng	0.093		0.026		
365-Day Rlng				58793	

12/27/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.1	0.026	7.4	0.013
1	0.081	26.58	0.022	7.31	0.013
2	0.089	25.81	0.023	6.76	0.013
3	0.088	26.07	0.026	7.51	0.013
4	0.089	25.62	0.028	8.13	0.013
5	0.09	26.72	0.028	8.31	0.013
6	0.087	25.49	0.025	7.32	0.013
7	0.088	28.4	0.028	8.84 Cal	
8	0.068	25.23	0.021	7.96	0.013
9	0.075	22.94	0.02	6.15	0.014
10	0.099	26.11	0.024	6.34	0.014
11	0.093	25.68	0.029	7.99	0.013
12	0.094	26.34	0.034	9.46	0.013
13	0.092	25.37	0.027	7.38	0.013
14	0.095	26.98	0.03	8.62	0.013
15	0.093	26.4	0.027	7.68	0.013
16	0.093	24.99	0.026	6.83	0.013
17	0.097	26.95	0.031	8.5	0.013
18	0.091	25.36	0.02	5.57	0.013
19	0.096	26.64	0.038	10.5	0.013
20	0.088	25.55	0.026	7.59	0.013
21	0.092	26.86	0.026	7.63	0.013
22	0.089	25.48	0.024	6.78	0.013
23	0.09	25.83	0.026	7.34	0.013

Average	0.09		0.026		0.013
Total		623.5		183.9	
30-Day Rlng	0.092		0.025		
365-Day Rlng				58792	

12/28/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	25.83	0.027	7.69	0.013
1	0.098	27.56	0.035	9.8	0.013
2	0.09	25.7	0.032	9.07	0.013
3	0.094	25.97	0.026	7.25	0.013
4	0.091	25.52	0.021	5.75	0.013
5	0.091	26.17	0.025	7.22	0.013
6	0.093	27.27	0.028	8.37	0.013
7	0.073	21.85	0.026	8.12	0.013
8	0.09	25.81	0.023	6.56	0.013
9	0.089	25.51	0.024	6.79	0.013
10	0.09	24.87	0.033	8.92	0.013
11	0.094	26.71	0.029	8.29	0.013
12	0.09	25.81	0.028	7.97	0.013
13	0.094	26.37	0.027	7.58	0.013
14	0.092	25.76	0.023	6.48	0.013
15	0.089	25.64	0.029	8.53	0.013
16	0.093	25.79	0.022	6.14	0.013
17	0.094	25.79	0.025	6.94	0.013
18	0.093	26.61	0.03	8.57	0.013
19	0.092	26.13	0.027	7.58	0.013
20	0.089	25.78	0.025	7.29	0.013
21	0.091	26.53	0.029	8.38	0.013
22	0.091	25.98	0.028	8.15	0.013
23	0.091	25.32	0.024	6.76	0.013
Average	0.091		0.027		0.013
Total		620.28		184.2	
30-Day Rlng	0.092		0.025		
365-Day Rlng				58782	

12/29/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.108	24.31	0.03	6.82	0.013
1	0.115	24.32	0.037	7.85	0.013
2	0.11	25.28	0.035	8.06	0.013
3	0.109	24.65	0.031	6.93	0.013
4	0.104	23.82	0.034	7.66	0.013
5	0.112	25.79	0.036	8.26	0.013
6	0.112	26.39	0.033	7.71	0.013
7	0.08	23.85	0.016	4.94	0.014
8	0.09	26.22	0.027	8.01	0.013
9	0.093	26.1	0.027	7.54	0.013
10	0.094	26.18	0.026	7.21	0.013

11	0.09	25.5	0.022	6.14	0.013
12	0.093	26.44	0.031	8.72	0.013
13	0.093	26.18	0.024	6.56	0.013
14	0.093	25.71	0.03	8.37	0.013
15	0.097	27.44	0.025	6.99	0.013
16	0.092	26.06	0.024	6.91	0.013
17	0.092	26.04	0.025	7.16	0.013
18	0.096	26.93	0.031	8.6	0.013
19	0.092	26.78	0.025	7.31	0.013
20	0.092	26.79	0.023	6.68	0.013
21	0.09	26.4	0.026	7.66	0.013
22	0.095	26.64	0.023	6.41	0.013
23	0.094	26.8	0.03	8.4	0.013
Average	0.097		0.028		0.013
Total		620.62		176.9	
30-Day Rlng	0.092		0.025		
365-Day Rlng				58754	

12/30/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.094	25.63	0.023	6.43	0.013
1	0.098	27.42	0.029	8.2	0.013
2	0.093	26.37	0.029	8.28	0.013
3	0.094	26.48	0.029	8.14	0.013
4	0.093	26.05	0.025	7.14	0.013
5	0.095	27.71	0.027	7.74	0.013
6	0.094	27.33	0.027	8.02	0.013
7	0.085	25.69	0.023	6.92	0.013
8	0.092	25.5	0.022	6.17	0.014
9	0.095	26.46	0.028	7.65	0.013
10	0.097	26.5	0.034	9.14	0.013
11	0.093	26.43	0.026	7.35	0.013
12	0.093	26.68	0.021	6.11	0.013
13	0.092	25.78	0.03	8.3	0.013
14	0.095	27.31	0.028	8.01	0.013
15	0.096	27.28	0.029	8.41	0.013
16	0.095	25.35	0.033	8.91	0.013
17	0.095	26.99	0.025	7.05	0.013
18	0.095	26.7	0.022	6.18	0.013
19	0.093	26.37	0.026	7.34	0.013
20	0.092	26.46	0.027	7.84	0.013
21	0.093	27.19	0.028	8.3	0.013
22	0.091	26.67	0.028	8.13	0.013
23	0.092	26.59	0.026	7.47	0.013
Average	0.094		0.027		0.013
Total		636.94		183.23	
30-Day Rlng	0.092		0.025		
365-Day Rlng				58744	

12/31/2020

Hour	NOx lb/mmBtu	NOx lbs	SO2 lb/mmBtu	SO2 lbs	CO lb/mmBtu
0	0.091	26.18	0.025	7.21	0.013
1	0.093	25.67	0.026	7.24	0.013
2	0.095	27.42	0.029	8.36	0.013
3	0.09	26.37	0.026	7.65	0.013
4	0.096	27.46	0.029	8.35	0.013
5	0.089	26.46	0.025	7.29	0.013
6	0.092	27.6	0.025	7.58	0.013
7	0.08	23.75	0.037	10.94	0.015
8	0.091	26.86	0.027	7.96	0.013
9	0.092	26	0.025	7.08	0.013
10	0.097	27.39	0.036	10.19	0.013
11	0.089	25.66	0.024	7.1	0.013
12	0.091	26.27	0.031	8.89	0.013
13	0.091	25.8	0.017	4.88	0.013
14	0.097	27.31	0.024	6.72	0.013
15	0.093	26.18	0.022	6.25	0.013
16	0.096	26.45	0.026	7.25	0.013
17	0.094	25.08	0.03	8.08	0.013
18	0.116	22.9	0.038	7.45	0.013
19	0.107	24.1	0.038	8.48	0.013
20	0.096	27.56	0.027	7.71	0.013
21	0.093	26.32	0.03	8.39	0.013
22	0.095	26.33	0.023	6.45	0.013
23	0.095	27.22	0.029	8.16	0.013
Average	0.094		0.028		0.013
Total		628.34		185.66	
30-Day Rng	0.092		0.025		
365-Day Rng				58729	

CO lbs

3.9
3.92
3.93
4.71
3.92
3.96
3.91
4.05
4.15
3.93
3.97
3.96
3.86
3.89
3.91
3.87
3.92
3.91
3.9
3.9
3.95
3.86
3.93
3.91

95.1

CO lbs

3.92
3.96
3.95
3.93
3.91
3.93
3.89
4.02
4.13
3.89
3.92
3.89
3.91
3.94

3.89
3.82
3.97
3.97
3.92
4.01
4.22
4
4.05
4.05

95.1

CO lbs

4.04
4.05
4.09
4.04
4.04
3.88
3.85
3.97
4.45
3.8
3.79
3.78
3.77
3.81
3.79
3.82
3.85
3.9
3.8
3.87
3.93
3.88
3.96
3.96

94.1

CO lbs

3.91

3.94
3.93
3.92
3.95
3.96
3.95
4.03
4.12
3.88
3.92
3.89
3.84
3.92
3.89
3.88
3.93
3.93
4.05
3.95
4.26
3.91
3.96
3.95

94.9

CO lbs

3.9
3.96
3.98
3.93
3.97
3.99
3.95
3.99
4.11
3.89
3.91
3.87
3.83
3.91
3.91
3.88
3.89
3.92

3.85
3.9
3.91
3.89
3.91
3.94

94.2

CO lbs

3.84
3.85
3.87
3.85
3.9
3.89
3.85
3.95
3.65
3.28
3.25
3.7
3.43
3.62
3.65
3.6
3.63
3.67
3.64
3.72
3.7
3.7
3.74
3.75

88.7

CO lbs

3.72
3.78
3.76
3.75
3.79

3.8
3.79
3.89
4.52
3.8
3.79
3.76
3.67
3.68
3.69
3.65
3.75
3.75
3.74
3.88
3.89
3.88
4.01
3.84

91.6

CO lbs

3.5
3.85
3.89
3.85
3.86
3.49
3.81
3.92
4.14
3.87
3.88
3.84
3.79
3.81
3.81
3.79
3.81
3.8
3.78
3.82
3.84
3.8

3.84
3.85

91.6

CO lbs

3.81
3.84
3.84
3.79
3.82
3.86
3.83
3.94
4.24
3.83
4.3
3.82
3.77
3.93
4.24
3.15
3.24
3.85
3.8
3.85
3.81
3.76
3.82
3.79

91.9

CO lbs

3.25
3.32
3.28
3.25
3.53
3.84
3.74
3.9
4.08

3.78
3.82
3.8
3.72
3.77
3.75
3.68
3.74
3.78
3.72
3.81
3.82
3.77
3.84
3.82

88.8

CO lbs

3.73
3.85
3.88
3.84
3.89
3.89
3.81
3.95

Cal

3.67
3.75
3.8
4.13
3.79
3.79
3.73
3.81
3.82
3.78
3.88
3.87
3.82
3.88
3.89

88.3

CO lbs

3.82
3.91
3.93
3.88
3.93
3.92
3.89
3.92
3.88
3.82
3.85
3.89
3.81
3.86
3.86
3.86
3.92
3.95
3.9
3.9
3.92
3.88
3.93
3.92

93.4

CO lbs

3.87
3.91
3.92
3.85
3.95
3.95
3.86
3.89
3.88
3.8
3.82
3.82
3.72

3.74

3.8

3.73

3.8

3.83

3.79

3.89

3.86

3.85

3.89

3.89

3.89

92.3

CO lbs

3.82

3.91

3.88

3.85

3.95

3.92

3.85

3.89

3.88

3.81

3.82

3.81

3.76

3.82

3.93

3.89

3.92

3.94

3.87

3.89

3.9

3.85

3.87

3.88

92.9

CO lbs

3.84
3.92
3.91
3.87
3.9
3.9
3.85
3.86
3.82
3.76
3.73
3.65
3.61
3.67
3.64
3.64
3.68
3.71
3.69
3.81
3.83
3.78
3.87
3.85

90.8

CO lbs

3.8
3.91
3.91
3.85
3.89
3.92
3.86
4.01
4.09
3.85
3.83
3.84
3.76
3.81
3.82
3.79
3.83

3.84
3.82
3.93
3.88
3.84
3.86
3.91

92.9

CO lbs

3.83
3.88
3.9
3.83
3.86
3.87
3.87
4.03
4.08
3.91
3.87
3.87
3.81
3.84
3.83
3.76
3.79
3.92
3.79
3.79
3.83
3.79
3.82
3.86

92.6

CO lbs

3.85
3.86
3.88
3.82

3.85
3.89
3.87
4.01
4
3.83
3.82
3.79
3.7
3.76
3.75
3.74
3.76
3.79
3.78
3.83
3.83
3.79
3.85
3.84

91.9

CO lbs

3.74
3.81
3.81
4.3
3.82
3.82
3.8
3.93
4.09
3.83
3.81
3.78
3.71
3.76
3.76
3.74
3.78
3.77
4.17
3.79
3.77

3.75
3.77
3.79

92.1

CO lbs

3.74
3.76
3.77
3.79
3.81
3.8
4.15
3.86
4.05
3.85
3.82
3.81
3.75
3.74
3.8
3.8
3.83
3.85
3.82
3.83
3.84
3.82
3.85
3.86

92

CO lbs

3.82
3.81
3.81
3.8
3.8
3.79
3.78
3.82

4.08
3.87
3.85
3.89
3.82
3.85
3.82
3.82
3.85
3.84
3.8
3.8
3.8
3.76
3.79
3.8

91.9

CO lbs

3.79
3.79
3.81
3.82
3.83
3.83
3.79
3.89
4.04
3.84
3.82
3.79
3.74
3.75
3.73
3.69
3.74
3.72
3.72
3.76
3.73
3.7
3.76
3.77

90.9

CO lbs

3.74

3.71

3.71

3.67

3.71

3.75

3.7

3.87

4.04

3.79

3.82

3.84

3.75

3.85

3.84

3.8

3.85

3.87

3.82

3.88

3.86

3.81

3.84

3.85

91.4

CO lbs

3.86

3.86

3.79

3.8

3.84

3.88

3.84

3.95

4.08

3.84

3.85

3.83

3.79
3.78
3.77
3.73
3.76
3.75
3.72
3.8
3.8
3.77
3.81
3.83

91.7

CO lbs

3.78
3.81
3.8
3.76
3.79
3.81
3.74
3.85
4.03
3.85
3.77
3.76
3.67
3.74
3.72
3.63
3.71
3.71
3.7
3.76
3.76
3.8
3.75
3.75

90.5

CO lbs

3.69
3.76
3.72
3.75
3.8
3.82
3.74
3.9
4.05
4.23
3.78
3.93
3.71
4.26
3.76
3.67
3.76
3.78
3.77
3.78
3.77
3.71
3.78
3.8

91.7

CO lbs

3.81
3.74
3.77
3.75
3.82
3.81
3.78
3.87
4
3.8
3.83
3.75
3.67
3.73
3.74
3.73

3.76
3.78
3.76
3.8
3.83
3.78
3.83
3.83

91

CO lbs

3.74
3.8
3.82
3.78
3.84
3.85
3.8
3.94
4.03
3.79
3.81
3.78
3.74
3.77
3.75
3.69
3.77
3.8
3.36
3.6
3.74
3.73
3.83
3.84

90.6

CO lbs

3.78
3.8
3.83

3.77
3.83
3.81
3.73
3.86
4
3.73
3.76
3.75
3.72
3.8
3.8
3.73
3.8
4.1
3.76
3.81
3.81
3.71
3.74
3.74

91.2

CO lbs

3.69
3.72
3.76
3.74
3.76
3.77
3.75
3.85
3.96
3.7
3.76
3.75
3.73
3.75
3.75
3.72
3.8
3.78
3.77
3.79

3.78
3.75
3.77
3.8

90.4

CO lbs

3.74
3.75
3.79
3.75
3.8
3.8
3.76
3.86
3.83
3.66
3.63
3.67
3.64
3.85
3.65
3.58
3.6
3.63
3.66
3.75
3.75
3.76
3.75
3.77

89.4

CO lbs

3.73
3.75
3.78
3.72
3.75
3.79
3.74

3.73
3.89
3.79
3.74
3.67
3.61
3.59
3.62
3.57
3.63
3.71
3.59
3.71
3.71
3.72
3.75
3.78

89.1

CO lbs

3.74
3.78
3.75
3.73
3.79
3.78
3.73
3.8
3.95
3.81
3.77
3.73
3.69
3.72
3.72
3.68
3.71
3.74
3.71
4.1
3.79
3.83
3.85
3.85

90.8

CO lbs

3.76

3.8

3.82

3.8

3.77

3.78

3.78

3.8

4.06

3.83

3.83

3.82

3.75

3.79

3.78

3.73

3.78

3.8

3.78

3.85

3.84

3.83

3.8

3.82

91.4

CO lbs

3.78

3.81

3.82

3.79

3.84

3.85

3.78

3.8

4.08

3.83

3.82

3.81

3.77

3.8

3.79

3.75

3.8

3.79

3.77

3.81

3.81

3.75

3.81

3.83

91.5

CO lbs

3.8

3.79

3.77

3.78

3.79

3.74

3.74

3.85

4.09

3.82

3.83

3.79

3.76

3.78

3.79

3.73

3.78

3.79

3.76

3.84

3.86

3.84

3.79

3.81

91.3

CO lbs

3.83
3.81
3.82
3.79
3.82
3.85
3.78
3.81
4.09
3.79
3.81
3.81
3.76
3.81
3.77
3.72
3.78
4.47
3.77
3.81
3.84
3.83
3.87
3.88

92.3

CO lbs

3.86
3.86
3.94
3.87
3.88
3.88
3.84
3.87
4.16
3.85
3.86
3.85
3.78
3.86
3.84

3.82
3.84
3.86
3.81
3.84
3.86
3.85
3.87
3.89

92.8

CO lbs

3.79
3.8
3.82
3.81
3.9
3.9
3.87
3.87
4.16
3.8
3.83
3.86
3.73
3.84
3.82
3.79
3.86
3.84
3.78
3.85
3.83
3.75
3.82
3.84

92.2

CO lbs

3.73
3.86

3.82
3.81
3.81
3.81
3.76
3.81
4.07
3.74
3.79
3.74
3.69
3.8
3.81
3.75
3.82
3.82
3.77
3.83
3.83
3.78
3.83
3.83

91.3

CO lbs

3.77
3.8
3.79
3.74
3.8
3.82
3.77
3.84
4.08
3.83
3.81
3.74
3.78
3.85
3.85
3.8
3.83
3.81
3.74

3.79
3.79
3.76
3.83
3.81

91.4

CO lbs

3.72
3.8
3.8
3.75
3.78
3.75
3.74
3.81
4.01
3.71
3.75
3.9
3.64
3.75
3.75
3.66
3.71
3.71
3.64
3.71
3.72
3.7
3.74
3.77

90

CO lbs

3.7
3.76
3.77
3.73

Inval

Inval

Inval

3.82
3.99
3.72
3.74
3.75
3.67
3.76
3.78
3.7
3.7
3.7
3.69
3.77
3.75
3.7
3.75
3.76

78.7

CO lbs

4.25
9.68
3.48
3.04
3.7
3.83
3.76
3.94
4.06
3.81
3.84
3.81
3.6
3.59
3.66
4.38
3.64
3.68
3.75
3.74
3.77
3.72
3.78

3.78

96.3

CO lbs

3.72

3.74

3.77

3.72

3.79

3.76

3.73

3.84

4

3.75

3.76

3.72

3.63

3.7

3.67

3.64

3.81

3.69

3.63

3.68

3.68

3.67

3.69

3.68

89.5

CO lbs

3.67

3.76

4.09

3.7

3.74

4.03

3.72

3.83

3.9

3.69

3.69
3.69
3.63
3.64
4.04
3.67
3.73
3.75
3.68
3.77
3.77
3.71
3.76
3.75

90.4

CO lbs

3.72
3.73
3.71
3.86
3.77
3.73
3.74
3.82
3.94
3.71
3.7
3.7
3.64
3.73
3.74
4.31
3.72
3.73
3.67
3.73
3.75
3.76
3.77
3.76

90.4

CO lbs

3.74
3.79
3.81
3.77
3.8
3.8
3.77
3.89
4
3.73
3.74
3.7
3.64
3.67
3.65
3.39
3.85
3.73
3.74
3.76
3.78
3.73
3.74
3.74

90

CO lbs

3.71
3.76
3.8
3.74
3.72
3.73
3.71
3.84
4.21
3.77
3.77
3.74
3.69
3.72

3.66
3.79
3.7
3.71
3.7
3.73
3.74
3.69
3.69
3.7

90

CO lbs

3.66
3.75
3.76
3.69
3.73
3.74
3.73
3.82
3.96
3.71
3.72
3.7
3.63
3.65
3.67
3.66
3.73
3.74
3.71
3.74
3.73
3.68
3.72
3.72

89.4

CO lbs

3.68

4.01
3.77
3.74
3.75
3.75
3.74
4.04
3.95
3.73
3.71
3.67
3.63
3.64
3.66
3.62
3.67
3.68
3.64
5.68
3.7
3.64
3.69
4.56

92.4

CO lbs

3.64
3.71
3.71
3.7
3.72
3.69
3.7
3.81
3.95
3.75
3.72
3.67
3.61
3.64
3.71
3.63
3.69
3.7

3.65
3.7
3.66
3.62
3.62
3.64

88.6

CO lbs

3.61
3.71
3.69
3.66
3.69
3.67
3.67
3.76
3.94
3.7
3.72
3.7
3.63
3.65
3.69
3.66
3.72
3.74
3.73
3.79
3.76
3.74
3.77
3.76

89.2

CO lbs

3.69
3.77
3.77
3.74
3.72

3.73
3.66
3.78
3.93
3.73
3.77
3.74
3.66
3.71
3.7
4.14
3.69
3.69
3.67
3.73
3.76
3.72
3.81
3.79

90.1

CO lbs

3.72
3.82
3.72
3.7
3.79
3.79
3.72
3.86
3.97
3.74
3.77
3.75
3.71
3.74
3.74
3.71
3.74
3.78
3.72
3.79
3.81
3.77

3.82
3.83

90.5

CO lbs

3.73
3.77
3.74
3.71
3.76
3.78
3.69
3.83
3.92
3.7
3.65
3.58
3.64
3.67
3.66
3.61
3.7
3.67
3.59
3.67
3.69
3.64
3.68
3.67

88.8

CO lbs

3.64
3.65

Inval

Down

Down

Down

Down

DCal

Down

7.3

Maint

CO lbs
Maint
Maint
Maint
Maint
Maint
Maint
Maint

4.34
3.01

Cal
OOR
OOR

4.77
4.24

Inval

Inval

3.6
3.65
3.7
3.62
3.66
3.63
3.62
3.63
3.65

49.1

CO lbs

3.61
3.64
3.66
3.63
3.69
3.68
3.65
3.77
3.78
3.61
3.63
3.63
3.64
3.73
3.65
3.65
3.74
3.73
3.72
3.76
3.74
3.72
3.75
3.76

88.6

CO lbs

3.72
3.79
3.78
3.74
3.81
3.82
3.79
3.93
3.94
3.73
3.81
3.72
3.73
3.64
3.8
3.77
3.82
3.86
3.8
3.82
3.8
3.77
3.8
3.8

91

CO lbs

3.78
3.79
3.81
3.78
3.82
3.81
3.77
3.81
4.31
4.01
3.7
3.7
3.69
3.69
3.73
3.75
3.78

3.81
3.8
3.85
3.86
3.86
3.88
3.88

91.7

CO lbs

3.86
3.87
3.92
3.9
3.93
3.91
3.88
3.97
4.15
3.91
3.9
3.88
3.88
3.87
3.88
3.81
3.84
3.84
3.85
3.88
3.87
3.92
3.89
3.91

93.5

CO lbs

3.96
3.86
3.87
3.85

3.89
3.92
3.89
3.98
4.1
3.86
3.87
3.82
3.78
3.81
3.82
3.78
3.81
3.81
3.79
3.84
3.86
3.84
3.88
3.9

92.8

CO lbs

3.92
3.9
3.93
3.9
3.92
3.9
3.85
4
4.21
3.98
3.92
4.06

Maint

3.62
3.56
3.54
3.58
3.6
3.6
3.62
3.65

3.63
3.68
3.67

87.2

CO lbs

3.65
3.69
3.67
3.66
3.69
3.69
3.7
3.76
3.96
3.79
3.73
3.7
3.67
3.68
3.67
3.58
3.66
3.64
3.61
3.66
3.67
3.64
3.72
3.74

88.6

CO lbs

3.66
3.7
3.7
3.64
3.69
3.7
3.66
3.76

3.9
3.68
3.75
3.72
3.71
3.75
3.71
3.69
3.7
3.71
3.69
3.68
3.66
3.63
3.68
3.68

88.9

CO lbs

3.63
3.67
3.69
3.63
3.63
3.7
3.82
3.48
3.63
3.6
3.67
3.9
4.19
3.77
3.52
3.51
3.49
3.48
3.46
3.43
3.39
3.4
3.46
3.27

86.4

CO lbs

3.39

3.49

3.64

3.68

3.76

3.83

3.77

4.12

3.99

4.17

4

3.95

3.56

3.86

3.41

3.25

3.21

3.26

3.22

3.25

3.26

3.2

3.21

3.21

3.21

85.7

CO lbs

3.2

3.13

3.21

3.28

3.45

3.41

2.75

2.25

2.31

2.19

2.12

2.14

2.13
2.15
2.17
2.17
2.21
2.21
2.18
2.21
2.18
2.21
2.21

59.7

CO lbs

2.18
2.22
2.7
3.51
3.91
3.97
4.02
3.96
3.91
3.91
3.83
3.84
3.75
2.49
2.3
2.2
2.17
2.2
2.2
2.92
3.52
3.94
3.89
3.78

77.3

CO lbs

3.8
3.82
3.85
3.86
3.85
3.9
4.11
3.95
3.89
3.91
3.9
3.9
3.87
3.83
3.82
3.83
3.83
3.82
3.85
3.81
3.79
3.42
3.55
3.68

91.8

CO lbs

3.71
3.72
3.73
3.8
3.77
3.86
4.07
4.03
3.82
3.77
3.74
3.88
3.72
3.64
3.68
3.67

3.65
3.72
3.78
3.79
3.71
3.74
3.68
3.75

90.4

CO lbs

3.81
3.71
3.67
3.83
3.72
3.84
4.02
3.91
3.8
3.76
3.71
3.73
3.71
3.71
3.68
3.68
3.63
3.81
3.68
3.68
3.62
3.61
3.61
3.63

89.6

CO lbs

3.61
3.61
3.64

3.65
3.62
3.68
4.21
3.78
3.79
3.81
3.76
3.93
3.76
3.73
3.76
3.7
3.68
3.71
3.7
3.68
3.67
3.65
3.66
3.74

89.5

CO lbs

3.75
3.72
3.76
3.78
3.72
3.79
3.91
3.77
3.8
3.76
3.72
3.77
3.77
3.76
3.77
3.72
3.72
3.84
3.83
3.77

3.79
3.87
3.76
3.81

90.7

CO lbs

3.82
3.79
3.83
3.82
3.8
3.86
3.97
3.84
3.88
3.93
3.87
3.83
3.83
3.8
3.82
3.76
3.72
3.82
3.82
3.86
3.93
3.91
3.9
3.92

92.3

CO lbs

4.02
3.97
4.01
2.99

Down

9.14
3.79

4.19
3.88
3.91
3.87
3.88
3.87
3.83
3.86
3.74
3.77
3.78
3.77
3.75
3.76
3.76
3.73
3.78

93.1

CO lbs

3.78
3.79
3.81
3.83
3.82
3.89
4.08
3.92
3.85
3.82
3.77
3.81
3.77
3.73
3.76
3.78
3.73
3.78
3.78
3.74
3.84
3.88
3.85
3.89

91.7

CO lbs

3.84
3.7
3.7
3.72
3.67
3.81

Cal

4.11
3.79
3.74
3.7
3.75
3.71
3.64
3.66
3.66
3.63
3.68
3.69
3.64
3.72
3.77
3.71
3.75

85.8

CO lbs

3.75
3.7
3.71
3.71
3.66
3.74
3.92
3.75
3.77
3.78
3.69

3.71
3.69
3.63
3.67
3.64
3.61
3.68
3.72
3.65
3.7
3.67
3.61
3.67

88.8

CO lbs

3.67
3.66
3.75
3.77
3.7
3.73
3.91
3.75
3.77
3.73
3.67
3.69
3.66
3.62
3.66
3.64
3.63
3.67
3.68
3.64
3.99
3.57
3.55
3.69

88.8

CO lbs

3.68
3.67
3.71
3.72
3.69
3.78
3.96
3.83
3.81
3.78
3.91
3.73
3.72
3.69
3.74
3.73
3.69
4.16
3.75
3.69
3.71
3.72
3.7
3.75

90.3

CO lbs

3.71
3.68
3.72
3.73
3.68
3.77
3.94
3.78
3.78
3.75
3.69
3.71
3.7
3.66
3.68

3.68
3.64
3.68
3.71
3.67
3.68
3.65
3.65
3.69

89

CO lbs

3.68
3.65
3.7
3.71
3.69
3.77

Cal

Cal

3.83
3.88
3.72
3.69
3.71
3.67
3.68
3.65
3.64
3.71
3.71
3.67
3.56
0.44

Down

Down

70.8

CO lbs
Down
Down

Down

Down
Down
Down
Down
Down

Down

CO lbs
Maint
Maint
Maint
Maint
Maint
OOC
OOC

6.47

Inval
Inval
Inval

21.71

Down
Down
Down
Down

28.2

CO lbs
Down
Down
Down
Down
Down
DCal

DCal
Down
Down

Down

CO lbs
Down
Down
Down
Down
Maint
Maint
Maint
Maint

19.25
17.56
16.09
7.13
4.4
8.78
3.09
3.49
3.61
3.71
3.85
4.36
4.09
3.94
3.94

3.93

111.2

CO lbs

3.95

3.95

3.91

4.01

3.99

3.94

4.08

4.02

3.85

3.8

3.77

3.77

3.74

3.74

3.79

3.8

3.71

4.17

3.87

3.8

3.78

3.75

3.73

3.77

92.7

CO lbs

3.77

3.77

4.24

3.8

3.77

3.84

4.02

3.84

3.84

3.84

3.79
3.75
3.76
3.75
3.76
3.76
3.72
3.76
3.73
3.77
3.78
3.75
4.79

92.4

CO lbs

3.82
3.77
3.9
3.82
3.79
3.87
3.96
4.15
3.8
3.79
3.72
3.79
3.83
3.8
3.81
3.82
3.77
3.81
3.8
3.75
3.79
3.85
3.82
3.8

91.8

CO lbs

3.78
3.78
4.05
3.83
3.76
3.82
3.98
3.86
3.76
3.76
3.7
3.74
3.78
3.8
3.84
3.83
3.8
3.81
3.79
3.71
3.76
3.8
3.76
3.8

91.3

CO lbs

3.72
3.7
3.96
3.7
3.43
3.86
4.02
3.86
3.86
3.84
3.77
3.82
3.85
3.91

3.83
3.78
3.81
3.78
3.78
3.75
3.84
3.79
3.75
3.78

91.2

CO lbs

3.73
3.69
3.74
3.76
3.72
3.8
3.99
3.95
3.84
4.13
3.74
3.77
3.73
3.7
3.73
3.77
3.71
3.69
3.68
3.64
3.68
3.68
3.64
3.73

90.2

CO lbs

3.75

3.97
3.73
3.72
3.68
3.73
3.96
3.83
3.81
3.77
3.7
3.72
3.71
3.68
3.71
3.74
3.68
3.43
3.01
3
3.05
3.05
3.06
3.1

85.6

CO lbs

3.09
3.07
3.36
3.56
3.74
3.83
3.39
3.68
3.85
3.78
3.78
3.84
3.78
3.78
3.81
3.82
3.73
3.71

3.72
3.67
3.73
3.81
3.72
3.76

88

CO lbs

3.78
3.73
3.8
3.8
3.79
3.85
4.42
3.88
3.89
3.84
3.82
3.77
4.2
3.85
3.83
3.81
3.78
3.81
3.81
3.75
3.83
3.78
3.74
3.77

92.3

CO lbs

3.73
3.73
3.75
3.76
3.75

3.82
4.03
3.91
3.93
3.86
3.83
3.88
3.83
3.78
3.8
3.8
3.77
3.8
3.79
3.75
3.78
3.8
3.75
3.79

91.4

CO lbs

3.78
3.77
3.82
4.2
3.8
3.9
4.04
3.89
3.87
3.83
3.75
3.77
3.77
3.74
3.76
3.77
3.71
3.76
3.76
3.67
3.44
3.65

3.75
3.79

91

CO lbs

3.81
3.73
3.76
3.75
3.74
3.81

Cal

3.93
3.3
3.28
3.25
3.25
3.23
3.24
3.26
3.24
3.21
3.24
3.25
3.24
3.24
3.21
3.15
3.14

78.3

CO lbs

3.16
3.47
3.2
3.44
3.19
3.77

Maint

4.21
3.74

3.4
3.17
3.17
3.96
4.55
4.52
5.01
4.34
4.13
4.22
4.14
4.14
4.31
3.49
3.47

88.2

CO lbs

4.99
4.56
4.49
4.22
4.23
4.29

Cal

4.33
3.81
3.8
3.74
3.75
4.42
3.64
3.65
3.74
3.7
3.64
3.77
3.72
3.76
3.78
3.76
3.79

91.6

CO lbs

3.83
3.84
3.83
3.83
4.53
3.86
4.43
4.09
4.41
4.16
4.32
4.3
4.18
4.15

Maint

3.92
3.98
3.91
3.97
4.05
4.01
4.05
3.96
4

93.6

CO lbs

4.05
4.1
4.08
4.12
4.15
4.08
3.84
3.85
3.59
3.6
3.58
3.57
3.53

3.52
3.53
3.55
3.78
3.58
3.64
3.7
3.71
3.7
3.7
3.66

90.2

CO lbs

3.66
3.66
3.7
3.72
3.68
3.76
3.87
4.08
3.72
3.67
4.32
3.63
3.78
3.77
3.63
3.93
3.6
3.78
3.67
3.64
3.73
3.88
3.65
3.62

90.2

CO lbs

3.62
3.62
3.68
3.66
3.62
3.68
3.97
3.73
3.7
3.65
3.6
3.89
3.89
3.81
3.6
3.61
3.58
3.83
3.89
3.62
3.65
3.7
4.26
3.7

89.6

CO lbs

3.67
3.65
3.66
3.67
4.42
3.69
4.14
3.71
3.7
3.7
3.62
3.62
3.61
3.64
3.72
3.62
3.56

3.66
3.63
4.49
3.61
3.61
3.59
3.76

89.8

CO lbs

3.58
3.54
3.66
3.73
3.64
3.71
3.91
3.67
3.69
3.66
3.61
3.58
3.62
3.59
3.62
3.63
3.62
3.66
3.64
3.6
3.65
3.69
3.69
3.63

87.6

CO lbs

3.62
3.6
3.94
3.66

3.63
3.73
3.88
3.72
3.72
3.69
3.64
3.67
4.14
3.68
3.64
3.61
3.58
3.61
3.84
4.54
3.72
3.75
3.61
3.68

89.9

CO lbs

3.62
3.8
3.83
3.99
3.59
3.62
3.94
3.7
3.64
3.61
3.58
3.82
3.56
3.49
4.07
3.5
4.13
3.5
3.75
3.59
3.59

3.51
3.49
3.54

88.5

CO lbs

3.69
3.51
3.57
3.75
3.65
3.8
3.79
3.69
3.66
3.63
3.63
3.68
3.72
3.72
3.61
3.77
3.51
3.57
4.11
3.6
3.74
3.63
3.87
4.72

89.6

CO lbs

4.53
3.52
3.66
3.57
3.47
3.55
3.94
3.7

3.66
3.64
3.56
3.57
3.61
3.59
3.63
3.61
3.57
3.6
3.94
3.61
3.65
3.72
3.58
3.56

88

CO lbs

3.66
3.6
3.6
3.6
3.58
3.88
3.81
3.7
3.7
3.63
3.68
3.61
3.63
3.61
3.62
3.61
3.58
3.62
3.51
3.47
3.52
3.53
3.49
3.73

CO lbs

3.53
3.53
3.54
3.58
3.53
3.71
3.78
3.81
3.65
4.02
3.72
3.61
3.65
3.69
3.63
3.57
3.59
3.63
3.76
3.7
3.45
3.44
3.44
3.46

CO lbs

3.47
3.46
3.51
3.49
3.47
3.56
3.84
3.74
3.73
3.85
3.63
3.58

3.64
3.62
3.65
3.63
3.61
3.65
3.59
3.61
3.64
3.66
3.61
3.47

86.7

CO lbs

3.65
3.62
3.65
3.68
3.62
3.72
3.91
3.73
3.69
3.69
3.7
3.62
3.65
3.59
3.59
3.59
3.55
3.57
3.76
3.58
3.62
3.6
3.59
3.63

87.6

CO lbs

3.61
3.61
3.67
3.65
3.64
3.71
3.89
3.74
3.71
3.7
3.65
3.63
3.66
3.66
3.68
3.66
3.64
3.72
3.65
3.66
3.67
3.63
3.6
3.7

88.1

CO lbs

3.63
3.66
3.7
3.72
3.67
3.71
3.91
3.76
3.75
3.73
3.7
3.66
3.94
3.61
3.65
3.62

3.6
3.73
3.63
4.04
3.62
3.61
3.65
3.7

89

CO lbs

3.68
3.65
3.67
3.68
3.66
3.73
3.75
3.54
3.66
4.06
3.65
3.64
3.67
3.7
3.69
3.67
3.65
3.65
3.68
3.67
3.72
3.7
3.88
3.74

88.8

CO lbs

3.66
3.66
3.69

3.7
3.68
4.55
3.91
3.8
3.74
3.7
3.64
3.64
3.66
3.63
3.64
3.63
3.6
3.71
4.15
4.6
3.69
3.71
3.69
3.74

90.8

CO lbs

3.72
3.96
3.6
3.62
3.59
3.65
4.41
3.59
3.44
3.4
3.35
3.35
3.33
3.45
3.28
4.53
3.29
3.33
3.34
3.33

3.37
3.36
3.43
3.34

85.1

CO lbs

3.35
3.36
3.36
3.38
3.33
3.45
3.54
3.39
3.4
4.1
3.3
3.27
3.34
3.33
3.35
3.35
3.3
3.34
3.36
3.32
3.36
3.37
3.33
3.31

81.3

CO lbs

3.22
3.49
3.26
3.27
3.27
4.11

DCal

20.6

Down

CO lbs

Down

Inval

Inval

Inval

Inval

Inval

Down
Down
Down
Down
Down
Down
Down
Down
Down

Down

Down

CO lbs
Down
Down

Down

Down
Down
Down
Down
Down

Down

Down

CO lbs
Down
Down
Maint
Maint
Maint
Maint

Maint
Maint
Maint
Maint
Maint
Maint
Maint
Maint
Maint
Maint
Maint
Maint
Maint
OOC
OOC
OOC
OOC

Maint

CO lbs
OOC
OOC
OOC
OOC
OOC
Cal

3.6
3.78
3.71
3.43
3.44
4.11
3.89
3.83
3.77
3.78
3.75
3.71
3.71
3.72
3.68
3.71
3.69

3.65

67

CO lbs

3.69

3.63

3.63

3.76

3.8

3.79

3.88

3.86

3.58

3.76

3.74

3.67

3.69

3.69

3.69

3.68

3.71

3.69

3.72

3.72

3.72

3.77

3.77

3.75

89.4

CO lbs

3.77

3.8

3.78

3.82

4.72

3.78

3.94

4.23

3.92

3.9

3.85

3.8

3.82

3.84

3.77

3.8

3.8

3.78

3.81

3.8

3.76

3.89

3.79

3.77

92.9

CO lbs

3.79

3.8

3.79

3.81

3.78

3.8

3.94

4.22

3.93

3.89

3.88

3.79

3.86

3.82

3.79

3.86

3.84

3.68

3.83

3.79

3.77

3.79

3.76

3.7

91.9

CO lbs

3.73

3.8

3.73

3.77

3.71

3.73

3.81

4.01

3.71

3.75

3.67

3.7

3.68

3.65

3.54

3.5

3.52

3.54

3.54

3.66

3.66

3.67

4.1

3.65

88.8

CO lbs

3.67

3.7

3.83

3.67

3.68

3.75

3.72

4.04

3.77

3.72

3.66

3.72

3.78

3.85

3.72
3.6
3.61
3.55
3.58
3.6
3.65
3.69
3.6
3.64

88.8

CO lbs

3.7
3.62
3.61
3.68
3.67
3.57
3.66
3.85
3.61
3.71
3.71
3.67
3.64
3.65
3.58
3.63
3.65
3.59
3.65
3.65
3.61
3.61
3.58
3.61

87.5

CO lbs

3.64

3.65
3.58
3.64
3.64
3.57
3.58
3.87
3.6
3.6
3.56
3.52
3.78
3.61
3.61
3.58
3.64
3.68
3.68
3.68
3.62
3.66
3.64
3.56

87.2

CO lbs

3.67
3.69
3.61
3.65
3.67
3.69
3.76
4.09
3.77
3.76
3.72
3.64
3.63
3.66
3.66
3.73
3.7
3.71

3.77
3.73
3.67
4.24
3.75
3.72

89.7

CO lbs

3.74
3.78
3.75
3.76
3.77
3.69
3.76
4.03
3.76
3.74
3.69
3.61
3.65
3.63
3.58
3.67
3.65
3.66
3.73
3.73
3.71
3.78
3.77
3.79

89.4

CO lbs

3.71
3.71
3.86
3.74
3.74

3.71
3.81
4.1
3.75
3.74
3.72
3.61
3.65
3.65
3.64
3.66
3.69
3.64
3.69
3.7
3.68
3.74
3.69
3.68

89.3

CO lbs

3.72
3.72
3.78
3.74
3.73
4.06
3.8
4.04
3.81
3.83
3.78
3.73
3.67
3.65
3.6
3.64
3.69
3.62
3.62
3.66

Inval

Inval

Inval
Inval

74.9

CO lbs

Inval
Inval
Inval
Inval
Inval
Inval

3.74
3.79
4.05
3.82
3.84
3.82
3.71
3.78
3.76
3.75
3.78
3.76
3.72
3.78
3.79
3.76
3.81
3.81
3.71

72

CO lbs

3.72
3.83
3.79
3.84
3.84
3.77
3.88
4.14
3.87

3.89
3.89
3.8
3.82
3.81
3.76
3.79
3.8
3.72
3.68
3.73
3.7
3.74
3.74
3.72

91.3

CO lbs

3.76
3.78
3.75
3.78
3.78
3.75
3.84
4.12
3.84
3.84
3.82
3.72
3.78
3.79
3.79
3.81
3.78
3.73
3.74
3.79
3.76
3.76
3.78
3.7

CO lbs

3.77

3.82

3.8

3.89

4.11

3.9

3.81

3.8

3.76

3.79

4.1

Maint

4.09

4.56

4.66

3.75

3.69

3.7

3.75

3.76

3.72

3.78

3.76

3.69

89.5

CO lbs

3.63

3.65

3.69

3.8

4.06

4.02

3.61

3.58

3.59

3.65

3.65

3.6

3.61

3.65
3.63
3.66
3.72
3.78
3.83
3.84
3.83
3.84
3.85
3.7

89.5

CO lbs

3.65
3.66
3.61
3.67
3.98
3.76
3.82
3.72
3.56
2.53
3.23
3.76
3.81
3.76
3.69
3.72
3.75
3.76
3.81
3.86
3.85
3.83
3.82
3.57

88.2

CO lbs

3.6
3.67
3.63
3.72
4.02
3.81
3.91
3.91
3.84
3.83
3.84
3.85
3.86
3.8
3.71
3.74
3.75
3.75
3.75
3.81
3.85
3.72
3.73
3.73
3.68

90.8

CO lbs

3.66
3.73
3.72
3.81
4.11
3.88
3.89
3.89
3.86
3.85
3.83
3.75
3.76
3.75
3.73
3.77
3.78

3.71
3.71
3.73
3.71
3.77
3.76
3.75

90.9

CO lbs

3.71
3.76
3.77
3.79
3.78
3.84
3.94
3.88
3.84
3.79
3.81
3.82
3.71
3.73
3.68
3.64
3.76
3.73
3.72
3.74
3.71
3.68
3.72
3.7

90.3

CO lbs

3.64
3.71
3.74
3.72

3.78
3.83
3.97
3.64
3.79
3.72
3.72
3.73
3.66
3.72
3.69
3.68
3.69
3.7
3.69
3.7
3.55
3.51
3.61
3.59

88.8

CO lbs

3.59
3.63
3.62
3.59
3.6
3.65
3.82
3.51
3.54
3.51
3.53
3.54
3.5
3.52
3.51
3.48
3.51
3.51
3.48
3.54
3.59

3.6
3.6
3.53

85.5

CO lbs

3.55
3.57
3.57
3.56
3.62
3.77
4.33
3.6
3.52
3.51
3.57
3.59
3.54
3.57
3.6
3.52
3.57
3.6
3.56
3.59
3.59
3.56
3.63
3.57

86.7

CO lbs

3.55
3.59
3.6
3.59
3.6
3.69
3.89
3.7

3.74
3.64
3.6
3.55
3.48
3.51
3.5
3.46
3.49
3.5
3.53
3.61
3.6
3.6
3.61
3.62

86.3

CO lbs

3.62
3.65
3.65
3.58
3.55
3.63
3.92
3.67
3.67
3.63
3.62
3.53
3.47
3.49
3.49
3.47
3.47
3.51
3.55
3.64
3.62
3.55
3.55
3.55

86.1

CO lbs

3.6

3.6

3.6

3.66

3.67

3.74

3.95

3.74

3.91

3.68

3.63

3.6

3.58

3.6

3.65

3.59

3.61

3.61

3.62

3.63

3.6

3.56

3.57

3.56

87.6

CO lbs

3.58

3.59

3.56

3.53

3.58

3.7

3.97

3.75

3.71

3.66

3.67

3.67

3.62
3.63
3.67
3.61
3.61
3.59
3.56
3.61
3.6
3.62
3.64
3.61

87.3

CO lbs

3.57
3.63
3.61
3.61
3.63
3.71
3.98
3.76
3.78
3.69
3.7
3.72
3.6
3.64
3.66
3.64
3.6
3.67
3.62
3.69
3.75
3.67
3.62
3.64

88.2

CO lbs

3.62

3.6

3.62

3.59

3.62

3.75

7.34

3.78

3.76

3.7

3.69

3.66

3.55

3.6

3.64

3.58

3.66

3.67

3.67

3.76

3.74

3.67

3.69

3.7

91.7

CO lbs

3.62

3.68

3.67

3.69

3.71

3.74

3.94

3.74

3.71

3.7

3.74

3.75

3.66

3.68

3.7

3.68

3.73
3.74
3.65
3.61
3.14
3.13
3.17
3.19

86.8

CO lbs

3.16
3.21
3.26
3.54
3.67
3.71
3.94
3.75
3.69
3.62
3.67
3.69
3.67
3.09

Down
Down

49.7

CO lbs
Down
Down
Down

Down

Down
Down
Down
Down

Down

Down

CO lbs
Down
Down
Down
Down
Down
Down
Down
Down

Down

Down

CO lbs

Down

CO lbs

Down

CO lbs
Maint
Maint
Maint
Maint
Maint
Maint
Maint

4.35
3.92
3.79
3.69
3.67
3.64
3.56
3.61
3.6

3.56
3.57
3.56
3.77
3.55
3.52
3.54
3.57
3.56

66

CO lbs

3.56
3.6
3.58
3.53
3.56
3.7
3.96
3.7
3.67
3.62
3.64
3.93
3.72
3.56
3.56
3.49
3.45
3.45
3.44
3.44
3.46
3.44
3.5
3.13

85.7

CO lbs

2.34
2.23

2.4
2.33
2.38
2.41
3.03
2.56
3.03
3.49
3.5
3.5
3.48
3.35
3.42
3.42
3.42
3.45
3.48
3.52
3.48
3.48
3.52
3.47

74.7

CO lbs

3.52
3.57
3.57
3.54
3.56
3.66
3.88
3.63
3.62
3.61
3.63
3.61
3.56
3.56
3.52
3.46
3.49
3.48
3.5

3.55
3.55
3.5
3.52
3.51

85.6

CO lbs

3.52
3.53
3.58
3.59
3.63
3.64
3.83
3.89
4.13
3.47
3.48
3.48
3.43
3.45
3.45
3.42
3.47
3.5
3.47
3.54
3.55
3.48
3.51
3.46

85.5

CO lbs

3.52
3.58
3.56
3.5
3.52
3.62

3.88
3.61
3.62
3.59
3.59
3.59
3.54
3.56
3.57
3.48
3.54
3.61
3.6
3.68
3.6
3.49
3.53
3.47

85.9

CO lbs

3.42
3.45
3.44
3.41
3.43
3.52
3.8
3.62
3.61
3.56
3.86
3.5
3.48
3.53
3.58
3.54
3.58
3.54
3.52
3.6
3.55
3.48
3.48

3.46

85

CO lbs

3.45

3.55

3.53

3.49

3.56

3.67

OOC

3.74

3.61

3.54

3.59

3.58

3.51

3.52

3.48

3.43

3.52

3.51

3.43

3.46

3.44

3.44

3.48

3.44

81

CO lbs

3.44

3.49

3.5

3.48

3.49

3.56

3.64

3.58

3.54

3.53

3.57
3.5
3.44
3.52
3.53
3.45
3.48
3.49
3.51
3.57
3.51
3.46
3.46
3.48

84.2

CO lbs

3.5
3.59
3.62
3.6
3.61
3.76
3.74
3.52
3.58
3.49
3.5
3.5
3.46
3.53
3.58
3.47
3.51
3.58
3.38
3.41
3.23

Down

Down

Down

74.2

CO lbs

Down

Down

Down

Down

Down

DCal

DCal

Down

CO lbs

Down

Down
Down
Down
Down
Down
Down
Down
Down
Down
Down

Down

CO lbs
Down
Down
Down
Down
Down
Down
DCal
DCal
Down
OOC
OOC

OOC

CO lbs
OOC

OOC	
Cal	
	3.6
	3.59
	3.43
	3.45
	3.48
	3.38
	3.67
	3.36
	3.35
	3.38
	3.37
	3.32
	3.52
	3.37
	3.36
	3.39
	3.41
	58.4

CO lbs	
	3.41
	3.42
	3.45
	3.42
	3.45
	3.51
	3.76
	3.53
	3.5
	3.56
	3.47
	3.43
	3.4
	3.39
	3.39
	3.37
	3.4
	3.38

3.38
3.4
3.41
3.4
3.46
3.46

82.8

CO lbs

3.46
3.5
3.51
3.45
3.47
3.51
3.75
3.51
3.47
3.4
3.42
3.42
3.39
3.47
3.39
3.36
3.35
3.37
3.36
3.45
3.38
3.34
3.35
3.35

82.4

CO lbs

3.31
3.31
3.33
3.35
3.41

3.49
Cal
3.35
3.43
3.68
3.69
3.53
3.45
3.54
3.44
3.51
3.47
3.47
3.49
3.42
3.47
3.39
3.39
3.46

79.4

CO lbs

3.53
3.44
3.43
3.48
3.44
3.58
3.8
3.36
3.4
3.42
3.43
3.46
3.41
3.44
3.54
3.48
3.52
3.46
3.37
3.35
3.4
4.1

3.38
3.51

83.7

CO lbs

3.51
3.39
3.4
3.41
3.38
3.42
3.54
3.52
3.48
3.45
3.47
3.55
3.52
3.5
3.46
3.48
3.52
3.42
3.38
3.39
3.37
3.36
3.39
3.44

82.8

CO lbs

3.41
3.28
3.41
3.33
3.36
3.44
3.57
3.47
3.53

3.64
3.8
3.86
3.81
3.68
3.71
3.68
3.73
3.75
3.64
3.63
3.62
3.54
3.58
3.85

86.3

CO lbs

3.48
3.54
3.51
3.48
3.3
3.49
3.77
3.77
3.71
3.61
3.56
3.67
3.62
3.6
3.68
3.65
3.72
3.77
3.63
3.69
3.64
3.48
3.54
3.55

86.5

CO lbs

3.45
3.53
3.59
3.61
3.72
3.88
3.82
3.84
3.84
3.71
3.72
3.88
3.63
3.73
3.72
3.63
3.63
3.67
3.62
3.65
3.58
3.48
3.54
3.58

88.1

CO lbs

3.51
3.55
3.56
3.5
3.52
3.62
3.72
3.67
3.63
3.58
3.56
3.68
3.59

3.54
3.57
3.48
3.51
3.51
3.46
3.5
3.45
3.4
3.5
3.5

85.1

CO lbs

3.44
3.45
3.46
3.44
3.53
3.61
3.6
3.51
3.48
3.45
3.5
3.56
3.46
3.38
3.35
3.4
3.43
3.45
3.4
3.31
3.3
3.3
3.35
3.47

82.6

CO lbs

3.36
3.34
3.38
3.39
3.54
3.72
3.81
3.79
3.8
3.73
3.78
3.7
3.69
3.74
3.63
3.52
3.64
3.62
3.56
3.53
3.5
3.47
3.56
3.62

86.4

CO lbs

3.59
3.66
3.68
3.64
3.79
3.83
3.81
3.76
3.75
3.7
3.73
3.67
3.61
3.53
3.49
3.42
3.45

3.53
3.47
3.49
3.43
3.41
3.42
3.51

86.4

CO lbs

3.43
3.45
3.44
3.44
3.56
3.62
3.64
3.6
3.65
3.67
3.7
3.71
3.58
3.58
3.61
3.49
3.53
3.65
3.59
3.62
3.56
3.49
3.49
3.59

85.7

CO lbs

3.58
3.66
3.61
3.56

3.59
3.56
3.62
3.64
 3.7
3.67
3.69
3.73
3.67
3.69
3.72
3.65
3.73
3.66
3.63
3.66
3.63
3.46
3.56
3.57

87.2

CO lbs

3.5
3.54
3.6
3.6
3.63
3.7
3.79
3.8
3.77
3.79
3.66
3.67
3.6
3.62
3.65
3.52
3.57
3.69
3.73
3.78
3.58

3.47
3.49
3.49

87.2

CO lbs

3.46
3.49
3.5
3.45
3.51
3.6
3.65
3.54
3.54
3.56
3.53
3.56
3.55
3.63
3.6
3.51
3.56
3.6
3.54
3.64
3.63
3.57
3.58
3.53

85.3

CO lbs

3.48
3.53
3.49
3.44
3.47
3.51
3.64
3.57

3.59
3.58
3.64
3.69
3.6
3.61
3.56
3.57
3.55
3.52
3.43
3.5
3.4
3.48
3.43
3.43

84.7

CO lbs

3.47
3.46
3.44
3.42
3.46
3.51
3.61
3.51
3.36
3.97
3.56
3.63
3.49
3.53
3.58
3.59
3.58
3.57
3.58
3.67
3.58
3.55
3.58
3.5

85.2

CO lbs

3.51

3.52

3.53

3.57

3.59

3.58

3.62

3.67

3.68

3.7

3.67

3.63

3.61

3.6

3.62

3.6

3.52

3.52

3.45

3.48

3.54

3.45

3.42

3.49

85.6

CO lbs

3.52

3.81

3.13

2.85

2.87

2.99

3.07

3.05

3.06

3.01

3.05

3.07

3.07
3.05
3.04
3.06
3.11
3.07
3.03
2.99
2.84
2.86
2.87
2.9

73.4

CO lbs

2.9
2.89
2.86
2.85
2.84
3.02

OOC

Cal

3.19
3.05
3.03
3.05
3.07
3.11
3.1
3.06
3.02
3.03
2.98
3
2.96
2.92
2.96
2.87

65.8

CO lbs

2.87
2.92
2.95
2.92
2.96
3.13

Cal

3.7
3.75
3.63
3.65
3.76
3.65
3.74
3.75
3.68
3.72
3.73
3.69
3.67
3.76
3.68
3.75
3.55

80.6

CO lbs

3.51
3.57
3.7
3.65
3.7
3.86

Cal

4.12
3.94
3.73
3.76
3.77
3.67
3.68
3.64
3.54

3.69
3.66
3.58
3.62
3.63
3.53
3.55
3.52

84.6

CO lbs

3.5
3.54
3.54
3.59
3.61
3.69
3.69
3.61
3.71
3.58
3.57
3.59
3.48
3.49
3.54
3.42
3.44
3.53
3.46
3.53
3.44
3.41
3.49
3.39

84.8

CO lbs

3.35
3.51
3.62

3.5
3.54
3.6

Cal

4.06

Maint

4
3.87
3.87
3.69
3.81
3.78
3.7
4.35
6.52
8.74
10.62
12.4
13.58
15.21
13.42

136.7

CO lbs

3.43
3.51
3.49
3.45
3.53
3.73
3.84
3.92
3.89
3.76
3.82
3.79
3.63
3.9
3.79
3.66
3.73
3.67
3.55
3.62

3.62
3.53
3.55
3.56

88

CO lbs

3.52
3.54
3.63
3.6
3.67
3.88
3.85
3.71
3.77
3.65
3.57
3.64
3.59
3.72
3.77
3.62
3.68
3.64
3.53
3.55
3.43
3.28
3.38
3.42

86.6

CO lbs

3.44
3.5
3.5
3.46
3.54
3.61
3.87

3.62
3.57
3.39
3.44
3.42
3.48
3.62
3.52
3.35
3.43
3.44
3.31
3.38
3.34
3.31
3.28
3.3

83.1

CO lbs

3.29
3.31
3.33
3.29
3.27
3.85
3.38
3.12
3.16
3.18
3.26
3.32
3.25
3.27
3.28
3.19
3.22
3.26
3.22
3.22
3.22
3.17
3.23
3.2

78.5

CO lbs

3.28

3.24

3.21

3.21

3.26

3.39

3.61

3.36

3.36

3.29

3.3

3.36

3.4

3.42

3.34

3.24

3.31

3.34

3.28

3.53

3.5

3.36

3.47

3.45

80.5

CO lbs

3.4

3.44

3.45

3.35

3.43

3.5

3.62

3.33

3.36

3.34

3.42

3.36
3.33
3.39
3.36
3.28
3.43
3.3
3.33
3.41
3.37
3.37
3.29
3.32

81.2

CO lbs

3.26
3.28
3.29
3.32
3.35
3.46
4
3.17
3.25
3.35
3.47
3.53
3.49
3.49
3.5
3.46
3.46
3.52
3.51
3.49
3.46
3.35
3.39
3.5

82.4

CO lbs

3.42

3.57

3.57

3.49

3.56

3.52

3.7

3.3

3.32

3.41

3.49

3.57

3.52

3.62

3.59

3.52

3.57

3.66

3.5

3.24

3.44

3.45

3.56

3.55

84.1

CO lbs

3.48

3.53

3.56

3.49

3.5

3.47

3.71

3.66

3.57

3.53

3.57

3.64

3.52

3.59

3.5

3.43
3.52
3.58
3.59
3.52
3.46
3.34
3.39
3.34

84.5

CO lbs

3.35
3.42
3.52
3.48
3.47
3.61
3.6
3.59
3.53
3.54
3.66
3.63
3.55
3.61
3.62
3.47
3.55
3.26
3.24
3.27
3.35
3.36
3.41
3.43

83.5

CO lbs

3.37
3.39

3.65
3.64
3.63
3.69
3.77
3.76
3.75
3.65
3.69
3.47
3.22
3.31
3.31
3.29
3.51
3.5
3.48
3.52
3.44
3.39
3.43
3.39

84.3

CO lbs

3.35
3.4
3.38
3.34
3.39
3.45
3.51
3.51
3.49
3.41
3.43
3.41
3.39
3.42
3.4
3.32
3.54
3.62
3.59

3.65
3.58
3.39
3.46
3.46

82.9

CO lbs

3.43
3.42
3.45
3.3
3.39
3.45
3.05
2.94
3.18
3.41
3.33
3.33
3.25
3.63
3.35
3.31
3.42
3.43
3.2
2.59
2.2
2.72
2.78
2.78

76.3

CO lbs

2.7
2.84
3.01
3.17

OOC

3.37

3.26
3.38
3.33
3.32
3.35
3.37
3.41
4.04
3.42
3.17
3.23
3.23
3.39
3.43
3.45
3.42
3.39
3.44

76.1

CO lbs

3.36
3.48
3.48
3.42
3.18
3.17
3.07
3.17
3.13
3.22
3.32
3.14
3.1
3.17
3.14
3.08
3.12
3.1
3.06
3.12
3.1
3.08
3.09

3.08

76.4

CO lbs

3.04

3.11

3.1

3.14

4.24

3.96

3.54

3.72

3.66

3.47

3.39

3.43

3.4

3.51

3.54

3.34

3.38

3.34

3.35

3.37

3.45

3.43

3.48

4.08

83.5

CO lbs

4.74

4.96

4.54

4.1

OOC

OOC

3.37

3.51

3.38

3.28

3.41
3.43
3.39
3.47
3.87
3.7

Maint

3.5
3.47
3.55
3.53
3.46
3.52
3.54

77.7

CO lbs

3.52
4.15
5.24
5.89

OOC

OOC

3.43
3.45
3.51
3.48
3.57
3.64
3.54
3.43
3.53
3.4
3.41
3.4
3.41
3.5
3.54
3.46
3.48
3.46

81.4

CO lbs

3.43
3.48
3.49
3.49
3.7
3.63
3.5
3.52
3.53
3.41
3.54
3.49
3.37
3.46
3.42
3.34
3.43
3.4
3.47
3.55
3.53
3.43
3.49
3.46

83.6

CO lbs

3.42
3.48
3.48
3.51
3.68
3.58
3.46
3.5
3.51
3.48
3.52
3.54
3.45
3.51

3.46
3.28
3.36
3.49
3.45
3.5
3.47
3.41
3.45
3.46

83.5

CO lbs

3.23
3.39
3.47
3.47
3.52
3.33
3.18
3.35
3.3
3.3
3.28
3.29
3.19
3.25
3.41
3.37
3.31
3.33
3.33
3.43
3.44
3.33
3.39
3.43

80.3

CO lbs

3.38

3.39
3.43
3.37
3.43
3.28
3.2
3.55
3.51
3.43
3.57
3.57
3.33
3.31
3.28
3.22
3.25
3.29
3.35
3.41
3.41
3.36
3.37
3.37

81.1

CO lbs

3.37
3.46
3.44
3.31
3.38
3.36
3.44
3.74
3.66
3.46
3.4
3.35
3.41
3.44
3.4
3.37
3.47
3.37

3.27
3.27
3.3
3.26
3.26
3.27

81.5

CO lbs

3.25
3.41
3.34
3.28
3.31
3.38
3.55
3.36
3.39
3.32
3.44
3.46
3.36
3.35
3.4
3.36
3.4
3.36
3.33
3.32
3.29
3.28
3.34
3.34

80.6

CO lbs

3.27
3.37
3.48
3.39
3.47

3.46
3.55
3.56
3.53
3.46
3.47
3.46
3.41
3.46
3.43
3.37
3.36
3.33
3.36
3.43
3.4
3.22
3.31
3.4

82

CO lbs

3.35
3.39
3.53
3.45
3.42
3.43
3.45
3.5
3.45
3.4
3.39
3.45
3.47
3.44
3.48
3.45
3.39
3.43
3.41
3.46
3.47
3.39
3.25

3.31
3.37

82.1

CO lbs

3.44
3.54
3.54
3.51
3.47
3.47
3.62
3.67
3.66
3.51
3.52
3.5
3.45
3.44
3.4
3.51
3.6
3.64
3.59
3.5
3.46
3.34
3.39
3.35

84.1

CO lbs

3.46
3.5
3.54
3.5
3.49
3.58
3.58
3.61
3.59

3.49
3.52
3.56
3.49
3.54
3.51
3.47
3.51
3.54
3.33
3.28
3.25
2.98

Down
Down

76.3

CO lbs

Down

Down

Down

Down

Down

DCal

DCal

Down

CO lbs

Down

Down

Down

Down

Down

DCal

DCal

Down

Maint

Maint

Maint

Maint

Maint

Maint

CO lbs

Maint

Maint

Maint

Maint

Maint

Maint

3.7

3.63

3.61

3.49

3.45

3.46

3.49

3.52
3.48
3.41
3.35
3.38
3.32
3.36
3.47
3.27
3.35
3.34

62.1

CO lbs

3.3
3.38
3.4
3.3
3.36
3.37
3.44
3.36
3.33
3.21
3.37
3.44
3.32
3.41
3.33
3.2
3.23
3.26
3.23
3.26
3.31
3.28
3.33
3.33

79.8

CO lbs

3.3
3.35
3.33
3.26
3.31
3.41
3.47
3.38
3.44
3.49
3.38
3.3
3.3
3.4
3.37
3.23
3.34
3.26
3.27
3.34
3.46
4.26
5.14
6.06

85.9

CO lbs

6.67
7.51
7.87
7.94
8.16
7.92

OOC

OOC

OOC

OOC

OOC

OOC

Maint

3.8
3.81
3.44
3.35

3.4
3.37
4.3
5.19
5.58
5.78
5.67

93.8

CO lbs

6.02
6.42
6.89
7.5
8.46
3.7
3.4
3.5
3.38
3.34
3.37
3.33
3.33
3.36
3.31
3.21
3.29
3.3
3.18
3.15
3.15
3.1
3.18
3.18

98.1

CO lbs

3.13
3.18
3.21
3.21

3.21
3.18
3.55
3.3

Maint

Maint

3.3
3.28
3.28
3.41
3.38
3.34
3.32
3.34
3.27
3.29
3.33
3.36
3.4
3.29

72.6

CO lbs

3.32
3.4
3.45
3.42
3.55
3.51
3.47
3.54
3.56
3.44
3.36
3.31
3.33
3.39
3.41
3.47
3.62
3.85
3.66
3.56
4.14

4.26
4.35
4.38

86.8

CO lbs

4.39
4.12
4.03
3.85
3.86
4.01

Cal

3.38
3.41
3.42
3.28
3.41
3.44
3.52
3.47
3.46
3.44
3.48
3.49
3.42
3.52
3.48
3.46
3.43

82.8

CO lbs

3.46
3.42
3.48
3.48
3.43
3.55
3.66
3.51

3.5
3.45
3.37
3.43
3.49
3.46
3.44
3.42
3.29
3.31
3.48
3.49
3.53
3.6
3.42
3.44

83.1

CO lbs

3.46
3.43
3.49
3.53
3.5
3.64
3.71
3.52
3.51
3.44
3.4
3.42
3.37
3.35
3.44
3.43
3.36
3.43
3.5
3.43
3.5
3.51
3.47
3.48

83.3

CO lbs

3.48

3.39

3.45

3.44

3.4

3.53

3.65

3.44

3.5

3.51

3.4

3.46

3.42

3.37

3.4

3.4

3.39

3.44

2.64

2.86

3.48

3.48

3.43

3.37

81.3

CO lbs

3.38

3.4

3.38

3.38

3.28

3.44

3.58

3.4

3.54

3.51

3.45

3.47

3.49
3.41
3.41
3.46
3.32
3.4
3.49
3.38
3.45
3.41
3.37
3.4

82.2

CO lbs

3.39
3.38
3.42
3.37
3.32
3.41
3.56
3.43
3.41
3.38
3.33
3.35
3.38
3.35
3.39
3.39
3.36
3.38
3.38
3.32
3.37
3.39
3.34
3.42

81.2

CO lbs

3.35
3.38
3.37
3.34
3.31
3.45
3.6
3.42
3.41
3.39
3.33
3.37
3.4
3.35
3.41
3.38
3.34
3.42
3.42
3.32
3.37
3.35
3.29
3.27

81

CO lbs

3.26
3.31
3.38
3.36
3.26
3.43
3.61
3.21
3.21
3.21
3.26
3.38
3.28
3.34
3.44
3.44

3.36
3.36
3.37
3.35
3.38
3.35

Down
Down

73.6

CO lbs

Down

Down

Down

Down

Down

DCal

DCal

Down

CO lbs

Down

Down

Down

Down

Down
Down
Down
Down

Down

CO lbs
Down
Down
Down
Down
Down
Down
Down
Down
Maint
Cal
OOC

3.58
3.7
3.66
3.71
4.13
4.85
5.3

28.9

CO lbs
6.08
6.16
5.72
5.58
5.53
5.64
3.72

3.36
3.31
3.35
3.34
3.45
3.46
3.4
3.49
3.5
3.44
3.52
3.6
3.46
3.56
3.59
3.45
3.53

97.2

CO lbs

3.46
3.4
3.49
3.29
3.09
3.38
3.5
3.48
3.6
3.54
3.53
3.47
3.48
3.44
3.53
3.46
3.41
3.5
3.45
3.13
3.21
3.03
2.76
2.75

80.4

CO lbs

2.74

2.68

2.74

2.71

2.68

2.82

2.87

2.72

2.74

2.94

2.93

3.15

3.44

3.36

3.42

3.41

3.41

3.43

3.46

3.34

3.37

3.32

3.07

1.51

72.3

CO lbs

1.14

Down

1.93

OOR

4.15

3.33

3.53

3.46

3.52

3.45

3.38

3.43
3.44
3.55
3.44
 3.4
3.34
3.41
3.44
3.36
3.38
3.33
3.27
3.29

72

CO lbs

3.29
3.45
3.45
3.55
3.53
3.73
3.81
3.49
3.46
3.63
3.53
3.39
3.42
3.39
3.42
 3.4
3.32
3.44
3.43
3.36
 3.4
3.44
3.37
3.42

83.1

CO lbs

3.33

3.31

3.37

3.4

3.44

3.67

3.76

3.52

3.55

3.42

3.48

3.58

3.45

3.4

3.4

3.61

3.23

3.32

3.42

3.4

3.36

3.32

3.3

3.31

82.4

CO lbs

3.36

3.46

3.63

3.62

3.52

3.58

3.76

3.52

3.44

3.4

3.36

3.38

3.39

3.34

3.36

3.39
3.32
3.39
3.42
3.38
3.43
3.43
3.37
3.37

82.6

CO lbs

3.39
3.36
3.36
3.37
3.34
3.46

OOC

3.24
3.33
3.33
3.27
3.41
3.39
3.33
3.34
3.4
3.37
3.38
3.38
3.38
3.45
3.4
3.4
3.38

77.5

CO lbs

3.39
3.37

3.39
3.4
3.41
3.46
3.64
3.48
3.46
3.37
3.37
3.67
3.45
3.38
3.37
3.39
3.32
3.4
3.43
3.43
3.39
3.38
3.35
3.3

82

CO lbs

3.34
3.37
3.43
3.43
3.55
3.73
3.85
3.64
3.57
3.5
3.37
3.4
3.4
3.42
3.44
3.46
3.37
3.45
3.5

3.45
3.51
3.45
3.39
3.38

83.4

CO lbs

3.4
3.38
3.44
3.42
3.35
3.46
3.78
3.54
3.51
3.48
3.44
3.44
3.51
3.44
3.39
3.4
3.34
3.44
3.47
3.44
3.41
3.46
3.38
3.41

82.7

CO lbs

3.41
3.35
3.38
3.41
3.36
3.44

3.68
3.75
3.59
3.55
3.42
3.42
3.43
3.4
3.37
3.4
3.26
3.38
3.43
3.39
3.39
3.39
3.41
3.54

82.6

CO lbs

3.55
3.51
3.51
3.49
3.42
3.86
3.76
3.5
3.55
3.43
3.4
3.45
3.45
3.41
3.43
3.48
3.25
3.22
3.32
3.28
3.86
4.45
4.67

4.56

86.8

CO lbs

4.6

4.6

4.58

4.57

4.51

4.8

3.36

3.21

3.24

3.19

3.13

3.4

3.38

3.34

3.22

3.24

3.25

3.35

3.32

3.23

3.28

3.35

3.43

3.42

87

CO lbs

3.29

3.23

3.31

3.19

3.35

3.7

4.14

3.48

3.1

3.24

3.38
3.49
3.23
2.96
3.27
3.37
3.3
3.4
3.42
3.26
3.33
3.33
3.29
3.38

80.4

CO lbs

3.42
3.43
3.53
3.68
3.46
3.53
3.7
3.36
3.36
3.35
3.34
3.43
3.47
3.42
3.42
3.41
3.32
3.34
3.34
3.3
3.35
3.34
2.47
2.39

80.2

CO lbs

2.46
2.44
2.5
2.48
2.42
2.5
2.49
2.92
3.59
3.57
3.51
3.57
3.58
3.54
3.61
3.61
3.56
3.6
3.56
3.5
3.55
3.54
3.47
3.53

77.1

CO lbs

3.53
3.51
3.55
3.55
3.47
3.57
3.65
3.58
3.59
3.79
3.69
3.42
3.79
3.71

3.72
3.48
3.45
3.52
3.49
3.48
3.48
3.49
3.45
3.49

85.5

CO lbs

3.47
3.46
3.51
3.48
3.64
3.7
3.96
3.66
3.63
3.67
3.6
3.47
3.47
3.46
3.53
3.35
3.03
3.12
3.15
3.16
3.5
3.57
3.5
3.53

83.6

CO lbs

3.47

3.48
3.51
3.44
3.54
3.64
 3.7
3.37
3.27
3.22
3.18
3.19
3.23
3.32
3.44
3.46
3.49
3.66
3.55
3.59
3.66
3.57
3.62
3.51

83.1

CO lbs

3.53
3.61
3.53
3.54
3.52
3.68
3.85
 3.8
3.68
3.62
3.49
3.44
3.49
3.62
3.46
3.29
3.28
3.36

3.46
3.49
3.53
3.54
3.54
1.99

83.3

CO lbs

Down

Down

Down

Down

Down

Down

Down
P

Down

Down
Downs

Down

Down
P

Down

Down

Down

Down

CO lbs

Down

Down

Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down

Down

CO lbs
Down
Down
Down
Maint
Maint
Maint
Maint
Maint
Maint
Maint
Maint
Maint
Maint

4.45
3.29
3.29
3.33
3.32
3.28
3.3
3.41
3.51
3.51
3.51

3.46
3.46

45.1

CO lbs

3.52
3.62
3.54
3.57
3.55
3.66
3.81
3.67
3.57
3.88
3.68
3.33
3.33
3.34
3.34
3.36
3.39
3.46
3.54
3.51
3.47
3.53
3.67
3.53

84.9

CO lbs

3.61
3.63
3.66
3.67
3.57
3.66
3.77
3.73
3.66

3.61
3.59
3.55
3.57
3.68
3.56
3.57
3.56
3.59
3.62
3.62
3.59
3.61
3.59
3.68

87

CO lbs

3.68
3.66
3.6
3.57
3.59
3.67
3.74
3.66
3.7
4.05
3.86
3.46
3.72
3.74
3.62
3.61
3.58
3.63
3.66
3.62
3.63
3.59
3.56
3.55

87.8

CO lbs

3.53
3.59
3.59
3.59
3.59
3.7
3.92
3.91
3.72
3.9
3.87
3.6
3.72
3.66
3.69
3.57
3.53
3.57
3.62
3.65
3.64
3.58
3.53
3.53

87.8

CO lbs

3.53
3.55
3.57
3.56
3.63
3.69
3.89
3.77
3.65
3.86
3.79
3.52
3.59

3.6
3.54
3.55
3.52
3.59
3.64
3.62
3.61
3.58
3.5
3.54

86.9

CO lbs

2.54
2.4
2.36
2.38
2.34
2.36
2.4
3.84
3.67
4.16
4
3.61
3.9
3.78
3.56
3.62
3.55
3.62
3.61
3.55
3.5
3.6
3.53
3.6

79.5

CO lbs

3.57
3.63
3.62
3.7
3.61
3.69
3.73
3.59
3.54
3.58
3.63
3.59
4.01
3.98
3.58
3.57
3.54
3.56
3.5
3.56
3.62
3.57
3.52
3.55

87

CO lbs

3.63
3.65
3.54
3.53
3.56
3.59
4.06
3.95
3.79
4.06
3.99
3.57
3.58
3.89
3.61
3.55
3.5

3.54
3.62
3.53
3.52
3.59
3.6
3.64

88.1

CO lbs

3.63
3.56
3.58
3.62
3.23
3.17
3.36
3.15
3.14
3.14
3.14
3.15
3.1
3.06
3.06
3.08
3.01
3.07
3.08
3.02
3.13
3.13
3.13
3.15

76.9

CO lbs

3.19
3.14
3.17
3.09

3.08
3.1
3.35
3.28
3.21
3.15
3.11
3.1
3.05
3.12
3.19
3.11
3.11
3.13
3.18
3.16
3.17
3.19
3.16
3.19

75.7

CO lbs

3.17
3.14
3.2
3.17
3.1
2.88
2.31
2.18
2.32
2.25
2.16
2.15
2.08
1.98
2.11
2.2
2.18
2.23
2.26
3.31
3.45

3.39
3.68
3.5

64.4

CO lbs

3.58
3.62
3.54
3.54
3.5
3.61
3.73
3.67
3.57
3.92
3.7
3.43
3.43
3.46
3.44
3.48
3.45
3.48
3.52
3.55
3.59
3.59
3.53
3.51

85.4

CO lbs

3.52
3.76
3.59
3.64
3.56
3.63
3.76
3.68

3.59
3.51
3.47
3.43
3.48
3.59
3.44
3.44
3.39
3.45
3.51
3.49
3.53
3.52
3.46
3.51

85

CO lbs

4.27
3.96
3.52
3.56
3.5
3.62
3.82
3.62
3.54
3.8
3.77
3.44
3.73
3.72
3.48
3.43
3.37
3.43
3.49
3.43
3.47
3.62
3.71
3.53

86.8

CO lbs

3.55

3.57

3.46

3.44

3.54

3.58

3.9

3.65

3.55

3.52

3.58

3.43

3.57

3.59

3.48

3.5

3.48

3.53

3.51

3.58

3.56

3.58

3.56

3.8

85.5

CO lbs

Down

Down

Down

Down

Down

DCal

DCal

Down

Down

Down

Down

Down

Down
Down
Down
Down
Down
Down
Down
Down

Down

Down

CO lbs
Down
Down
Down

Down

Down
Down
Down
Down

Down

Down

CO lbs
Down
Down
Down
Down
Down
Down
Down
Down

Down

Maint

CO lbs

OOC

OOC

OOC

OOC

OOC

OOC

3.68

3.77

3.74

3.69

3.6

3.63

3.65

3.66

3.71

3.71

3.68

3.75

3.75

3.7

3.71

3.64

3.65

3.63

66.4

CO lbs

3.65

3.58

3.63

3.6

3.63

3.65

3.81

3.76

3.72

3.71

3.72

3.71
3.69
3.8
3.73
3.71
3.65
3.71
3.68
3.65
3.65
3.66
3.63
3.66

88.4

CO lbs

3.69
3.65
3.69
3.72
3.71
3.8
3.89
3.72
3.7
3.7
3.66
3.7
3.64
3.6
3.65
3.7
3.63
3.68
3.68
3.64
3.62
3.56
3.55
3.58

88.2

CO lbs

3.07
2.96
3.06
3
2.98
3.06
3.06
2.97
2.95
2.96
2.91
2.95
2.91
2.94
3.02
2.91
2.88
2.91
2.91
2.91
2.95
2.97
2.95
2.95

71.1

CO lbs

2.98
2.96
2.88
2.93
2.94
2.98
3.05
3.07
3.01
2.95
2.93
2.92
2.96
2.93
2.9

2.9
2.85
2.89
2.89
2.9
2.93
2.96
2.97
2.98

70.7

CO lbs

3.58
3.68
3.66
3.68
3.67
3.69
3.74
3.82
3.73
3.66
3.6
3.58
3.56
3.54
3.59
3.62
3.63
3.67
3.71
3.69
3.71
3.68
3.69
3.71

87.9

CO lbs

3.73
3.66

3.7
3.72
3.65
3.63
3.69
3.81
3.79
3.78
3.72
3.74
3.74
3.72
3.73
3.67
3.66
3.7
3.7
3.69
3.72
3.7
3.68
3.69

89

CO lbs

3.69
3.71
3.71
3.69
3.67
3.7
3.78
3.87
3.78
3.74
3.59
3.62
3.58
3.61
3.6
3.6
3.57
3.62
3.67

3.63
3.64
3.64
3.6
3.62

87.9

CO lbs

3.66
3.64
3.66
3.64
3.61
3.67
3.73
3.79
3.72
3.65
3.56
3.59
3.63
3.57
3.6
3.61
3.58
3.6
3.61
3.6
3.67
3.63
3.6
3.63

87.3

CO lbs

3.62
3.58
3.59
3.62
3.57
3.6

3.66
3.76
3.67
3.64
3.57
3.54
3.62
3.54
3.58
3.59
3.55
3.61
3.6
3.59
3.66
3.65
3.56
3.59

86.6

CO lbs

3.61
3.58
3.62
3.6
3.55
3.6
3.64
3.62
3.59
3.55
3.47
3.54
3.47
3.44
3.54
3.48
3.44
3.46
3.5
3.48
3.5
3.51
3.49

3.53

84.8

CO lbs

3.54

3.54

3.55

3.54

3.54

3.55

3.67

3.73

3.74

3.63

3.49

3.5

3.5

3.42

3.46

3.48

3.48

3.54

3.56

3.52

3.6

3.59

3.53

3.61

85.3

CO lbs

3.58

3.5

3.61

3.65

3.65

3.69

3.77

3.82

3.76

3.66

3.53
3.53
3.59
3.57
 3.6
3.55
3.51
3.56
3.57
3.54
3.57
3.57
3.13
3.11

85.6

CO lbs

3.17
3.1
3.11
3.11
3.08
3.16
3.2
3.3
3.25
3.18
3.12
3.15
3.13
3.09
3.14
3.17
3.15
3.15
3.14
3.12
3.13
3.13
3.12
3.18

75.6

CO lbs

3.19
3.17
3.21
3.19
3.17
3.21
3.3
3.31
3.25
3.2
3.17
3.16
3.19
3.19
3.2
3.16
3.13
3.14
3.14
3.13
3.21
3.14
2.67
2.22

75.1

CO lbs

2.2
2.16
2.15
2.16
2.13
2.19
3.06
3.29
3.19
3.11
3.05
2.7
2.24
2.16

2.13
2.18
3.12
3.33
3.21
2.7
3.3
2.62
2.25
2.52

63.2

CO lbs

2.5
2.51
2.54
2.5
2.51
3.12
3.49
3.62
3.48
3.21
3.13
3.38
3.48
3.53
3.38
3.4
3.3
3.31
3.34
3.49
3.38
3.31
3.24
3.25

76.4

CO lbs

3.29

3.2
3.26
3.37
3.46
3.84
4.04
3.97
3.77
3.91
3.64
3.77
3.88
3.72
3.7
3.66
3.45
3.6
3.5
3.57
3.55
3.61
3.43
3.47

86.7

CO lbs

3.39
3.47
3.51
3.43
3.34
3.41
3.48
3.71
3.58
3.49
3.49
3.4
3.45
3.36
3.4
3.4
3.39
3.47

3.55
3.49
3.56
3.55
3.4
3.51

83.2

CO lbs

3.6
3.44
3.44
3.42
3.45
3.49
3.48
3.71
3.53
3.42
3.34
3.34
3.36
3.34
3.34
3.42
3.35
3.4
3.43
3.49
3.51
3.59
3.48
3.29

82.7

CO lbs

3.32
3.39
3.42
3.38
3.3

3.32
3.45
3.65
3.4
3.35
3.33
3.36
3.36
3.42
3.43
3.47
3.4
3.57
3.62
3.53
3.56
3.52
3.45
3.6

82.6

CO lbs

3.5
3.45
3.52
3.64
3.54
3.64
3.72
3.9
3.64
3.47
3.43
3.46
3.46
3.35
3.31
3.36
3.32
3.19
3.33
3.35
3.32
3.3
3.29

3.26
3.26

82.6

CO lbs

3.27
2.62
2.67
2.69
2.58
2.65
2.7
2.95
2.52
2.53
2.4
2.3
2.35
3.21
3.43
3.42
3.49
3.51
3.51
3.49
3.45
3.46
3.4
3.42

72

CO lbs

3.4
3.45
3.54
3.52
3.44
3.48
3.63
3.6
3.58

3.51
3.46
3.46
3.46
3.38
3.42
3.41
3.47
3.09
3.16
3.12
3.14
3.1
3.05
3.12

81

CO lbs

3.32
3.51
3.5
3.55
3.47
3.47
3.53
3.61
3.62
3.45
3.41
3.45
3.47
3.42
3.48
3.47
3.49
3.5
3.53
3.41
3.42
3.42
3.38
3.45

83.3

CO lbs

3.53
3.48
3.53
3.48
3.55
3.63
3.68
3.6
3.64
3.49
3.45
3.4
3.38
3.48
3.6
3.44
3.42
3.54
3.58
3.57
3.62
3.63
3.56
3.56

84.8

CO lbs

3.51
3.47
3.55
3.56
3.49
3.52
3.63
3.64

Inval

3.76
3.66
3.71
3.55

3.58
3.54
3.5
3.3
3.44
2.85
2.45
2.51
3.41
3.54
3.62

78.8

CO lbs

3.55
3.46
3.64
3.63
3.6
3.61
3.67
3.69
3.7
3.66
3.52
3.53
3.43

Maint
Maint

3.85
3.75
3.51
3.52
3.52
3.51
3.55
3.48
3.53

78.9

CO lbs

3.59
3.64
3.59
3.77
3.66
3.57
3.71
3.8
3.66
3.78
3.79
3.54
3.47
3.42
3.6
3.44
3.44
3.49
3.5
3.72
3.53
3.45
3.44
3.54

86.1

CO lbs

3.63
3.65
3.55
3.6
3.39
3.52
3.61
3.9
3.63
4.04
3.93
3.56
3.54
3.48
3.51
3.53
3.49

3.53
3.66
3.71
3.62
3.54
3.53
3.63

86.8

CO lbs

3.77
3.63
3.55
3.62
3.69
3.58
3.68

Cal

3.92
3.72
3.67
3.57
3.54
3.53
3.56
3.56
3.56
3.62
3.61
3.79
3.69
3.61
3.55
3.63

83.7

CO lbs

3.82
3.93
3.64
3.92

3.82
3.64
3.71
3.93
3.73
3.66
3.63
3.63
3.58
3.51
3.55
3.54
3.5
3.54
3.52
3.54
3.5
3.51
3.47
3.5

87.3

CO lbs

3.86
3.5
3.47
3.62
3.45
3.49
3.6
3.71
3.62
3.86
3.63
3.53
3.52
3.45
3.47
3.47
3.47
3.53
3.54
3.66
3.54

3.9
3.91
3.61

86.4

CO lbs

3.55
3.6
3.57
3.51
3.6
3.59
3.77
3.86
3.73

Maint

4.23
3.62
3.87
3.72
3.44
3.45
3.39
3.44
3.57
3.59
3.52
3.43
3.41
3.38

82.8

CO lbs

3.47
3.5
3.45
3.69
3.84
3.55
3.6
3.73

3.64
3.96
3.93
3.58
3.57
3.61
3.55
3.52
3.5
3.54
3.54
3.47
3.6
3.82
3.62
3.63

86.9

CO lbs

3.33
3.42
3.44
3.55
3.66
3.6
3.64
3.39
2.98
2.88
2.55
2.19
2.16
2.13
2.18
2.19
2.15
2.21
2.2
2.17
2.21
2.23
2.2
3.76

66.4

CO lbs

Down

Down

Down

Down

Down

Down

DCal

DCal

Down

DCal

DCal

Down

Down

Down

Down

Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down
Down

Down

CO lbs
Down
OOC
OOC
OOC
OOC
OOC
OOC
Cal

7.19
3.74
3.74
3.68
3.64
3.68
3.65
3.66
3.61
3.54
3.42
3.52
3.43
3.32
3.56
3.48

60.9

CO lbs

3.49
3.49
3.47
3.46
3.53
3.49
3.5
3.76
3.63
3.61
3.76
3.51
3.54
3.48
3.46
3.59
3.53
3.62
3.6
3.52
3.58
3.56
3.45
3.49

85.1

CO lbs

3.76
3.8
3.6
3.67
3.74
3.56
3.64
4.08
3.66
3.9
3.83
3.58
3.62
3.65
3.58
3.57

3.62
3.71
3.67
3.61
3.75
3.81
3.75
3.64

88.8

CO lbs

3.74
3.78
3.54
3.52
3.5
3.56
3.72
3.83
3.68
3.61
3.51
3.52
3.54
3.44
3.54
3.5
3.42
3.51
3.58
3.55
3.59
3.82
3.69
3.58

86.3

CO lbs

3.66
3.55
3.45

3.35
3.28
3.2
3.23
3.53
3.48
3.4
3.43
3.47
3.49
3.49
3.6
3.59
3.56
3.45
3.47
3.58
3.54
3.49
3.41
3.46

83.2

CO lbs

3.62
3.7
3.34
3.36
3.32
3.41
3.38
3.73
3.78
3.74
3.86
3.63
3.59
3.55
3.61
3.67
4.49
3.71
3.73
3.72

3.72
3.66
3.67
3.78

87.8

CO lbs

3.89
3.74
3.55
3.55
3.6
3.69
3.86
4.02
3.85
4.2
4.13
3.76
3.94
3.7
3.74
3.76
3.69
3.75
3.81
3.79
3.8
3.8
3.77
3.78

91.2

CO lbs

3.79
3.72
3.8
3.82
3.75
3.86
4.02

4.53
4.06
4.28
3.99
3.71
3.73
3.73
3.68
3.69
3.67
3.72
3.76
3.71
3.95
3.68
4.36
3.79

92.8

CO lbs

3.81
4.27
3.78
3.84
3.78
3.86
3.87

Cal

5.02
4.22
3.65
3.69
3.66
3.64
3.72
3.7
3.61
3.69
3.72
3.64
3.82
3.83
3.77
3.78

88.4

CO lbs

3.76

3.69

3.72

3.63

3.67

3.78

3.87

4

3.82

3.81

3.67

3.76

3.8

3.73

3.71

3.75

3.68

3.69

3.73

3.72

3.75

3.78

3.72

3.7

89.9

CO lbs

2.97

2.77

2.98

2.98

2.99

3.03

3.12

4.09

3.84

3.68

3.64

3.78
3.78
3.7
3.7
3.71
3.7
3.74
3.74
3.76
3.79
3.8
3.7
3.73

84.7

CO lbs

3.69
3.67
3.72
3.74
3.69
3.78
3.85
4
3.76
3.63
3.55
3.68
3.74
3.68
3.72
3.71
3.54
3.71
3.67
3.71
3.78
3.82
3.86
3.8

89.5

CO lbs

3.81
3.72
3.81
3.88
3.77
3.85
3.92
4.43
3.92
3.78
3.75
3.87
3.82
3.83
3.73
3.72
3.63
3.52
2.56
2.99
3.71
3.64
3.57
3.73